

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Midjil	Vemula	33KV	Jadcherla	00.00	09.20	09.20	E/L	2no Disc insulator failed	Midjil	-
2		Maddur	Kankurthy	33KV	Mahabubnagar	13.45	24.00	10.15	E/L	Under Breakdown	Maddur	-
3		Amarchintha	Amarchintha	33KV	Wanaparth	18.28	19.25	00.57	E/L	No Visible fault and AB Switch Opened at Mulamalla Lift	Amarchintha	-
4		Nagarkurnool	Bijinepally	33KV	Nagarkurnool	22.00	24.00	02.00	E/L	Under Breakdown	Nagarkurnool	-
5		Alampur	Alampur	33KV	Gadwal	13.15	14.55	01.40	E/L	Breaker Problem and 2 no HG fuse failed and Replaced	Alampur	-
1	MDK	Narsapur	RWS	33KV	Medak	13.10	15.35	02.25		B/D Due to tree branches fallen on the line	Narsapur	-
2		Chegunta	BONAL	33KV	Toopran	15.00	19.30	04.30		B/D Due to Pin Insulator failure	Chegunta	-
1	RR N	Medchal	GP Pally-II	33KV	Medchal	16.38	19.18	02.40		Due to 2 Nos pin insulators failed	Medchal	-
2		Malkaram	Shameeipet	33KV	Medchal	14.36	19.20	04.44		Due to pin binding removed	Malkaram	-
3		Lezimpet	Aliyabad	33KV	Medchal	19.30	21.15	01.45		Due to lighting arested	Lezimpet	-
4		bollaram	Satyam	33KV	Kukatpally	15.55	18.45	02.50		Due to Tree failen on line	bollaram	-

TSSPDCL - LMRC / Corporate office

Date: 28.09.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Sanginonipally	Vinjamoor	11KV	Mahabubnagar	15:00	16:00	1:00		11KV Insulator Damage near Ramanpally (V)	-
2		Gudeballore	Kothapally	11KV	Mahabubnagar	14:30	16:40	2:10		11KV Disk failure at Khandoddy (vi)	-
3		Kothamolgara	Kothamolgara	11KV	Jadcherla	10:30	13:00	2:30		11 kv Insulator fail near Patha molgara	-
4		Rajapur	Solguti	11KV	Jadcherla	14:45	18:35	3:50		AB Switch prable near Rajapur Rice mill	-
5		Veldanda	Kuppagandla	11KV	Jadcherla	10:40	14:30	3:50		11kv wire cut near Kuppagandla	-
6		Udithyal	Macharam	11KV	Jadcherla	8:30	11:00	2:30		Phase to Phase near Suraram	-
1	NLG	Aroor	Aroor Agl	11KV	Choutuppal	06.00	08.30	02.30	EL	Tree branches fallen On Line	-
2		Venkiryala	Pallegudem Indus	11KV	Bhongir	07.00	11.00	04.00	EL	11KV Line snapped	-
3		Kethepally	Korlapahad	11KV	Nalgonda	13.00	15.00	02.00	EL	11Kv line cut SS.11	-
4		Akaram	Vallala	11KV	Nalgonda	05.00	07.50	02.50	EL	11 KV insulator failed	-
5		Velugupally	Pasnoor	11KV	Suryapet	07.00	09.20	02.20	E/L	Jumper cut	-
6		Repala	Repala	11KV	Huzurnagar	05.00	07.00	02.00	E/L	11 kv inslater failed at Repala villege	-
7		Palakeedu	Bothalapalem	11KV	Huzurnagar	10.00	12.30	02.30	E/L	11 kv disk failed at Bothalapalem village	-
1	RR S	Manikonda	Hanumannagar	11KV	IBGH	13.28	16.01	02.33		11 KV Insulator fail at Shivapuri Colony	-
1	RR N	Ravolkol	IDA	11KV	Medchal	16.25	20.15	03.50		11 KV Insulator failed	-
2		Ushamullapudi	Crasar	11KV	Medchal	16.25	18.40	02.15		11 KV Insulator failed	-
3		Aliyabad	Majidpur	11KV	Medchal	16.50	19.30	02.40		11 KV Insulator failed & disc failure	-
4		Kodlakoya	Godraj	11KV	Medchal	16.50	22.00	05.10		Due to tree failen 11KV line	-
5		Miyapur	CPR	11KV	Kukatpally	16.20	17.40	01.20		11 KV Insulator failed	-
6		Miyapur	KTR colony	11KV	Kukatpally	16.35	17.10	00.35		11 KV Insulator failed	-
7		Bachupally	Sairam colony	11KV	Kukatpally	17.50	18.20	00.30		Due CTPT problam	-
8		Bachupally	SMS	11KV	Kukatpally	18.20	19.40	01.20		Due to pin insulator failed	-
9		Jeedimetla SS-IV	Tagur	11KV	Jeedimetla	13.10	14.35	01.25		Due to cable kit problem	-
10		Jeedimetla SS-I	Phase-II	11KV	Jeedimetla	16.55	18.00	01.05		Due to tree failen 11KV line	-
1		Moula-Ali	Kailasgiri	11KV	Sainikpuri	13.25	14.05	00.40		11Kv Disk failed at HB Colony Phase-I (LM Venkatesh)	-
2		Cherlapally-II	Junnuram	11KV	Sainikpuri	17.50	18.20	00.30		TEC Bulding near Heavy Flash Over at Rampally (ALM Mallesh)	-
3		IDA Uppal	Metro	11KV	HBG	17.20	19.05	01.45		11KV Line snapped near Neelima Organize at IDA Uppal	-
4		IDA Uppal	Srikrishna	11KV	HBG	17.20	19.05	01.45		11KV Line snapped near Neelima Organize at IDA Uppal	-
5		Mallapur-2	AP colony	11KV	HBG	13.35	14.25	00.50		Line patrolling but no visible fault	-
6		Mallapur-2	AP colony	11KV	HBG	17.10	18.38	01.28		11KV Pin Insulator failed at Lingamaiah Colony	-
7		Polytechnic	Vishal	11KV	HBG	18.02	18.42	00.40		Line patrolling but no visible fault & AB switch opend & Gokul Nagar feeder load Normalised	-

8	RR E	Polytechnic	srinivasapuram	11KV	HBG	18.02	18.43	00.41		Line patrolling but no visible fault & AB switch opened near Babu Rao Hotel	-
9		Ramanthapur	Ganesh Nagar	11KV	HBG	08.30	10.47	02.17		11KV Pin Insulator failed near Swagath Grand EHT T/F & AB switch opened near Dooradrshan Gate	-
10		Mallapur	Noma	11KV	HBG	18.10	19.50	01.40		11kv Disk fail & tree fallen on 11kv line at Vishnu teja Appartment	-
11		Nagaram	Gandhi nagar	11KV	HBG	18.20	19.19	00.59		11kv Pin insulator fail at west gandhi nagar	-
12		Narapally	Narapally	11KV	HBG	19.45	21.45	02.00		11kv line snapped & tree fallen on 11kv line at Ganesh nagar	-
13		Keesara	Collector office	11KV	HBG	19.20	22.20	03.00		line petroling done no visiable falt found & feeder back feeding from cheryala feeder	-
14		Singapur	I.T park	11KV	HBG	19.35	20.30	00.55		11kv insulator fail & 11kv line snapped at infoseys	-
15		Singapur	RGk	11KV	HBG	18.35	20.40	02.05		11kv insulator fail at power grade	
16	P&T colony	Chengicherla	11KV	HBG	13.40	14.50	01.10		Tree fallen on 11kv line at Kamala nagar	-	
1	HYD N	Zamistanpur	Sanjeevapuram	11KV	Sec-Bad	17.14	19.18	02.04	EL	Tree branches fallen on lines at S.R Hospital	
2		Film Nagar	MLA Colony	11KV	Banjarahills	21.36	01.00	03.24	OL-Bph	Pin Insulator flash over at Venkat Reddy Colony	-
3		Sanjeevaiah Park	Police Lines	11KV	Sec-Bad	19.45	22.50	03.05	EL	UG Cable fault at Opp. China Bowl	-
4		Zamistanpur	MCH Park	11KV	Sec-Bad	21.23	23.28	02.05	EL,OL-Rph	Tree branches fallen on lines at Zamistanpur	-
5		I.D.P.L.	Wonder Plast	11KV	Bowenpally	22.05	23.45	01.40	All Indication	Disc Insulator flash over at Bala Nagar	-
6		Gymkhana	Apollo	11KV	Sec-Bad	23.05	01.25	02.20	EL,OL-R&Bph	2Nos HT Lines snapped at Bata Show Room	-
1	HYD S	Asmangadh	GA Bank Colony	11KV	Asmangadh	12.55	14.45	01.50	EL,OL	Tree branches fallen on lines at SBH Colony	-----
2		Santosh Nagar	Bhavani Nagar	11KV	Asmangadh	13.00	14.20	01.20	Master Relay	Insulator flash over at Post Office	-----
3		Salarjung	Sadath Nagar	11KV	Asmangadh	14.30	15.58	01.28	EL,OL	-----	Arranged B/F on 11KV Bada Bazar feeder
4		Yakuthpura	Bada Bazar	11KV	Asmangadh	17.38	18.53	01.15	EL,OL-Rph	Faulty loads of 11KV Sadath Nagar fdr	-
5		Chanchalguda	Chanchalguda	11KV	Asmangadh	17.50	19.30	01.40	EL,OL-Rph	DTR fault at Anjuman DTR	-
6		Santosh Nagar	Jyothi Bagh	11KV	Asmangadh	19.05	21.05	02.00	EL,OL-Bph	Faulty loads of 11KV Saleema Khatoon fdr	-
7		Yakuthpura	Saleema Khatoon	11KV	Asmangadh	21.41	22.58	01.17	EL,OL-Yph	Line AB Switch fault at Rahamath Nagar Nalla	-
8		Karwan	Tallagadda OH	11KV	Begumbazar	19.50	20.56	01.06	Without Indication	No Visible Fault	Arranged B/F on 11KV Nalla Pochamma Temple fdr
9	Asmangadh	G.A.Bank Colony	11KV	Asmangadh	22.30	23.50	01.20	EL,OL	No Visible Fault	-	
1	HYD C	Golconda	Q.Q.Toombs	11KV	Mehdipatanam	17.55	21.05	03.10	All Indication	Cable fault at Gulshan Colony	-

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201		1		1		1			
5	RR(N)	82	407	4	10	4	10	4	10			
6	RR(E)	38	360		16		16		16			
7	Hyd	186	1014		16		16		16			
	Total	504	2929	4	43	4	43	4	43	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969	5	6	5	6	5	6			
2	NLG	150	948		7		7		7			
3	MDK	87	828	2		2		2				
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	7	13	7	13	7	13	0	0	
	Grand Total	908	6149	11	56	11	56	11	56	0	0	