

TSSPDCL - LMRC / Corporate office

Date: 29.09.2017

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	leeza	Venkatapuram	33KV	Gadwal	01.00	06.20	05.20	E/L	Due to Heavy Rain No Visabule Fault		-
1	NLG	Hanmapur	Anatharam	33KV	Bhongir	06.00	08.30	02.30	EL	33KV Insultor failed Near Hanmapur		-
2		Hanmapur	Bhongir	33KV	Bhongir	16.10	19.10	03.00	EL	33KV Insultor failed at Near Hanmapur Flyover		-
1	MDK	Jogipet	Laxmisagar	33KV	Jogipet	17.00	23.30	06.30		B/D due to Insulator failed		-
2		Palamakula	Rampur	33KV	Siddipet	17.50	22.10	04.20		B/D due to Pin Insulator failed		-
3		Palamakula	Narmeta	33KV	Siddipet	18.32	20.50	02.18		B/D due to After petrolling no fault at found		-
1	RR N	Medchal	Aliabad.	33KV	Medchal	10.01	12.00	01.59	BD	33KV Jumper cut and 33KV Disc failed at 132KV Medchal SS		-
2		Medchal	Keshawaram	33KV	Medchal	10.01	11.44	01.43	BD	No Fault		-

TSSPDCL - LMRC / Corporate office

Date: 29.09.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Koukuntla	Gopanpally	11KV	Mahabubnagar	08.30	09.50	01.20		11KV Tree fallen on conductor Near Jeenugurula (V)	-
2		Kondapur	Hanmanpally	11KV	Mahabubnagar	03.00	09.00	06.00		11KV Insulator Damage near aakumar Thanda (V)	-
3		Kondapur	Gotoor	11KV	Mahabubnagar	08.00	12.00	04.00		11KV Insulator Damage at Chandapur (V)	-
4		Marikal	Theelair	11KV	Mahabubnagar	16.15	17.35	01.20		11KV Insulator Failure Near Theelair (V)	-
5		Peddananadigama	Nandaram	11KV	Mahabubnagar	03.00	06.20	03.20		11KV Phase to Phase at Patharkunta Thanda V)	-
1	NLG	Arlagaddagudem	Tatikal	11KV	Nalgonda	21.15	23.05	01.50	E/L	11KV Jumper cut	-
2		Kethepally	Inupamula	11KV	Nalgonda	06.30	09.30	03.00	E/L	HT LT lines melting at Inupamula village	-
3		Kethepally	Cheekatigudem	11KV	Nalgonda	06.00	09.20	03.20	E/L	11KV Jumper cut	-
4		Aipoor	Aipoor	11KV	Suryapet	09.30	13.00	03.30	EL	Disk Failed	-
5		Yennaram	Suraram	11KV	Bhongir	06.00	08.40	02.40	EL	11KV Diskfailed	-
6		Yennaram	Kakireni	11KV	Bhongir	05.30	09.10	03.40	EL	11KV Diskfailed	-
7		Repala	N S gudem	11KV	Huzurnagar	02.00	09.00	07.00	EL	11 kv line snapped at N S Gudem village	-
1	MDK	Thogita	H.Ghanpur	11KV	Medak	06.15	07.15	01.00		B/D due to Disc Failed	-
2		Kowdipally	Mohd Nagar	11KV	Medak	01.00	06.30	05.30		B/D due to Disc Failed	-
3		Gavvalapally	Gavvalapally	11KV	Medak	07.22	08.49	01.27		B/D due to 11Kv Conductor Snapped.	-
4		Cheryal	Cheryal	11KV	Sangareddy	08.00	12.00	04.00		B/D due to Jumper cut	-
1	RR S	Gandhamguda	Kalimandir	11KV	RJNR	17.45	20.20	02.35		11KV Insulator failed at Bandlaguda Old village	-
2		Gaganpahad	Rajendranagar(GPH D)	11KV	RJNR	15.29	17.55	02.26		No visible fault Due to Rain	-
3		NPA	Babulreddy nagar	11KV	RJNR	07.15	08.44	01.29		No visible fault Due to Rain	-
1	RR N	Nizampet	Nizampet	11KV	Kukatpally	17.20	18.20	01.00	BD	Tree Branches Fallon the 11kv line at Mallanna Temple	-
2		Guntur Vikas	Co-Ca-Cola	11KV	Kukatpally	10.12	12.35	02.23	BD	11kv Line Cut Near Co-ca-Cola X Road	-
3		Vemana Colony	Suraksha Enclave	11KV	Kukatpally	01.19	02.40	01.21	BD	11kv line PinInsulater Failure at Vidyanagar Comman	-
4		Mayurinagar	Laxminagar	11KV	Kukatpally	16.17	17.05	00.48	BD	Tree Branches Fallon the 11kv line at Laxminagar	-
5		Jeedimetla-III	USP Organic	11KV	Jeedimetla	18.50	19.40	00.50	BD	11metar pole Bend at Sub-Station beside	-
6		GP Pally	GP Pally	11KV	Medchal	16.35	18.00	01.25	BD	Tree fallen on the 11KV Line at Railway Gate	-
7		Ravalkole	IDA	11KV	Medchal	16.40	19.40	03.00	BD	2 Nos 11KV Pin Insulator failed at Kashimbavi Thanda	-
8		Devarayamjal	Kottapet	11KV	Medchal	17.00	20.10	03.10	BD	Tree fallen on the 11KV Line at EMRI	-
9		Shameerpet	Shameerpet	11KV	Medchal	16.50	20.00	03.10	BD	No Fault	-
10		Medicity	Munirabad	11KV	Medchal	20.22	21.48	01.26	BD	63KVA T/F Brass Patti cut and replaced at Munirabad Village	-
11		Athiwelly	Ravalkole thanda	11KV	Medchal	21.10	22.40	01.30	BD	11KV Pin Insulator failed at Rekulabavi	-

1	RR E	Moula-JAli	Moula-JAli	11KV	Sainikpuri	00.40	01.20	00.40		Tree fallen on 11Kv line at Green Hills Colony (Foc Ravinder/AS Rao Nagar)	-
2		poyltechnic	Srinivasapuram	11KV	Habsiguda	13.24	14.36	01.12		Insulator fail at st no 3 srinivasapuram	-
3		Ramapally	Veneguda	11KV	Keesar	16.40	20.08	03.28		Insulator fail at Varshguda	-
4		Ramapally	Rampally	11KV	Keesar	17.40	20.40	03.00		Tree fallen on 11kv line at Nukalaguda	-
5		Ramapally	Industrial	11KV	Keesar	16.30	21.10	04.40		Tree fallen on 11kv line at RR poultary form	-
6		Keesara	Ankireddypally	11KV	Keesar	19.30	10.00	14.30		11kv line cut at Pedda cherevu	-
7		Keesara	Ankireddypally	11KV	Keesar	16.15	20.10	03.55		Line petroling done no visiable falt found line AB swith open at pedda cherevu	-
8		Keesara	Bogaram AGL	11KV	Keesar	19.30	12.30	17.00		2 11kv pole damaged & line AB swith open at Keesara gutta back side	-
1	HYD N	Bowenpally	Pipe Line Road	11KV	Bowenpally	17.30	18.45	01.15	OL-R&Yph	Tree branches fallen on lines at Road No.45	-
2		Lalaguda	Nagarjuna Nagar	11KV	Sec-Bad	18.10	20.40	02.30	EL	Big Tree fallen on lines at Sunday Market	-
3		Macha Bollaram	Radha Sathsang	11KV	Bowenpally	22.40	23.55	01.15	EL	Pin Insulator flash over at Rukmini Enclave	-

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201		3		3		3			
5	RR(N)	82	407	2	11	2	11	2	11			
6	RR(E)	38	360		8		8		8			
7	Hyd	186	1014		3		3		3			
	Total	504	2929	2	25	2	25	2	25	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969	1	5	1	5	1	5			
2	NLG	150	948	2	7	2	7	2	7			
3	MDK	87	828	3	4	3	4	3	4			
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	6	16	6	16	6	16	0	0	
	Grand Total	908	6149	8	41	8	41	8	41	0	0	