

**Status Report on Breakdowns (Urban / Rural)****Urban**

| S.No | Circle       | No.of Feeders Existing Urban |             | Breakdowns occurred during the day |          | Attended during the day |          | Time taken for restoring the supply |          |                                |          | Remarks (Pending) |
|------|--------------|------------------------------|-------------|------------------------------------|----------|-------------------------|----------|-------------------------------------|----------|--------------------------------|----------|-------------------|
|      |              | 33KV                         | 11KV        | 33KV                               | 11KV     | 33KV                    | 11KV     | Rectified (Within 24 Hours)         |          | Not Rectified (Above 24 Hours) |          |                   |
|      |              |                              |             |                                    |          |                         |          | 33KV                                | 11KV     | 33KV                           | 11KV     |                   |
| 1    | MBN          | 18                           | 107         |                                    |          |                         |          |                                     |          |                                |          |                   |
| 2    | NLG          | 22                           | 358         |                                    |          |                         |          |                                     |          |                                |          |                   |
| 3    | MDK          | 97                           | 359         |                                    |          |                         |          |                                     |          |                                |          |                   |
| 4    | RR(S)        | 53                           | 234         |                                    | 1        |                         | 1        |                                     | 1        |                                |          |                   |
| 5    | RR(N)        | 54                           | 550         |                                    | 1        |                         | 1        |                                     | 1        |                                |          |                   |
| 6    | RR(E)        | 168                          | 403         |                                    |          |                         |          |                                     |          |                                |          |                   |
| 7    | Hyd          | 194                          | 1044        |                                    |          |                         |          |                                     |          |                                |          |                   |
|      | <b>Total</b> | <b>606</b>                   | <b>3055</b> | <b>0</b>                           | <b>2</b> | <b>0</b>                | <b>2</b> | <b>0</b>                            | <b>2</b> | <b>0</b>                       | <b>0</b> |                   |

**Rural**

| S.No | Circle             | No.of Feeders Existing Rurals |             | Breakdowns occurred during the day |          | Attended during the day |          | Time taken for restoring the supply |          |                                |          | Remarks (Pending) |
|------|--------------------|-------------------------------|-------------|------------------------------------|----------|-------------------------|----------|-------------------------------------|----------|--------------------------------|----------|-------------------|
|      |                    | 33KV                          | 11KV        | 33KV                               | 11KV     | 33KV                    | 11KV     | Rectified (Within 24 Hours)         |          | Not Rectified (Above 24 Hours) |          |                   |
|      |                    |                               |             |                                    |          |                         |          | 33KV                                | 11KV     | 33KV                           | 11KV     |                   |
| 1    | MBN                | 107                           | 849         | 3                                  |          | 3                       |          | 3                                   |          |                                |          |                   |
| 2    | NLG                | 144                           | 988         |                                    | 2        |                         | 2        |                                     | 2        |                                |          |                   |
| 3    | MDK                | 107                           | 933         | 2                                  |          | 2                       |          | 2                                   |          |                                |          |                   |
| 4    | RR(S)              | 58                            | 396         |                                    |          |                         |          |                                     |          |                                |          |                   |
| 5    | RR(N)              | 38                            | 114         |                                    |          |                         |          |                                     |          |                                |          |                   |
| 6    | RR(E)              | 22                            | 133         |                                    |          |                         |          |                                     |          |                                |          |                   |
|      | <b>Total</b>       | <b>476</b>                    | <b>3413</b> | <b>5</b>                           | <b>2</b> | <b>5</b>                | <b>2</b> | <b>5</b>                            | <b>2</b> | <b>0</b>                       | <b>0</b> |                   |
|      | <b>Grand Total</b> | <b>1082</b>                   | <b>6468</b> | <b>5</b>                           | <b>4</b> | <b>5</b>                | <b>4</b> | <b>5</b>                            | <b>4</b> | <b>0</b>                       | <b>0</b> |                   |

TSSPDCL - LMRC / Corporate office

Date: 05.04.18

| S.No | Circle | Name of 33/11KV SS | Name of 11 KV Feeder | Vol  | Name of the Division | From  | To    | Duration | Relay Indication | Cause of Breakdown  | Alternate Supply Arranged |
|------|--------|--------------------|----------------------|------|----------------------|-------|-------|----------|------------------|---|---------------------------|
| 1    | NLG    | Ch.laxmapur        | Ch.laxmapur agl      | 11KV | Bhongir              | 20:00 | 22:30 | 2:30     | EL               | Insulator failed  | No                        |
| 2    |        | Aipoor             | Istalapuram          | 11KV | Suryapet             | 14.30 | 16.00 | 01.30    | EL               | Jumper Cut  | No                        |
| 1    | RR S   | Rajendranagar      | Pahadi               | 11KV | Rajendranagar        | 17:05 | 18:00 | 0:55     |                  | Tree branches fallen on the line                                    | No                        |
| 1    | RR N   | Jeedimetla SS-III  | USP Organics         | 11KV | Jeedimetla           | 11:50 | 16:30 | 4:40     | EL/OL            | 11kv line AB Cable Straight Through Joint failed near Mylon Company | No                        |

TSSPDCL - LMRC / Corporate office

Date: 05.04.18

| S.No | Circle | Name of 132/33KV SS | Name of 33 KV Feeder | Vol  | Name of the Division | From  | To    | Duration | Relay Indication | Cause of Breakdown                    | Sub Stations Effected | Alternate Supply Arranged   |
|------|--------|---------------------|----------------------|------|----------------------|-------|-------|----------|------------------|---------------------------------------|-----------------------|---|
| 1    | MBNR   | Mahabubnagar        | Jadcherla            | 33KV | Jadcherla            | 15.12 | 16.30 | 01.18    | E/L&O/L          | Insulator failed                      | Jadcherla             | Alternate Supply Arranged from 33KV Gangapur SS at 16:30 Hrs Supply Stud Ok |
| 2    |        | Mahabubnagar        | Machanpally          | 33KV | Mahabubnagar         | 06.44 | 07.16 | 00.32    | E/L&O/L          | Insulator failed                      | Machanpally           | No  |
| 3    |        | Polepally           | Gangapur             | 33KV | Jadcherla            | 16.55 | 18.45 | 01.50    | E/L              | Y-Phase clamp replaced                | Gangapur              | No  |
| 1    | MDK    | Manoharabad         | Suguna               | 33KV | Medak                | 17:38 | 21:10 | 3:32     |                  | Tree braches fallen on the line       | Suguna                | No  |
| 2    |        | Sadashivapet        | Munipally SS         | 33KV | Sangareddy           | 18.30 | 20.35 | 02.05    |                  | Station transformer failed at 220KVSS | Munipally SS          | No  |