

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	RR(S)	53	234	3	2	3	2	1	2	2		2 Nos. Still
5	RR(N)	54	550	3	27	3	27	3	27			
6	RR(E)	168	403		32		32		32			
7	Hyd	194	1044	2	221	2	221	2	220		1	1 No. Still
	Total	606	3055	8	282	8	282	6	281	2	1	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	5	2	5	2	4	2	1		1 No. Still
2	NLG	144	988		4		4		4			
3	MDK	107	933	19	11	19	11	14	11	5		5 Nos. Still
4	RR(S)	58	396									
5	RR(N)	38	114									
6	RR(E)	22	133									
	Total	476	3413	24	17	24	17	18	17	6	0	
	Grand Total	1082	6468	32	299	32	299	24	298	8	1	

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Konded	Chinna adirala	11KV	Jadcherla	09.00	11.00	02.00		Tree follen on 11 kv line near Thupdagadda thanda (v)	No
2		Gangapur	Alwan pally	11KV	Jadcherla	06.20	09.10	02.50		Tree follen on 11 kv line near kurvagadda pally (v)	No
1	NLG	Kudakuda	Komatikunta	11KV	Suryapet	9:40	12:30	2:50	E/L	11Kv Jumper cut	No
2		Pamanagundla	Yerasanigudem	11KV	Nalgonda	06.00	08.30	02.30	E/L	11 KV Line Insulator Failed at Yerasanigudem	No
3		Chandhampet	Mudidhandla	11KV	Devarakonda	08.00	10.00	02.00	E/L	11Kv Conductor Sanppd	No
4		Kamareddy gudem	Konathalapally	11KV	Miryalaguda	04.00	08.00	04.00	E/L	11Kv Pin insulator failed	No
1	MDK	Pillikotyal	Pillikotyal	11KV	Medak	0:00	8:45	8:45		Due to heavy rain	No
2		Pillikotyal	Nawabpet	11KV	Medak	00.00	08.45	08.45		Due to heavy rain	No
3		Medak	Ausulapally	11KV	Medak	00.00	05.30	05.30		Due to heavy rain	No
4		Medak	Kuchanpally	11KV	Medak	00.00	05.30	05.30		Due to heavy rain	No
5		Medak	Komtur	11KV	Medak	00.00	05.30	05.30		Due to heavy rain	No
6		Thogita	Aurangabad	11KV	Medak	00.00	11.30	11.30		Tree fallen on the line	No
7		Thogita	H.Ghanpur	11KV	Medak	00.00	10.00	10.00		Due to heavy rain	No
8		Thogita	Kuchanpally	11KV	Medak	00.00	07.05	07.05		Due to heavy rain	No
9		Reddypally	Reddypally	11KV	Medak	04.40	06.30	01.50		Jumper cut	No
10		Amsanpally	Kongode	11KV	Medak	00.00	11.00	11.00		Due to heavy rain	No
11		H.Ghanpur	Aurangabad	11KV	Medak	00.00	10.05	10.05		11KV Wire cut	No
1	RR S	Rajendranagar	Pahadi	11KV	Rajendranagar	22:52	0:18	1:26		Tree branches fallen on 11kv line at Kishori Masjid	No
2		Rajendranagar	Univarcity	11KV	Rajendranagar	20:10	23:55	3:45		Tree branches fallen on 11kv line at University	No
1		Mayurinagar	Mayurinagar	11KV	Kukatpally	20:47	22:30	1:43		HT line Cut at Sony Garden ,Mayurinagar	No
2		Mayurinagar	Cable	11KV	Kukatpally	21:22	22:45	1:23		Due To Havy Rain	No
3		Mayurinagar	Laxminagar	11KV	Kukatpally	22:30	0:10	1:40		Stick fallon the 11kv line near Sai baba temple at laxminagar	No
4		Nizampet	Journalist colony	11KV	Kukatpally	19:50	22:00	2:10		HG Fuse Insulater failur at Hydernagar Cheruvu Katta	No
5		Vikas	Apparna	11KV	Kukatpally	21:18	22:20	1:02		Due To Havy Rain	No
6		HMT	Sriramnagar	11KV	Kukatpally	21:45	22:40	0:55		Due To Havy Rain	No
7		HMT	Addagutta	11KV	Kukatpally	21:40	22:20	0:40		Due To Havy Rain	No
8		Shemshiguda	Janmabumi Colony Janmabumi Colony Janmabumi Colony Janmabumi Colony Janmabumi Colony Janmabumi Colony Janmabumi Colony Janmabumi Colony Janmabumi Colony Janmabumi Colony Janmabumi Colony	11KV	Kukatpally	21:45	22:25	0:40		Due To Havy Rain	No
9	RR N	Vijayanagar	Arunasocity	11KV	Kukatpally	22:00	22:55	0:55		Tree fallen on the 11kv line at Road:3. Jayanagar	No
10		KPHB	Gowthaminagar	11KV	Kukatpally	19:45	22:41	2:56		Due To Havy Rain	No
11		Hudatruckpark	Srisai Nagar	11KV	Kukatpally	20:00	22:30	2:30		Due To Havy Rain	No
12		Hudatruckpark	Sangeethnagar	11KV	Kukatpally	20:02	22:36	2:34		Due To Havy Rain	No
13		Mayurinagar	Ramnareshnagar	11KV	Kukatpally	23:00	0:35	1:35		Due To Havy Rain	No
14		HMT	Sriramnagar	11KV	Kukatpally	21:45	23:10	1:25		Due To Havy Rain	No

15	JDMSS-II	Kompally phormay	11KV	Jeedimetla	20:20	23:15	2:55		11kv line Pin insulator failure near Rakash Four Mill ,opp:Phase-III	No
16	JDMSS-II	NRSA	11KV	Jeedimetla	21:52	23:55	2:03		11kv line AB Cable failure at Srivari Hospital, opp:phase-IV	No
17	Aleap	Doctors Colony	11KV	Jeedimetla	0:10	1:18	1:08		11kv line Twist & Jumper Cut at near Plot: 1941 ,Aleap	No
18	JDMSS-V	Jagadambba	11KV	Jeedimetla	20:06	0:30	4:24		11kv line AB Cable Failure at opp: Jagadambba company	No
19	JDMSS-V	Wingtools	11KV	Jeedimetla	21:55	23:15	1:20		11kv line Jumper cut & touch the Crasaram at Phase-IV	No
20	Jagathgirigutta	Jagathgirigutta	11KV	Medchal	20:20	21:40	1:20		Tree fallen on 11KV Line at Jagathgirigutta	No
21	Subash Nagar	Jeedimetla	11KV	Medchal	20:15	22:00	1:45		Metiral fallen on the 11KV Line Jeedimetla Village	No
22	Subash Nagar	Ramaraj Nagar	11KV	Medchal	20:15	22:50	2:35		Tree fallen on 11KV Line at Ramaraj nagar	No
23	Subash Nagar	Suchitra	11KV	Medchal	21:00	23:30	2:30		11KV Line cut and replaced at Suchitra X Road	No
24	ICICI	Uniq Biotech-I	11KV	Medchal	18.42	20.32	01.50		11KV Jumper cut and replaced near SS	No
25	Medicity	IDA	11KV	Medchal	19.00	00.30	05.30		Tree fallen on 11KV Line at Medicity comman	No
26	Bandamadaram	Robosand	11KV	Medchal	22.40	02.20	03.40		11KV Disc failed at Bandamadaram X Road	No
27	Medchal	Checkpost	11KV	Medchal	18:50	21:20	2:30		11KV Line cut & replacement REVL Company	No
1	IICT	Nacharam	11KV	Habsiguda	20:30	22:15	1:45		Tree fallen on 11KV line near CK Garden	No
2	IICT	Snehapuri	11KV	Habsiguda	20:30	22:20	1:50		Tree fallen on 11KV line near E-Seva at HMT Nagar	No
3	IICT	CCMB	11KV	Habsiguda	20:30	22:15	1:45		Tree fallen on 11KV line at Nacharam Police Station Backside	No
4	Nacharam Indore	Vyjayanthi	11KV	Habsiguda	21:27	23:40	2:13		Tree fallen on 11KV line at Nacharam ESI Hospital	No
5	Nacharam	Multisteel	11KV	Habsiguda	20:25	22:25	2:00		Line patrolling but visible fault due to heavy rain and gale	No
6	Nacharam	Stallion Tyres	11KV	Habsiguda	20:34	23:10	2:36		Line patrolling but visible fault due to heavy rain and gale	No
7	Nacharam	Nile	11KV	Habsiguda	21:30	23:45	2:15		Tree branhes fallen on 11KV line near Nile Company	No
8	Nacharam	Chandamama	11KV	Habsiguda	20:30	22:30	2:00		Line patrolling but visible fault due to heavy rain and gale	No
9	Techpark	Balaji	11KV	Habsiguda	20:29	0:25	3:56		Tree fallen on 11kv line near Balaji Company	No
10	Techpark	Srikrishna Pharma	11KV	Habsiguda	20:20	21:52	1:32		11KV Copper patti touched to 11KV AB switch Pipe near Bandla Print Company	No
11	Techpark	Haryanasteel	11KV	Habsiguda	20:48	0:02	3:14		Tree fallen on 11kv line near Rolex Company	No
12	Techpark	Techpark	11KV	Habsiguda	20:46	23:50	3:04		Tree fallen on 11kv line near SS Yard	No
13	NGRI	Habsiguda	11KV	Habsiguda	20:27	21:30	1:03		11KV Disc Insulator failed	No
14	Mallapur	BEL	11KV	Habsiguda	20:30	22:40	2:10		11KV Brass patti cut near RS Wall Company and Tree branches fallen on 11KV line near Lotus Chekodia	No
15	Mallapur	Noma	11KV	Habsiguda	20:20	22:30	2:10		11KV Pin Insulator failed near Jenuram Colony	No
16	VP Nagar	RK Puram	11KV	Sainikpuri	21:08	22:00	0:52		Tree fallen on 11Kv line at near Water Tank VP Nagar	No
17	VP Nagar	RK Puram	11KV	Sainikpuri	22:51	23:35	0:44		11Kv Polimer Disk failure at RK Puram Raithu Bazar	No
18	Cherlapally-IV	Sai Nagar	11KV	Sainikpuri	20:40	22:40	2:00		Tree fallen on 11Kv line at Preded Compony	No
19	Kushaiguda	Rukminipuri	11KV	Sainikpuri	21:30	22:30	1:00		Tree fallen on 11Kv line at Arul Colony	No
20	Chengicherla	My Villas	11KV	Keesara	21:55	22:45	0:50		Line patrolling but visible fault due to heavy rain and gale	No
21	Saketh	Jawahar Nagar	11KV	Keesara	21:30	22:45	1:15		Line patrolling but visible fault due to heavy rain and gale and Line AB switch opened at Sai Baba Nagar	No
22	Yadgarpally	Yadgarpally	11KV	Keesara	20:15	23:15	3:00		11KV Jumper cut near Jai Bharath Machine	No
23	Yadgarpally	Thimmaipally	11KV	Keesara	23:46	1:14	1:28		11KV Pin insulator failed near Bharath Petrol Bunk	No
24	Rampally Dayara	Vannaeguda AGL	11KV	Keesara	22:05	23:30	1:25		Line patrolling but visible fault due to heavy rain and gale	No

25		Rampally Dayara	Vannaeguda Indl	11KV	Keesara	22:05	0:30	2:25		Tree fallen on 11KV line near Bala Saraswathi Crusher	No
26		Rampally Dayara	Rampally Dayara	11KV	Keesara	22:05	0:40	2:35		11KV line cut near Sampath Rao Thota	No
27		Keesara	Bogaram	11KV	Keesara	22:30	23:25	0:55		No visible fault	No
28		Keesara	Anki Reddy Pally	11KV	Keesara	22:15	0:48	2:33		11KV line twisted near GM Function Hall	No
29		Ghatkesar	Yamanumpet	11KV	Keesara	22:30	00:00	01:30		11KV Disc failed at Yamanumpet Village	No
30		P and T Colony	Medipally	11KV	Keesara	21.40	22.50	01.10		GI Wire fallen on 11kv line at Medipally	No
31		P and T Colony	NIN	11KV	Keesara	21.45	23.00	01.15		11KV Brass patti cut at P & T Colony	No
32		Pocharam	Jodimetla	11KV	Keesara	22:55	2:15	3:20		Tree branches fallen on 11kv line near Medha Opposite	No
1	HYD N	Jubilee Hills	Art Gallery	11KV	X	20.25	21.50	01.25	EL	No Visible Fault	No
2		Jubilee Hills	Jubilee Hills	11KV	X	20:30	21:55	1:25	EL,OL	No Visible Fault	No
3		Jubilee Hills	P.E.I. OH	11KV	X	20:05	21:40	1:35	EL,OL-Bph	No Visible Fault	No
4		Mothi Nagar	Rajiv Nagar	11KV	IV	20:36	22:30	1:54	EL	No Visible Fault	No
5		Road No.12	N.B.T.Nagar	11KV	X	20:30	22:25	1:55	EL	Tree branches fallen on lines at Mithila Nagar	No
6		Road No.13	Road No.1	11KV	X	20:20	0:20	4:00	EL,OL-Rph	No Visible Fault	No
7		Bora Banda	SRT Nagar Market	11KV	IV	20:12	22:50	2:38	EL,OL	Kite Sticks on lines at Vanitha Super Market	No
8		Chinthal	Caption Gas	11KV	VI	20:10	23:10	3:00	EL	No Visible Fault	No
9		Bowenpally	Jaya Nagar	11KV	VI	20:10	22:15	2:05	EL	No Visible Fault	No
10		Bowenpally	B.B.R.Hospital	11KV	VI	20:10	21:35	1:25	EL	No Visible Fault	No
11		Bowenpally	Kalinga Enclave	11KV	VI	20:10	21:35	1:25	EL	No Visible Fault	No
12		Bowenpally	Akshaya Enclave	11KV	VI	20:15	21:35	1:20	EL	No Visible Fault	No
13		Bowenpally	Plassy Line	11KV	VI	20:15	21:35	1:20	EL	No Visible Fault	No
14		Bowenpally	Pipe Line	11KV	VI	20:15	21:35	1:20	EL	No Visible Fault	No
15		Bowenpally	Sancharpuri Colony	11KV	VI	20:20	22:35	2:15	EL	No Visible Fault	No
16		Toli Chowki	Road No.86	11KV	X	20:20	23:06	2:46	EL	Tree branches fallen on lines at Kiran Kumar Reddy's House	No
17		Mothi Nagar	B.S.Puri	11KV	IV	20:16	21:30	1:14	EL,OL-Bph	No Visible Fault	No
18		Road No.2	D.K.Basthi	11KV	X	21:02	23:55	2:53	OL-Rph	Tree branches fallen on lines at Road No.5	No
19		Road No.2	E-Seva	11KV	X	21:01	22:50	1:49	EL	Tree branches fallen on lines at Road No.3	No
20		H.A.L.	Indian Rubber	11KV	VI	21:15	1:15	4:00	EL,OL-Rph	Cable fault (3No. DTR's kept off)	No
21		Bora Banda	Banjara Nagar	11KV	IV	20:38	21:40	1:02	EL	No Visible Fault	No
22		Nehru Nagar	Rezimental Bazar	11KV	V	20:12	22:40	2:28	EL	Pin Insulator flash over at Apollo Hospital	No
23		Kundanbagh	Transist Hostel	11KV	IV	21:35	22:51	1:16	EL,OL-Rph	HT Jumper cut at Transist Hostel	No
24		Hakimpet	Risala Bazar	11KV	VI	20:43	23:45	3:02	All Indication	No Visible Fault	No
25		Mothi Nagar	P.R.Nagar	11KV	IV	20:12	22:12	2:00	EL,OL-Bph	No Visible Fault	No
26		Bansilalpet	Naganna Kunta	11KV	V	20:30	1:12	4:42	EL,OL-Rph	No Visible Fault	No
27		Zamisthanpur	MCH Park	11KV	V	20:28	23:20	2:52	OL-R&Yph	Tree branches fallen on lines at Prem Apts	No
28		Nehru Nagar	Contonment	11KV	V	21:42	23:48	2:06	EL,OL	No Visible Fault	No
29		Nehru Nagar	West Marredpally	11KV	V	21:35	23:40	2:05	EL,OL-Rph	Brass Patti cut & touching to Pole at Konda Reddy DTR	No
30		H.A.L.	Sowbhagya Nagar	11KV	VI	22:12	1:20	3:08	EL,OL-Bph	Faulty 3No. DTR's at Anand Bhavan Hotel	No
31		Road No.12	Kanaka Durga	11KV	X	20:00	0:40	4:40	OL-Bph	Tree branches fallen on lines at Anand Banjara Colony	No
32		Macha Bollaram	Radha Sathsang	11KV	VI	20:15	21:20	1:05	OL-Bph	No Visible Fault	No
33		Macha Bollaram	Ayyappa Nagar	11KV	VI	20:20	21:25	1:05	EL	No Visible Fault	No
34		Macha Bollaram	Father Balaiah Nagar	11KV	VI	20:20	21:26	1:06	EL,OL	No Visible Fault	No
35		Chilkaiguda	Dandu Pentaiah	11KV	V	20:30	23:05	2:35	EL	Tree branches fallen on lines at Priyanka Towers	No
36		Chilkaiguda	New Boiguda	11KV	V	20:45	23:00	2:15	EL	Tree branches fallen on lines at Kamela	No
37		Chilkaiguda	Pragatools	11KV	V	20:48	22:38	1:50	EL	Tree branches fallen on lines at Pragatools	No
38		MLA Colony	Shopping Complex	11KV	X	21:10	22:58	1:48	EL,OL-R&Ypjh	Line AB Switch sparking at Syed Nagar	No
39		Vasanthapuri	Shesha Pahadi	11KV	V	20:32	22:07	1:35	EL,OL	No Visible Fault	No
40		Vasanthapuri	Siripuri	11KV	V	20:28	22:54	2:26	OL	No Visible Fault	No
41		Chinna Thokatta	Central Excise	11KV	VI	20:05	21:20	1:15	All Indication	No Visible Fault	No
42		Chinna Thokatta	Hasmathpet	11KV	VI	20:05	21:10	1:05	All Indication	No Visible Fault	No

43	Gymkhana	Balamrai	11KV	V	20:30	23:20	2:50	EL	Tree branches fallen on lines	No
44	Gymkhana	Tadbun Temple	11KV	V	20:30	22:10	1:40	EL	Tree branches fallen on lines	No
45	Gymkhana	Vasavi Nagar	11KV	V	20:30	22:20	1:50	EL	Tree branches fallen on lines	No
46	Kalyan Nagar	Rahamath Nagar	11KV	X	20:47	22:10	1:23	EL	Tree branches fallen on lines at Pochamma Temple	No
47	N.I.M.S.	Tata Rao	11KV	X	20:05	21:25	1:20	EL,OL	No Visible Fault	No
48	I.D.P.L.	SIFCO	11KV	VI	20:15	22:10	1:55	EL	No Visible Fault	No
49	Begumpet	Maitrivanam	11KV	IV	20:20	21:50	1:30	EL	No Visible Fault	No
50	I.D.P.L.	Wonder Plast	11KV	VI	21:10	22:20	1:10	EL,OL	No Visible Fault	No
51	Bowenpally	Ferozguda	11KV	VI	23:20	0:50	1:30	EL	Flexi fallen on lines at Good Star Hotel	No
52	Bowenpally	I.A.F	11KV	VI	23:20	0:50	1:30	EL	Flexi fallen on lines at Good Star Hotel	No
53	N.I.M.S.	Chief Justice	11KV	VI	20:21	21:50	01:29	EL	No Visible Fault	No
1	Miralam	Hasan Nagar	11KV	III	00:30	04:45	04:15	EL,OL-Rph	Cable fault at Danamma Jopdi	No
2	Petlaburz	Gansi Bazar	11KV	III	9:25	12:55	3:30	EL	Cable fault at High Court Gate No.5 (09:55 Hrs partial fdr charged upto 12Amps)	No
3	Miralam	Madina Masjid	11KV	III	9:35	10:50	1:15	EL,OL-Rph	Cable fault at Bada Nala	Arranged B/F on 11KV Hasan Nagar feeder
4	Malakpet B-Block	L.I.C.	11KV	VIII	20:26	22:03	1:37	OL-R&Yph	No Visible Fault	No
5	Malakpet B-Block	Ekalavya Nagar	11KV	VIII	20:29	22:06	1:37	OL-Rph	No Visible Fault	No
6	Malakpet B-Block	Akber Bagh	11KV	VIII	20:53	22:32	1:39	OL-Rph	No Visible Fault	No
7	Miralam	Hasan Nagar	11KV	III	20:06	23:10	3:04	EL,OL	Tree branches fallen on lines at Madina Masjid	No
8	Miralam	Ranjan Colony	11KV	III	20:07	1:10	5:03	EL,OL	Cable fault at Maqsood PT	No
9	Miralam	Ansari Road	11KV	III	20:10	22:35	2:25	EL,OL	Tree branches fallen on lines at Ansari Road Chowrastha	No
10	Miralam	Kalapather	11KV	III	20:10	22:40	2:30	EL,OL	No Visible Fault	No
11	Miralam	Teegala Kunta	11KV	III	22:05	0:30	2:25	EL,OL	HT Line snapped at Teegala Kunta	No
12	Miralam	MCH Colony	11KV	III	22:23	0:20	1:57	EL,OL	No Visible Fault	No
13	Miralam	N.S.Kunta	11KV	III	22:25	1:00	2:35	EL,OL	No Visible Fault	No
14	Panjasha	Sultan Shai	11KV	III	20:14	23:34	3:20	EL	No Visible Fault	No
15	Aliabad	Rooplal Bazar	11KV	III	20:23	23:15	2:52	EL	No Visible Fault	No
16	Aliabad	Satter Bagh	11KV	III	20:25	23:34	3:09	EL	No Visible Fault	No
17	Gunj	Hanuman Temple	11KV	VIII	20:25	23:00	2:35	EL,OL-Rph	No Visible Fault	No
18	Gunj	Race Course	11KV	VIII	20:36	22:10	1:34	EL,OL-R&Bph	No Visible Fault	No
19	Gunj	Palton	11KV	VIII	20:50	22:59	2:09	OL-R&Yph	No Visible Fault	No
20	Gunj	Super Bazar	11KV	VIII	20:40	23:35	2:55	EL,OL-Yph	Faulty DTR at Reliance Fresh	No
21	Gunj	Gunj	11KV	VIII	20:48	23:32	2:44	EL,OL-Rph	No Visible Fault	No
22	Panjasha	Metherwadi	11KV	III	20:29	22:16	1:47	EL	No Visible Fault	No
23	Panjasha	Bibi Bazar	11KV	III	20:50	22:22	1:32	EL	No Visible Fault	No
24	Aliabad	Police Quarters	11KV	III	20:07	23:05	2:58	EL	No Visible Fault	No
25	Santosh Nagar	Moin Bagh	11KV	III	20:30	22:20	1:50	All Indication	No Visible Fault	No
26	Laxmi Nagar	Laxmi Nagar	11KV	VIII	20:24	22:30	2:06	EL	No Visible Fault	No
27	Santosh Nagar	Bhavani Nagar	11KV	VIII	20:35	22:27	1:52	EL	No Visible Fault	No
28	Santosh Nagar	Jahangir Nagar	11KV	VIII	20:40	22:24	1:44	OL-R&Bph	No Visible Fault	No
29	Santosh Nagar	Jyothi Bagh	11KV	VIII	20:40	21:58	1:18	OL-R&Bph	No Visible Fault	No
30	Santosh Nagar	Santosh Nagar Colony	11KV	VIII	20:41	22:28	1:47	EL,OL-Bph	No Visible Fault	No
31	Santosh Nagar	SRT Colony	11KV	VIII	20:45	22:55	2:10	EL	No Visible Fault	No
32	Laxmi Nagar	Vinay Nagar	11KV	VIII	20:32	23:04	2:32	EL	No Visible Fault	No
33	Laxmi Nagar	Edgah	11KV	VIII	20:46	23:00	2:14	EL	No Visible Fault	No
34	Laxmi Nagar	Dhobi Ghat	11KV	VIII	21:12	22:59	1:47	EL	No Visible Fault	No
35	Salarjung	Purani Haveli	11KV	III	20:25	23:10	2:45	All Indication	HT Jumper cut at Chetta Bazar	No
36	Gosha Mahal	Feelkhana	11KV	IX	20:45	21:50	1:05	EL,OL-Rph	No Visible Fault	No
37	Gosha Mahal	M.J.Market	11KV	IX	20:45	22:25	1:40	EL,OL-Rph	No Visible Fault	No
38	Gosha Mahal	Hindi Nagar	11KV	IX	20:48	22:05	1:17	EL	No Visible Fault	No
39	Gosha Mahal	Gyanbagh Colony	11KV	IX	20:48	22:10	1:22	EL	No Visible Fault	No
40	Gosha Mahal	Gosha Mahal	11KV	IX	20:48	22:05	1:17	EL	No Visible Fault	No
41	Aliabad	Sharadha College	11KV	III	20:30	23:30	3:00	EL	No Visible Fault	No

42	Seetharambagh	Dattatreya Nagar OH	11KV IX	20:15	22:50	2:35	EL,OL	No Visible Fault	No
43	Seetharambagh	Agapura	11KV IX	21:35	23:00	1:25	OL-R&Bph	No Visible Fault	No
44	Asmangadh	Tirumalagiri	11KV VIII	20:25	21:40	1:15	EL	No Visible Fault	No
45	Asmangadh	Saidabad Colony	11KV VIII	20:30	21:45	1:15	EL	No Visible Fault	No
46	Asmangadh	G.A.Bank Colony	11KV VIII	22:32	23:50	1:18	EL	No Visible Fault	No
47	Asmangadh	Shiva Ganga	11KV VIII	22:35	23:52	1:17	EL	No Visible Fault	No
48	Durga Nagar	MRO Office	11KV VIII	22:00	23:25	1:25	EL,OL	Tree branches fallen on lines at Moosarambagh	No
49	Kanchanbagh	Riyasath Nagar	11KV III	20:22	22:15	1:53	EL	No Visible Fault	No
50	Kanchanbagh	Darga	11KV VIII	20:30	21:52	1:22	EL	No Visible Fault	No
51	Kanchanbagh	Jamal Colony	11KV VIII	20:33	21:50	1:17	EL,OL	No Visible Fault	No
52	Kanchanbagh	Jamal Colony	11KV VIII	21:55	23:18	1:23	EL	No Visible Fault	No
53	Kanchanbagh	I.S.Sadan	11KV VIII	20:45	21:49	1:04	EL	No Visible Fault	No
54	Kanchanbagh	Kanchanbagh	11KV VIII	21:04	23:22	2:18	EL	No Visible Fault	No
55	C.R.P.F.	Keshavgiri	11KV III	20:15	23:30	3:15	EL	No Visible Fault	No
56	C.R.P.F.	Baba Nagar	11KV III	20:20	22:56	2:36	EL	No Visible Fault	No
57	C.R.P.F.	Balapur	11KV III	20:27	22:57	2:30	EL	No Visible Fault	No
58	C.R.P.F.	Salala	11KV III	20:32	22:59	2:27	EL	No Visible Fault	No
59	C.R.P.F.	C.R.P.F.	11KV III	20:32	3:00	6:28	EL	Tree branches fallen on lines at C.R.P.F. Campus	No
60	C.R.P.F.	Omer Colony	11KV III	20:35	0:10	3:35	EL	HT Line snapped at Omer Colony	No
61	C.R.P.F.	Jamal Banda	11KV III	20:36	22:50	2:14	EL,OL	No Visible Fault	No
62	C.R.P.F.	Maisaram	11KV III	20:38	22:55	2:17	EL,OL	No Visible Fault	No
63	C.R.P.F.	Barkas	11KV III	20:25	23:40	3:15	EL,OL	No Visible Fault	No
64	Petlaburz	Hussaini Alam	11KV III	20:40	22:05	1:25	EL,OL	No Visible Fault	No
65	Petlaburz	Chowk	11KV III	20:22	21:38	1:16	EL	No Visible Fault	No
66	Falaknuma	Falaknuma UG	11KV III	20:10	23:50	3:40	EL	Tree branches fallen on lines	No
67	Falaknuma	Farooq Nagar	11KV III	20:17	21:50	1:33	EL	No Visible Fault	No
68	Falaknuma	Chatrinaka	11KV III	21:50	23:20	1:30	EL	Tree branches fallen on lines	No
69	Falaknuma	Jangammet OH	11KV III	20:14	23:25	3:11	EL	Tree branches fallen on lines	No
70	Panjasha	Panch Mohallah	11KV III	21:04	23:00	1:56	EL,OL	No Visible Fault	No
71	Khilwath	Laladarwaza	11KV III	20:20	21:50	1:30	EL	No Visible Fault	No
72	Kandikal Gate	Kandikal Gate	11KV III	20:15	21:40	1:25	EL	No Visible Fault	No
73	Kandikal Gate	G.M.Chowni	11KV III	20:20	21:45	1:25	EL	No Visible Fault	No
74	Kandikal Gate	Saibaba Nagar	11KV III	20:25	21:45	1:20	EL	No Visible Fault	No
75	Kandikal Gate	Phool Bagh	11KV III	20:25	21:55	1:30	EL	No Visible Fault	No
76	Kandikal Gate	Naseeb Nagar	11KV III	20:28	21:40	1:12	EL	No Visible Fault	No
77	Kandikal Gate	Indira Nagar	11KV III	20:30	21:40	1:10	EL	No Visible Fault	No
78	Kandikal Gate	Rakshapuram	11KV III	20:35	21:40	1:05	EL	No Visible Fault	No
79	Teegalaguda	Teegalaguda	11KV VIII	20:26	22:45	2:19	OL-R&Yph	Jumper cut at near SS	No
80	Teegalaguda	Milk Booth	11KV VIII	20:27	21:30	1:03	OL-R&Yph	No Visible Fault	No
81	Teegalaguda	H.B.Colony	11KV VIII	21:50	23:05	1:15	EL,OL-Rph	No Visible Fault	No
82	Sultan Bazar	Sultan Bazar	11KV IX	21:35	23:10	1:35	EL,OL-Rph	Tree branches fallen on lines at Hanuman Vaiyam Shalal	No
83	Jiyaguda	Goshala	11KV IX	20:15	23:00	02:45	EL,OL-Rph	Tree branches fallen on lines at Goshala	No
1	Toli Chowki	Kala Banglow	11KV VII	20:01	22:33	02:32	EL	Twisted lines at Govt. High School	No
2	Toli Chowki	Hakimsha	11KV VII	20:13	22:05	01:52	EL	No Visible Fault	No
3	Toli Chowki	B.S.N.L.	11KV VII	20:20	21:32	01:12	EL,OL-Rph	No Visible Fault	No
4	Mothi Mahal	Risala Bazar	11KV VII	20:03	22:40	02:37	EL,OL-Rph	Tree branches fallen on lines at Police Quarters	No
5	Mothi Mahal	Saleh Nagar	11KV VII	20:12	21:50	01:38	EL,OL-R&Bph	Tree branches fallen on lines at Saleh Nagar Kancha	No
6	Mothi Mahal	Company Bagh	11KV VII	20:15	23:20	03:05	EL,OL-R&Bph	AB Switch fault at Company Bagh	No
7	Golconda	O.U.Colony	11KV VII	20:05	23:15	03:10	EL	No Visible Fault	No
8	Exhibition	Collector Office	11KV I	20:40	23:50	03:10	EL,OL	Kite sticks on DTR Channel at Khaither Galli	No
9	Nampally	Nampally Hospital	11KV VII	21:21	00:15	02:54	EL,OL	No Visible Fault	No
10	Hyderguda	Urdu Hall	11KV I	20:31	22:05	01:34	EL	No Visible Fault	No
11	Hyderguda	Hyderguda	11KV I	20:32	22:35	02:03	EL	Faulty DTR at King Koti	No

12	Azamabad	Azamabad I.E	11KV II	20.30	22.55	02.25	EL	Tree branches fallen on Lines at Vidya Nagar	No
13	Golconda	Aditya Nagar OH	11KV VII	20.10	23.10	03.00	EL	No Visible Fault	No
14	Toli Chowki	Paramount Hills	11KV VII	20.17	22.56	02.39	EL,OL-Bph	Foreign material fallen on lines at Paramount Hills Gate No.1	No
15	Nampally	Red Hills	11KV VII	20.21	22.19	01.58	EL	No Visible Fault	No
16	Hyderguda	Boggula Kunta	11KV I	20.48	22.07	01.19	EL	No Visible Fault	No
17	Golnaka	Shivalayam	11KV II	21.58	01.42	03.44	EL	Pin Insulator flash over at Ganesh Nagar	No
18	Golnaka	Kamala Nagar	11KV II	22.03	01.05	03.02	EL,OL	Cable Jumper cut at Kamala Nagar	No
19	Toli Chowki	Paramount Hills	11KV VII	23.13	00.55	01.42	EL,OL-Bph	Disc Insulator flash over at P.M.R. Residency	No
20	Jawahar Nagar	Jawahar Nagar	11KV I	20.10	23.35	03.25	OL-Bph	No Visible Fault	No
21	Asif Nagar	N.S.F.Colony	11KV VII	20.14	22.30	02.16	EL	No Visible Fault	No
22	Asif Nagar	Mehdipatnam OH	11KV VII	20.15	23.20	03.05	EL	No Visible Fault	No
23	Asif Nagar	Mehdipatnam Cable	11KV VII	20.21	22.08	01.47	EL	No Visible Fault	No
24	Asif Nagar	Kakatiya Nagar	11KV VII	20.15	00.11	03.56	EL,OL-Rph	Tree branches fallen on lines at Military Area	No
25	Asif Nagar	Hakimpet	11KV VII	20.17	00.44	04.27	EL,OL-Rph	Tree branches fallen on lines at Hakimpet	No
26	Industrial Area	RTC X Road	11KV II	20.35	23.18	02.43	EL	Cable fault	Arranged B/F on 11KV Dayara Market fdr
27	Lake View	N.K.M.'s Hotel	11KV I	20.27	21.55	01.28	EL	No Visible Fault	No
28	Nizam College	Galaxy Hotel	11KV I	20.32	22.02	01.30	EL,OL-Rph	No Visible Fault	No
29	Asif Nagar	Toli Chowki	11KV VII	20.18	22.05	01.47	EL,OL-Bph	No Visible Fault	No
30	Asif Nagar	Military	11KV VII	20.20	02.56	06.36	EL,OL-Bph	Tree branches fallen on lines at Military Area	No
31	Langerhouse	Prashanth Nagar	11KV VII	20.13	22.10	01.57	EL	No Visible Fault	No
32	Asif Nagar	Toli Chowki	11KV VII	23.25	01.38	02.13	EL,OL-Bph	Tree branches fallen on lines at Toli Chowki	No
33	Fever Hospital	Fever Hospital	11KV II	20.30	21.45	01.15	EL	No Visible Fault	No
34	Fever Hospital	Nalla Kunta	11KV II	20.25	21.45	01.20	EL,OL-Bph	No Visible Fault	No
35	Fever Hospital	Sri Ram Nagar	11KV II	20.35	21.45	01.10	EL	No Visible Fault	No
36	Fever Hospital	C.C.S.Hospital	11KV II	20.35	21.45	01.10	EL	No Visible Fault	No
37	Fever Hospital	Tourist Hotel	11KV II	20.35	22.00	01.25	EL	No Visible Fault	No
38	Gudimalkapur	Sharadha Nagar	11KV VII	20.13	21.30	01.17	EL	Tree branches fallen on lines at Sharadha Nagar	No
39	Gudimalkapur	Navodaya Colony	11KV VII	20.22	23.05	02.43	OL-Bph	Tree branches fallen on lines at Navodaya Colony	No
40	Gudimalkapur	Amba Garden	11KV VII	20.28	23.06	02.38	OL-Rph	Tree branches fallen on lines at Amba Garden	No
41	I.T.I. Mallepally	Afzal Sagar	11KV VII	20.26	23.10	02.44	EL	Tree branches fallen on lines at Afzal Sagar	No
42	I.T.I. Mallepally	Zaheera Masjid	11KV VII	20.20	00.20	04.00	EL	Tree branches fallen on lines at Mallepally	No
43	I.T.I. Mallepally	P.S.Nagar	11KV VII	21.48	00.10	02.22	EL	Tree branches fallen on lines at P.S.Nagar	No
44	I.T.I. Mallepally	Indira Nagar	11KV VII	21.42	22.55	01.13	EL	Tree branches fallen on lines at Indira Nagar	No
45	I.T.I. Mallepally	Anwar UI Uloom	11KV VII	21.55	01.58	04.03	EL	Tree fallen on lines at Anwar UI Uloom College backside	No
46	Chilkaiguda	44 Bus Stop	11KV II	20.52	23.20	02.28	EL	Brass Patti B/O at Shankermutt	No
47	Nizam College	Galaxy Hotel	11KV I	22.06	02.12	04.06	EL	DTR Insulator flash over at Chutney Hotel	No
48	Bathkammakunta	C.E.Colony	11KV II	20.28	23.10	02.42	OL-Rph	Tree branches fallen on lines at Nandraj Goud DTR	No
49	Bathkammakunta	Shivam	11KV II	20.30	00.10	03.40	All Indication	HT Jumper cut at T.R.T. Quarters	No
50	Toli Chowki	Hakimsha	11KV VII	22.48	00.45	01.57	EL	DTR Insulator flash over at Server Nagar	No
51	Nampally	Pearl Regency	11KV VII	22.35	00.25	01.50	EL	No Visible Fault	No
52	Langerhouse	Fathe Darwaza	11KV VII	20.15	21.50	01.35	EL,OL-Rph	No Visible Fault	No
53	Langerhouse	Defence Colony	11KV VII	20.15	21.25	01.10	EL,OL-Rph	No Visible Fault	No
54	Langerhouse	Pensionpura	11KV VII	20.15	21.27	01.12	EL,OL-Rph	No Visible Fault	No
55	Langerhouse	Military Hospital	11KV VII	20.20	21.47	01.27	All Indication	No Visible Fault	No
56	Langerhouse	Netaji Nagar	11KV VII	20.25	22.40	02.15	EL,OL-R&Bph	Flexi fallen on lines at Jyothi Nagar Bus Stop	No
57	Amberpet	Zindatilismath	11KV VII	21.30	23.30	02.00	EL	Cable fault	Arranged B/F on 11KV Krishna Nagar fdr
58	S.D.Hospital	Humayun Nagar	11KV VII	21.58	00.22	02.24	EL	HT Jumper cut at Humayun Nagar	No
59	S.D.Hospital	C.C.Nehru Nagar	11KV VII	20.26	00.10	03.44	EL	Tree branches fallen on lines at Areef PT	No
60	S.D.Hospital	Khadi Bandar	11KV VII	20.30	01.44	05.14	OL-R&Bph	Cable Jumper cut at Khadi Bandar	No
61	S.D.Hospital	Ahmed Nagar Cable	11KV VII	21.53	00.29	02.36	EL,OL	Tree branches fallen on lines at Ahmed Nagar	No

62	S.D.Hospital	Police Mess	11KV	VII	20.22	00.05	03.43	EL,OL	HT Jumper cut at Chaman PT	No
63	S.D.Hospital	Ahmed Nagar OH	11KV	VII	20.20	01.02	04.42	EL,OL	Tree branches fallen on lines at Garden Towers	No
64	Jawahar Nagar	Bank of Baroda	11KV	I	20.30	23.10	02.40	OL-R&Bph	Tree branches fallen on lines at Bank of Baroda	No
65	Jawahar Nagar	Post Office	11KV	I	20.35	01.55	05.20		Pin Insulator flash over at Weights & Measurements	No
66	Z.P.Office	Seven Temple	11KV	I	20.46	22.12	01.26	EL,OL	No Visible Fault	No
67	Z.P.Office	Golconda Hotel	11KV	I	20.47	00.14	03.27	EL,OL	No Visible Fault	No
68	A.C.Guards	Mahaveer OH	11KV	I	20.25	22.40	02.15	EL,OL-R&Bph	Tree branches fallen on lines at Mahaveer Hospital backside	No
69	A.C.Guards	Shanthi Nagar	11KV	VII	20.12	21.20	01.08	EL	AB Cable fault at Shanthi Nagar	No
70	A.C.Guards	N.M.D.C.	11KV	VII	20.24	22.05	01.41	EL	No Visible Fault	No
71	Indira Park	R.K.Mutt	11KV	I	20.30	22.25	01.55	EL,OL-Rph	Tree branches fallen on lines	No
72	Indira Park	Gandhi Nagar	11KV	I	20.30	01.20	04.50	EL,OL-Rph	Tree branches fallen on lines	No
73	Indira Park	Domalguda	11KV	I	20.30	23.30	03.00	EL,OL-Rph	Tree branches fallen on lines	No
74	Indira Park	Secretariat	11KV	I	20.30	23.50	03.20	EL,OL-Rph	Tree branches fallen on lines	No
75	Indira Park	Kuchipudi	11KV	I	20.30	22.50	02.20	EL,OL-Rph	Tree branches fallen on lines	No
76	Erramanzil	Anugraha	11KV	I	20.33	23.55	03.22	EL	No Visible Fault	No
77	Erramanzil	I.C.Quarters	11KV	I	20.14	22.48	02.34	EL,OL-Bph	No Visible Fault	No
78	Bathkammakunta	Ahobilmutt	11KV	II	20.20	23.50	03.30	OL-Rph	No Visible Fault	No
79	Lake View	Dilkusha	11KV	I	20.15	22.00	01.45	EL	No Visible Fault	No
80	Narayanguda	Narayanguda	11KV	II	20.35	22.00	01.25	EL,OL	No Visible Fault	No
81	Golconda	Q.Q.Toombs	11KV	VII	21.10	23.20	02.10	EL	Tree branches fallen on lines & Faulty Loads of 11KV Shaikpet W.W. feeder	No
82	N.I.M.S.	Erramanzil	11KV	I	20.17	23.50	03.33	EL	Big tree fallen on lines at Erramanzil	No
83	A.S.R.Raju Nagar	J.K.Nagar	11KV	VII	20.10	23.45	03.35	EL	Tree branches fallen on lines at J.K.Nagar	No
84	A.S.R.Raju Nagar	Golla Basthi	11KV	VII	20.25	22.27	02.02	EL	Tree branches fallen on lines at Golla Basthi	No
85	Golconda	Shaikpet Water Works	11KV	VII	21.10	Still		EL,OL-Rph	Coconut tree branches fallen on lines	No

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effectuated	Alternate Supply Arranged	
1	MBNR	Marikal	Koilkonda Water Gird	33KV	Mahabubnagar	23.40	Still		E/L&O/L	Not Rectified	Koilkonda Water Gird	No	
2		Wanaparthy	Chinnamaroor	33KV	Wanaparthy	22.45	23.40	00.55	E/L	Back Feeding Supply Taken to 33KV Pebbair Feeder at 20:40Hrs Supply Stud Ok	Chinnamaroor	No	
3		Balanagar	Surya Jyothi	33KV	Jadcherla	20.48	23.20	02.32	E/L	Tree Fallen on the Line near at Sri Nedhye Roto Sam Industrial	Surya Jyothi	No	
4		Achampet	Amrabad	33KV	Nagarkurnool	15:45	18:35	2:50	E/L&O/L	No Visible Fault Due to Heavy Rain & Wind	Amrabad	No	
5		Achampet	Uppununthala	33KV	Nagarkurnool	15.50	21.45	05.55	E/L&O/L	Due to Heavy Rain & Wind and V Cross aaram Repalsment and Top clamp Replased near Forest Office at Achampet	Uppununthala	No	
1	MDK	Kowdipally	Amsanpally	33KV	Medak	23:52	Still				Amsanpally	No	
2		Jogipet	Chitkul	33KV	Medak	20.05	Still				Chitkul	No	
3		Jogipet	G.Peddapur	33KV	Medak	20.05	6:30	10.25			BD Due Heavy Wind & Gale	G.Peddapur	No
4		Kandi	HFC I	33KV	Sangareddy	18.20	Still					HFC I	At 02:00 hour Alternative supply arranged from HFC - II SS
5		Sadasivpet	Koheer	33KV	Sangareddy	19.00	Still					Koheer	At 01:00 hour Alternative supply arranged from Zaheerabad SS
6		Sadasivpet	Manjeera	33KV	Sangareddy	19.00	Still					Manjeera	At 01:00 hour Alternative supply arranged from Sangareddy SS
7		Chegunta	Chegunta	33KV	Toopran	19.55	01.05	05.10			BD Due to Jumper cut Near SS Daba	Chegunta	
8		Jogipet	Laxmi sagar	33KV	Medak	20.08	00.00	03.52			BD due to Tree Fallen on line	Laxmi sagar	
9		Narsapur	Kotha pet	33KV	Medak	17.55	00.40	06.45			BD due to Tree Fallen on line	Kotha pet	
10		Narsapur	Reddypally	33KV	Medak	21.25	00.35	03.10			BD Due Heavy Wind & Gale	Reddypally	
11		Narsapur	RWS	33KV	Medak	22.20	00.25	02.05			BD Due Heavy Wind & Gale	RWS	
12		Narsapur	Arobindo	33KV	Medak	23.05	00.30	01.25			BD Due Heavy Wind & Gale	Arobindo	
13		Pashamailaram	BPL	33KV	Sangareddy	20.02	22.05	02.03			BD due to Jumpercut	BPL	
14		Pashamailaram	Manjeera	33KV	Sangareddy	14.05	18.05	04.00			BD due to Tree Fallen on line	Manjeera	
15		Pashamailaram	APL5	33KV	Sangareddy	19.45	00.15	04.30			BD due to Tree Fallen on line	APL5	
16		Gummadidala	AFA	33KV	Sangareddy	23.30	00.20	00.50			BD due to Tree Fallen on line	AFA	
17		Gummadidala	Jinnaram	33KV	Sangareddy	21.45	23.25	01.40			BD Due Heavy Wind & Gale	Jinnaram	
18		Gummadidala	GPSS-2	33KV	Sangareddy	20.40	00.10	03.30			BD due to Tree Fallen on line	GPSS-2	
19		Bollaram	Meenakshi	33KV	Sangareddy	18:15	4:45	10:30			BD due to line cut	Meenakshi	
1	RR S	Sadashvapet	Mominpet	33KV	Vikarabad	20:50	7:30	11:10			Tree branches fallen on 33kv Line at MKV Pally	Mominpet	No
2		Shivarampally	Katedhan I	33KV	Rajendranagar	20.59	Still				Katedhan I		
3		Shivarampally	Kismathpur	33KV	Rajendranagar	21.07	Still				Kismathpur		
1	RR N	132KV LGM Pet	33KV LGM Pet	33KV	Medchal	20:45	23:13	2:28			Tripped on EL Indication (Due to heavy wind & rain)	33KV LGM Pet	No
2		132KV Medchal	33KV GP Pally-II	33KV	Medchal	16.26	19.07	02.41			33KV Cable failed & replacement near GP Pally Village	33KV GP Pally-II	No
3		132KV Medchal	33KV GP Pally-II	33KV	Medchal	20.30	23.20	02.50			33KV Pin Insulator failed at GP Pally Village	33KV GP Pally-II	No
1	HYD N	132KV J' Hills	I.T Properties	33KV	Kalyan Ngr	13.10	13.20	00.10	OL-Rph	Cable damaged by unknown person at Madhapur D-Mart	I.T Properties	3No. HT Service Loads diverted onto 132KV J' Hills SS via 33KV Sundew fdr	
1	HYD S	220KV Ch' Gutta	Malakpet Gunj (Asmangadh)	33KV	Malakpet	02.50	03.00	00.10	EL	Cable Joint failed near Jaya Nagar	Malakpet Gunj (Asmangadh)	Loads transferred onto 132KV Moosarmbagh SS	