

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	RR(S)	53	234									
5	RR(N)	54	550		7		7		7			
6	RR(E)	168	403		2		2		2			
7	Hyd	194	1044		3		3		3			
	Total	606	3055	0	12	0	12	0	12	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	6	16	6	16	6	16			
2	NLG	144	988		9		9		9			
3	MDK	107	933	16	22	16	22	16	22			
4	RR(S)	58	396									
5	RR(N)	38	114									
6	RR(E)	22	133									
	Total	476	3413	22	47	22	47	22	47	0	0	
	Grand Total	1082	6468	22	59	22	59	22	59	0	0	

TSSPDCL - LMRC / Corporate office

Date: 07.04.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Devarkadra	Koilsagar	11KV	Mahabubnagar	06.30	09.05	02.35		11KV Insulator Damage at Gurakonda	-
2		Devarkadra	Gaddegudem	11KV	Mahabubnagar	06.30	09.27	02.57		11KV Tree fallen on conductor Near baspally	-
3		Devarkadra	Devarkadra	11KV	Mahabubnagar	06.30	09.15	02.45		11KV Tree fallen on conductor Near boplapur	-
4		Jaklair	Bondalkunta	11KV	Mahabubnagar	06.00	10.00	04.00		11KV Tree fallen on conductor Near Bondalkunta	-
5		Jaklair	Gudigandla	11KV	Mahabubnagar	06.00	09.00	03.00		11KV Insulator Damage near Bapanpally	-
6		Mushtipally	Satyaram	11KV	Mahabubnagar	21.00	08.00	11.00		11KV Conductor cut near kondareddy (v)	-
7		Maganoor	Warkoor	11KV	Mahabubnagar	09.00	12.00	03.00		11KV Tree fallen on conductor Near Warkoor	-
8		Rajapur	Salgutti	11KV	Jadcherla	10.10	14.00	03.50		B.D.Cable Failed At Muddireddypally(Vi).	-
9		Rajapur	Mallepally	11KV	Jadcherla	11.00	14.30	03.30		DTR Failure At Mallepally(vi).	-
10		Rajapur	Chennavelly	11KV	Jadcherla	08.00	11.30	03.30		11 Kv Jumper Cut Near Kucharkal Tanda Side.	-
11		Badepally	Nagasala	11KV	Jadcherla	07.30	09.45	02.15		11 Kv Wire Cut Near Nasurllabad Tanda Side.	-
12		Badepally	Burgupally	11KV	Jadcherla	07.54	11.26	03.32		11 Kv Line Cut Near Aloor(vi).	-
13		Janampet	Water Works	11KV	Jadcherla	06.40	09.25	02.45		B.D.11Kv Wire Cut Near Moosapet(Vi).	-
14		Kandoor	Kandoor	11KV	Jadcherla	04.40	07.00	02.20		B.D.11 Kv Jumper Cut Near Addakal(Vi).	-
15		Ponnakal	Ponnakal	11KV	Jadcherla	08.00	11.35	03.35		11 Kv Jumper Cut Near ponnakal(Vi).	-
16		Ponnakal	Rachala	11KV	Jadcherla	07.10	10.00	02.50		Lt Poles Broken At Rachala(Vi).	-
1	NLG	Janapahad	Suryapahad	11KV	Huzurnagar	08.50	10.15	01.25	E/L	Jumper cut	-
2		Kalmalacheruvu	Kalmalacheruvu	11KV	Huzurnagar	07.00	08.30	01.30	E/L	Jumper cut	-
3		K.M.Pally	Industrial	11KV	Devarakonda	08.30	11.20	02.50	E/L	11 KV Conductor Snapped	-
4		N.G Bandal	Veerareddy Pally	11KV	Bhongir	05.00	09.30	04.30	E/L	11KV Insulator Failed , 11KV Line Snapped Gopal Pur	-
5		Venkirial	Venkirial	11KV	Bhongir	05.00	09.30	04.30	E/L	Tree Branches On Line at Venkyral Village	-
6		Maryala	Mailaram	11KV	Bhongir	08.00	15.30	05.30	E/L	1 Poles Broken Near Maryala SS	-
7		B.Ramaram	Jalapur	11KV	Bhongir	03.00	08.00	05.00	E/L	8.0 Mts 2 Poles Broken ,11KV Line snapped near rangapur	-
8		Alair	Ikkurthy	11KV	Bhongir	05.00	08.30	03.30	E/L	11KV Line snapped at Ikkurthy Village	-
9		Voligonda	D.R Gudem	11KV	CTPI	00.00	05.30	05.30	E/L	Pind Binding , 11KV Insulator failed	-
1		Thogita	Kuchanpally	11KV	Medak	06.30	11.10	04.40		BREAK DOEN DICKS FAIL	-
2		Narsapur	Narayanpur	11KV	Medak	06.50	15.00	08.10		B/D Due to Conductor Snapped	-
3		Narsapur	Reddypally	11KV	Medak	06.50	15.00	08.10		B/D Due to Conductor Snapped	-
4		Narsapur	Avancha	11KV	Medak	06.50	15.00	08.10		B/D Due to Tree fallen on the line	-
5		Narsapur	Kagazmaddur	11KV	Medak	06.50	15.00	08.10		B/D Due to Tree fallen on the line	-
6		Narsapur	Chippalthurthy	11KV	Medak	09.00	11.00	02.00		B/D Due to Insulator Failed	-
7		Kowdipally	Devulapally	11KV	Medak	00.00	08.10	08.10		B/D Due to Tree fallen on the line	-
8		Kowdipally	Mohd Nagar	11KV	Medak	00.00	17.30	17.30		B/D Due to Poles Damaged	-
9		Kowdipally	Yelmakanna	11KV	Medak	00.00	10.40	10.40		B/D Due to 11KV Insulator failed	-

10	MDK	Kowdipally	Dharmasagar	11KV	Medak	00.00	09.15	09.15		B/D Due to Tree fallen on the line	-
11		Kothapally	Kothapally	11KV	Medak	21.30	11.30	14.00		B/D Due to Tree fallen on the line	-
12		Kothapally	Nagsanpally	11KV	Medak	21.30	01.30	04.00		B/D Due to 11KV Line Cutting	-
13		Kothapally	Annaram	11KV	Medak	21.30	09.00	11.30		B/D Due to Disc Failed	-
14		Kothapally	Kurthiwada	11KV	Medak	20.00	07.00	11.00		B/D Due to Tree fallen on the line	-
15		Kothapally	Yousufpet	11KV	Medak	21.00	08.00	11.00		B/D Due to 11KV Line Cutting	-
16		IKPET	ARUTLA	11KV	Sangareddy	07.43	15.30	07.47		B/D Due to WIRES CUT INSULTER FAIL	-
17		CHERIYAL	TURBOYN	11KV	Sangareddy	01.10	12.50	11.40		B/D Due to KV LINE FALL ON TREE & INSULATER FAIL	-
18		CHERIYAL	DULICHAND	11KV	Sangareddy	06.30	11.00	04.30		B/D Due to JUMPER CUT AT NEAR AMBOJI FARM HOUSE	-
19		CHERIYAL	INDRAKARAN	11KV	Sangareddy	05.10	12.00	06.50		B/D Due to 11KV CONDUCTER SNAPED AT AGL	-
20		SRD-T-I	FASALWADI	11KV	Sangareddy	01.00	09.40	08.40		B/D Due to RAIN PROBLEM	-
21		MALKAPUR	MALLEPALLY	11KV	Sangareddy	08.00	14.55	06.55		B/D Due to CONDUCTOR SNAPPED AT VEERABHADRA RICE MILL	-
22	EPIP-I	MSN	11KV	Sangareddy	01.10	13.21	12.11		B/D Due to CT PT HT CALBE KIT CABLE BRUST	-	
1	RR N	KPHB	Bhagynagar	11KV	Kukatpally	16.58	18.00	01.02	BD	11kv UG Cable Failure At My Home Bhagynagar	-
2		Uddamarry	Keshavpur	11KV	Medchal	06.50	10.45	03.55	BD	LT Pole damaged & replaced near SS	-
3		Medicity	Rajabollaram	11KV	Medchal	00.00	03.00	03.00	BD	11KV Pin Insulator failed at Rajabollaram Cheruvkatta	-
4		Athiwelly	SPIC	11KV	Medchal	00.00	04.15	04.15	BD	11KV Pole bend at Jayadarshini Thota	-
5		Ravalkole	IDA	11KV	Medchal	04.30	09.15	04.45	BD	Tree Branches fallen on the 11KV line at Lokesh Company	-
6		Ravalkole	Cheruvukatta	11KV	Medchal	00.30	04.01	03.31	BD	Tree Branches fallen on the 11KV line at Madhu Farm	-
7		Gowdavelly	Ayodya	11KV	Medchal	12.05	13.55	01.50	BD	Tree fallen on the 11KV Line at Ayodhya Chowrasta	-
1	RR E	NGRI	HMT	11KV	Habsiguda	13.15	15.10	01.55		AB cable fail at sudha water plant at HMT nagar	-
2		Singapur	Singapur2	11KV	Keesara	00.55	02.55	02.00		Tree fallen on 11kv line at Block 4	-
1	HYD N	Chinna Thokatta	Central Excise	11KV	Bowenpally	00.00	01.40	01.40	EL,OL	No Visible Fault	-
2		Nehru Nagar	J.B.S	11KV	Sec-Bad	10.52	11.58	01.06	EL	No Visible Fault	-
3	HYD C	Bathakamma Kunta	Shivam	11KV	Azamabad	14.19	16.03	01.44	EL,OL	Pin Insulator flash over at Vasavi Height Apartment	-

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Mahabubnagar	Ghanpur	33KV	Mahabubnagar	06.58	09.00	02.02	E/L&O/L	Due to Y Phase Jumper cut at line isloter towards line	Mahabubnagar	-
2		220KVSS Palkonda	Kodur	33KV	Mahabubnagar	07.50	10.50	03.00	E/L	Tree fallen on the line near Bandamidipally	220KVSS Palkonda	-
3		Maddur	Vepur	33KV	Mahabubnagar	07.25	14.15	06.50	E/L&O/L	Tree fallen on the line near Ranivatla	Maddur	-
4		Makthal	Narva	33KV	Mahabubnagar	05.40	11.05	05.25	E/L	for Pin biending Replacement at Kanapur (vi)	Makthal	-
5		Wanaparthi	Kothakota	33KV	Wanaparthi	07.35	09.38	02.03	E/L	for Jumpepr Replaced at 132KV SS	Wanaparthi	-
6		Alampur	Shanthinagar -1	33KV	Gadwal	07.38	09.40	02.02	O/L	Tree fallen on the line near Ramapuram stage	Alampur	-
1	MDK	Kandhi	ITW Signode	33KV	Sangareedy	02.20	15.00	12.40		B/D due to Tree fallen on line	Kandhi	-
2		Sadashivapet	Jogipet	33KV		07.00	10.55	03.55		B/D due to Lighting arrester failed	Sadashivapet	-
3		Gummadidala	Dundigal	33KV	Patancheru	06.45	09.50	03.05		B/D due to Tree fallen on line	Gummadidala	-
4		Pashamailaram	Suven life science	33KV	Sangareedy	02.55	09.25	06.30		B/D due to Tree fallen on line	Pashamailaram	-
5		Pashamailaram	GTN	33KV		02.55	15.50	12.55		B/D due to Tree fallen on line & Jumper cut	Pashamailaram	-
6		Pashamailaram	APL IV	33KV		02.50	13.50	11.00		B/D due to Tree fallen on line	Pashamailaram	-
7		Pashamailaram	EPIP P. Mailaram	33KV		05.50	15.10	09.20		B/D due to Tree fallen on line & Jumper cut	Pashamailaram	-
8		Singoor	Mudmanik	33KV	Jogipet	00.30	06.40	06.10		B/D due to Insulator failed	Singoor	-
9		Singoor	Jackwell	33KV		00.00	16.45	16.45		B/D due to Insulator failed	Singoor	-
10		Zaheerabad	Machnoor	33KV	Zaheerabad	00.00	12.00	12.00		B/D due to Tree fallen on line	Zaheerabad	-
11		Zaheerabad	Buchnelly	33KV		00.00	10.35	10.35		B/D due to Insulators failed	Zaheerabad	-
12		Zaheerabad	Hadnoor	33KV		10.20	17.20	07.00		B/D due to Insulators failed	Zaheerabad	-
13		Narsapur	Reddypally	33KV	Medak	02.20	10.10	07.50		B/D due to Disk failed	Narsapur	-
14		Narsapur	Kagazmaddur	33KV		01.20	14.10	12.50		B/D due to Tree fallen on line	Narsapur	-
15		Kowdipally	Salabathpur	33KV		00.00	09.10	09.10		BD due to 3no. Insulators failed	Kowdipally	-
16		Manoharabad	Manoharabad	33KV	Toopran	09.20	14.15	04.55		BD due to Jumper cut	Manoharabad	-