

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	RR(S)	53	234	2	2	2	2	2	2			
5	RR(N)	54	550	4	37	4	37	4	37			
6	RR(E)	168	403		15		15		15			
7	Hyd	194	1044		62		62		62			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>6</b>	<b>116</b>	<b>6</b>	<b>116</b>	<b>6</b>	<b>116</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	11	10	11	10	11	10			
2	NLG	144	988	24	113	24	113	24	113			
3	MDK	107	933	19	79	19	79	19	79			
4	RR(S)	58	396									
5	RR(N)	38	114									
6	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>54</b>	<b>202</b>	<b>54</b>	<b>202</b>	<b>54</b>	<b>202</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>60</b>	<b>318</b>	<b>60</b>	<b>318</b>	<b>60</b>	<b>318</b>	<b>0</b>	<b>0</b>	

## TSSPDCL - LMRC / Corporate office

Date: 08.04.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Koukuntla	Muchinthalla	11KV	Mahabubnagar	04.05	05.30	01.25		11KV Phase to Phase at Muchinthalla. (Vi)	-
2		Koukuntla	Gopanpally	11KV	Mahabubnagar	04.10	05.40	01.30		11KV Phase to Phase at Gopanpally (Vi)	
3		Dhanwada	Mandipally	11KV	Mahabubnagar	08.30	11.00	02.30		Tree fallen on 11KV conductor Near Manipoor thanda(Vi)	
4		Kanukurthy	Damargidda	11KV	Mahabubnagar	03.10	05.00	01.50		11KV Phase to Phase at Udmalgidda (Vi)	
5		Maganoor	Warkoor	11KV	Mahabubnagar	09.00	11.00	02.00		Tree fallen on 11KV conductor Near Warkoor(Vi)	
6		Kollur	Nawabpet	11KV	Jadcherla	10.00	13.00	03.00		11kv Jumper cut near Nawabpet	
7		Rajapur	Salguti	11KV	Jadcherla	03.00	12.00	09.00		11kv Insulator fail near Rajapur	
8		Balanagar	Amith Cotton mill	11KV	Jadcherla	07.00	14.00	07.00		Jumper cut near Indus Towar	
9		Udithyal	Macharam	11KV	Jadcherla	11.00	13.00	02.00		11Phase to Phase near Suraram	
10		Pedda Revally	Thirumalagiri	11KV	Jadcherla	06.10	08.10	02.00		11kv Insulator fail near Thirumalagiri	-
1		Madhanapur	Mall	11KV	Devarakonda	05.00	11.00	06.00	E/L	Mumentry Falt	-
2		Madhanapur	Madhanapur	11KV	Devarakonda	05.00	08.30	03.30	E/L	Tree branch fallen	
3		Chinthapally	Chinthapally	11KV	Devarakonda	05.00	09.00	04.00	E/L	Tree branch fallen	
4		Chinthapally	nasarlapally	11KV	Devarakonda	05.00	07.15	02.15	E/L	Tree branch fallen	
5		Teeded	K.Gowararam	11KV	Devarakonda	05.20	09.00	03.40	E/L	HT/LT Melt	
6		D.B.Pally	Neralapally	11KV	Devarakonda	07.00	17.00	10.00	E/L	HT/LT Melt And Tree branch fallen	
7		D.B.Pally	S.P.Thanda	11KV	Devarakonda	05.00	15.10	10.10	E/L	11Kv Insulator Failed	
8		D.B.Pally	Y.G.Pally	11KV	Devarakonda	07.15	15.00	07.45	E/L	Tree branch fallen	
9		Marriguda	Vattipally	11KV	Devarakonda	07.15	08.00	00.45	E/L	Tree branch fallen	
10		Nampally	Mandhapuram	11KV	Devarakonda	07.00	11.30	04.30	E/L	11Kv Line Cut	
11		Mellavai	Mellavai	11KV	Devarakonda	03.30	08.00	04.30	E/L	11Kv Line Cut	
12		Mellavai	Pasunoor	11KV	Devarakonda	03.30	08.00	04.30	E/L	11Kv Insulator Failed	
13		Mellavai	Revali	11KV	Devarakonda	03.30	11.00	07.30	E/L	11Kv Jumper Cut	
14		Mellavai	Fakeerapur	11KV	Devarakonda	03.30	12.30	09.00	E/L	11Kv Insulator Failed	
15		Mellavai	Devathpally	11KV	Devarakonda	03.30	15.00	11.30	E/L	11Kv Jumper Cut	
16		Mudigonda	Gottimukula	11KV	Devarakonda	06.00	08.00	02.00	E/L	11Kv Jumper Cut	
17		K.M.Pally	Palvai	11KV	Devarakonda	06.30	16.45	10.15	E/L	Tree branch fallen	
18		Ghanapuram	Polkampally	11KV	Devarakonda	05.30	14.30	09.00	E/L	11Kv Insulator Failed	
19		Ghanapuram	G.B.Pally	11KV	Devarakonda	05.30	17.40	12.10	E/L	11Kv Disck Failed Tree flan	
20		Azmapuram	Mallapur	11KV	Devarakonda	05.15	11.00	05.45	E/L	Tree branch fallen	
21		Dugayala	Thirumalagiri	11KV	Devarakonda	05.00	12.02	07.02	E/L	11Kv Insulator Failed	
22		Dugayala	Dugayala	11KV	Devarakonda	06.20	09.40	03.20	E/L	11Kv Insulator Failed	
23		Pitalagudam	Vattikodu	11KV	Devarakonda	01.30	10.00	08.30	E/L	Tree branch fallen	
24		Tripuraram	Duggepally	11KV	Miryalaguda	09.00	13.30	04.30	E/L	2No. Pole Dameges	
25		Tripuraram	Indl.	11KV	Miryalaguda	09.00	09.30	00.30	E/L	Tree branch Fallen on the line	
26		P.D.Pally	Gajalapuram	11KV	Miryalaguda	06.30	12.10	05.40	E/L	Tree branch Fallen on the line	
27		Utlapally	Kalwapally	11KV	Miryalaguda	06.30	10.00	03.30	E/L	Tree branch Fallen on the line	
28		Utlapally	Yadgarpally	11KV	Miryalaguda	06.00	09.00	03.00	E/L	Conductor snapped	
29		Avanthipuram	Indl-I	11KV	Miryalaguda	07.00	08.30	01.30	E/L	Tree branch Fallen on the line	
30		Kothagudem	Gudur	11KV	Miryalaguda	06.00	10.00	04.00	E/L	11KV Pin insulator Failed	
31		Kothagudem	Kothagudem	11KV	Miryalaguda	06.00	10.00	04.00	E/L	11KV Pin insulator Failed	
32		Thadakamalla	Settiapalem	11KV	Miryalaguda	08.00	09.30	01.30	E/L	Jumper cut at Utlapally thanda (Under rectification)	

33	Thadakamalla	Thadakamalla	11KV	Miryalaguda	08.10	09.30	01.20	E/L	11Kv jumper cut near village	
34	Nandi Pahad	lyalapuram	11KV	Miryalaguda	07.50	09.53	02.03	E/L	11KV jumper cut	
35	Miryalguda town-I	Seetharam puram	11KV	Miryalaguda	06.20	08.51	02.31	E/L	Heavy gale and wind	
36	Damarcherla	Wathya GP	11KV	Miryalaguda	06.30	08.30	02.00	E/L	Heavy gale and wind	
37	Damarcherla	Wadapally	11KV	Miryalaguda	06.45	08.30	01.45	E/L	Heavy gale and wind	
38	Thimmapuram	Padamati thanda	11KV	Miryalaguda	08.20	13.10	04.50	E/L	11Kv Conductor snaped	
39	A.D.Pally	A.D.PALLY	11KV	Miryalaguda	08.10	13.40	05.30	E/L	heavy gale and wind, Tree branches on 33KV line	
40	A.D.Pally	MULKACHERLA	11KV	Miryalaguda	08.10	13.40	05.30	E/L	heavy gale and wind, Tree branches on 33KV line and Conductor snapped	
41	B.b.Gudem	Thimmareddygudem -I	11KV	Miryalaguda	06.10	12.20	06.10	E/L	Tree branch Fallen on the line	
42	B.b.Gudem	Thimmareddygudem -II	11KV	Miryalaguda	06.10	10.30	04.20	E/L	Heavy gale and wind	
43	B.b.Gudem	Thopucherla	11KV	Miryalaguda	07.00	11.00	04.00	E/L	11KV jumper cut	
44	Settiapalem	A.R.Gudem	11KV	Miryalaguda	06.30	11.10	04.40	E/L	Tree branch Fallen on the line	
45	Settiapalem	Settiapalem-II	11KV	Miryalaguda	06.20	13.50	07.30	E/L	11KV Disc Failed	
46	Agamothkur	Agamothkur	11KV	Miryalaguda	06.20	13.50	07.30	E/L	11 KV disc insulator failed	
47	Agamothkur	Chirumarthy	11KV	Miryalaguda	06.25	17.18	10.53	E/L	Tree branch Fallen on the line	
48	Agamothkur	Bommakal	11KV	Miryalaguda	06.15	12.35	06.20	E/L	11KV Pin insulator Failed	
49	Molkapatnam	Molkapatnam	11KV	Miryalaguda	06.30	13.50	07.20	E/L	11KV jumper cut	
50	Laxmdevigudem	Raovulapenta	11KV	Miryalaguda	06.20	11.20	05.00	E/L	Tree branch Fallen on the line	
51	Katangur	Dugnelle	11KV	Nalgonda	05.45	16.30	10.45	E/L	11 KV Pin Insulator Failure	
52	Katangur	Bollepally	11KV	Nalgonda	05.45	11.00	05.15	E/L	11 KV Pin Insulator Failure	
53	Katangur	Mallaram	11KV	Nalgonda	05.45	15.00	09.15	E/L	11 KV Pin Insulator Failure	
54	Katangur	Kalimera	11KV	Nalgonda	05.45	15.40	09.55	E/L	11 KV Line Jumper Cut	
55	Thoragal	Thangellavarigudem	11KV	Nalgonda	08.45	12.30	03.45	E/L	11 KV Pin Insulator Failure	
56	Thoragal	Madaram	11KV	Nalgonda	08.45	16.20	07.35	E/L	11 KV Pin Insulator Failure	
57	Thoragal	Thoragal	11KV	Nalgonda	08.45	14.20	05.35	E/L	11 KV Pin Insulator Failure	
58	Thurkapally	M.Gouraram	11KV	Nalgonda	08.50	15.55	07.05	E/L	11 KV Pin Insulator Failure	
59	Gundrampally	Gundrampally	11KV	Nalgonda	07.10	10.50	03.40	E/L	11KV Line Insulator Failure	
60	Gundrampally	Apoor	11KV	Nalgonda	07.10	11.05	03.55	E/L	11KV Line Insulator Failure	
61	Gattupal	Teratpally	11KV	Nalgonda	06.10	11.00	04.50	E/L	LT Pin Insulator Failure	
62	Pamanagundla	Ismailpally	11KV	Nalgonda	05.35	16.05	10.30	E/L	LT Pin Insulator Failure	
63	Atipamula	Annaram	11KV	Nalgonda	06.00	15.55	09.55	E/L	LT Pin Insulator Failure	
64	Atipamula	Ramachandrapuram	11KV	Nalgonda	06.00	14.50	08.50	E/L	11KV Pole Damaged	
65	Cherukupally	Bondagu	11KV	Nalgonda	07.00	15.30	08.30	E/L	11 KV Line Disk Fail	
66	Kesharapally	Mahila Praganam	11KV	Nalgonda	06.10	16.30	10.20	E/L	11 KV Line Disk Fail	
67	Narsing Balta	Chennugudem	11KV	Nalgonda	05.45	15.15	09.30	E/L	11 KV Line Disk Fail	
68	Palem	Ogodu	11KV	Nalgonda	09.00	12.10	03.10	E/L	11 KV Line Disk Failure	
69	Palem	Palem	11KV	Nalgonda	09.10	12.00	02.50	E/L	11 KV Line Insulator Fail	
70	Palem	Bopparam	11KV	Nalgonda	09.05	13.00	03.55	E/L	11 KV Line Jumper Cut	
71	Mamidala	Aregudem	11KV	Nalgonda	10.15	14.10	03.55	E/L	11 KV Line Jumper Cut	
72	Mamidala	Godavarigudem	11KV	Nalgonda	10.15	13.15	03.00	E/L	11 KV Line Jumper Cut	
73	Eduloor	Parada	11KV	Nalgonda	09.40	15.55	06.15	E/L	11 KV Line Jumper Cut	
74	Eduloor	Kurmarthy	11KV	Nalgonda	09.50	14.35	04.45	E/L	11 KV Line Jumper Cut	
75	Narketpally	Yedavelly	11KV	Nalgonda	08.00	12.00	04.00	E/L	11 KV Line Jumper Cut	
76	Nemmani	Mellakuntta	11KV	Nalgonda	10.55	13.40	02.45	E/L	11 KV Line Jumper Cut	
77	Ch.Mamidi	Kompally	11KV	Nalgonda	05.10	14.10	09.00	E/L	5 Nos. 11 KV Damged	
78	Koppole K.	Beemaram	11KV	Nalgonda	07.00	14.00	07.00	E/L	HT / LT Melting	

NLG

79	Dirsincherla	Narasayagudem	11KV	Huzurnagar	09.00	11.30	02.30	EL	Due to 11Kv line cutted near Narasayagudem village
80	Palakaveedu	Janpahad Town	11KV	Huzurnagar	08.40	11.30	02.50	OL	Due to Tree branch Fall on 11Kv line near village
81	Alingapuram	Gundlapahad	11KV	Huzurnagar	08.00	11.00	03.00	EL	Due to 11Kv line cutted near Gundlapahad village
82	Keethavarigudem	Laxmipuram	11KV	Huzurnagar	09.00	10.25	01.25	EL	Due to Tree branch Fall on 11Kv line near village
83	Mattapally	Ramachandrapuram	11KV	Huzurnagar	09.30	10.30	01.00	EL	Due to Jumper cutted near Ramachandrapuram village
84	Gondriyala	Chimiryala	11KV	Huzurnagar	10.10	14.50	04.40	EL/OL	Due to 11Kv line cutted near Chimiryala village
85	Ananthagiri	Shantinagar	11KV	Huzurnagar	06.10	08.45	02.35	OL	Due to Jumper cutted near Shantinagar village
86	Chanupally	Tripuravaram	11KV	Huzurnagar	10.20	11.40	01.20	EL	Due to Jumper cutted near Tripuravaram village
87	Urulugonda	Thummagudem	11KV	Huzurnagar	07.30	11.00	03.30	EL	Due to 11Kv line cutted near Thummagudem village
88	Urulugonda	Sarvaram	11KV	Huzurnagar	07.30	11.00	03.30	EL	Due to Animal fall on 11Kv line near Sarvaram village
89	Urulugonda	Karkayalagudem	11KV	Huzurnagar	07.30	11.30	04.00	EL	Due to Tree branch Fall on 11Kv line near Karkayalagudem village
90	Urulugonda	N S Puram	11KV	Huzurnagar	07.30	12.00	04.30	EL	Due to 01 Pole Damage near N.S.Puram village
91	Repala	V R Puram	11KV	Huzurnagar	09.05	12.15	03.10	OL	Due to Tree branch Fall on 11Kv line near V R Puram village
92	Repala	Kalakova	11KV	Huzurnagar	09.10	11.00	01.50	OL	Due to 11Kv line cutted near Kalakova village
93	Repala	Repala	11KV	Huzurnagar	09.00	13.00	04.00	EL	Due to 11Kv Jumper cutted near Repala Village
94	Mamillagudem	Vibula puram	11KV	Huzurnagar	07.00	12.10	05.10	OL	Due to 25 Kva problem near Vibula puram village
95	Kasarabada	Express feeder	11KV	Suryapet	09.25	11.20	01.55	EL	Jumper cut
96	Nuthankal	Polumalla	11KV	Suryapet	09.40	12.50	03.10	EL	SS-10 Disk Failure
97	Nuthankal	Somla thanda	11KV	Suryapet	07.40	10.30	02.50	EL	Conductor Snapped
98	Penpahad	Dubba thanda	11KV	Suryapet	10.00	11.30	01.30	EL	Jumper cut
99	B.Chandupatla	Chivemla	11KV	Suryapet	10.10	12.40	02.30	EL	Pin insulator flashover
100	Bibigudem	Chivemla Agl	11KV	Suryapet	09.40	12.05	02.25	EL	Tree branch fallen on the line
101	Kudakuda	lylapuram	11KV	Suryapet	14.00	16.50	02.50	EL	Tree branch fallen on the line
102	Kandagatla	Patha Suryapeta	11KV	Suryapet	06.50	10.30	03.40	EL	Insulator flashover
103	Athmakur(S)	T.Penpahad	11KV	Suryapet	12.00	13.15	01.15	EL	Tree branch fallen on the line
104	Aipoor	Isthalapuram	11KV	Suryapet	09.20	12.00	02.40	EL	Insulator flashover
105	Jalapuram	M.K Thanda	11KV	Suryapet	11.30	13.50	02.20	EL	Insulator flashover
106	Reddygudem	Kukkadam	11KV	Suryapet	14.45	17.30	02.45	EL	Pin insulator flashover
107	GOLANKONDA	GOLANKONDA	11KV	BHONGIR	11.00	12.45	01.45	EL	EL 11 KV DISK FAILURE
108	NGBANDALA	VERAREDDY PALLY	11KV	BHONGIR	07.30	11.30	04.00	EL	11KV INSULATOR FAILURE
109	Y GUTTA	GUTTA TOWN	11KV	BHONGIR	06.00	09.00	03.00	EL	11 KV DISK FAILURE
110	Y GUTTA	PEL	11KV	BHONGIR	06.30	09.00	03.30	EL	11KV INSULATOR FAILURE
111	BIBINAGAR	SAKET INDIA	11KV	BHONGIR	06.00	11.00	05.00	EL	11 KV INSULETOR FALUR
112	RAGUNATHPALLY	RN POOR AGL	11KV	BHONGIR	06.00	10.00	04.00	EL	11 KV INSULETOR FALUR
113	ADDAGUDUR SS	CH RAMARAM	11KV	BHONGIR	01.00	05.00	04.00	EL	11 KV INSULETOR FALUR

1		Medak	Komtur	11KV	Medak	13.41	17.02	03.21		BREAK DOEN DICKS FAIL	-
2		M. Bhupathipur	M. Bhupathipur	11KV	Medak	11.50	13.14	01.24		B/D Due to Fallen on the Tree	
3		Shankarampet' R	Kamaram	11KV	Medak	03.05	05.00	01.55		B/D Due to Insulator Failed	
4		Shankarampet' R	Rudram	11KV	Medak	09.52	12.00	02.08		B/D Due to Insulator Failed	
5		Gavvalapally	Gavvalapally	11KV	Medak	02.00	09.00	07.00		B/D Due to Fallen on the Tree	
6		Gavvalapally	Madur	11KV	Medak	02.00	09.00	07.00		B/D Due to Fallen on the Tree	
7		Narsapur	Reddypally	11KV	Medak	03.30	07.00	03.30		B/D Due to Conductor Snapped	
8		Narsapur	Avancha	11KV	Medak	10.00	14.37	04.37		B/D Due to Fallen on the Tree	
9		Avancha	Avancha	11KV	Medak	05.50	12.00	06.10		B/D Due to Conductor Snapped	
10		Avancha	Ramchandrapuram	11KV	Medak	05.50	13.00	07.10		B/D Due to Conductor Snapped	
11		Lingapur	Lingapur	11KV	Medak	03.00	11.15	08.15		B/D Due to Conductor Snapped	
12		Lingapur	Thujalpur	11KV	Medak	03.00	11.15	08.15		B/D Due to 11KV Insulator Failed	
13		Kowdipally	Mohd Nagar	11KV	Medak	02.35	11.10	08.35		B/D Due to Conductor Snapped	
14		Kowdipally	Yelmakanna	11KV	Medak	02.40	12.40	10.00		B/D Due to 11KV Line Cut	
15		Kulcharam	Kulcharam	11KV	Medak	03.18	11.48	08.30		B/D Due to Fallen on the Tree	
16		Yenigandla	Y. Mandapur	11KV	Medak	03.00	09.30	06.30		B/D Due to 11KV Line Cut	
17		Rangampet	Rangampet	11KV	Medak	04.00	09.00	05.00		B/D Due to Fallen on the Tree	
18		Rangampet	Paithra	11KV	Medak	04.00	08.00	04.00		BRAK DOWN DUE TO 3 PHASE NOT STANDING	
19		Gadipeddapur	Gadipeddapur	11KV	Medak	01.45	11.45	10.00		B/D Due to Fallen on the Tree	
20		Gadipeddapur	Muslapur	11KV	Medak	02.15	07.00	04.45		B/D Due to Fallen on the Tree	
21		Tekmal	Hasan Mohammed pally	11KV	Medak	10.00	13.30	03.30		B/D Due to Fallen on the Tree	
22		Kadloor	Kadloor	11KV	Medak	02.00	09.55	07.55		B/D Due to Fallen on the Tree	
23	MDK	SANGAREDDY-I	TALLAPALLY	11KV	SANGAREDDY	06.30	10.05	03.35		B/D DUE TO 11KV JUMPER CUT	
24		ISMAILKANPET	ERDHANOR	11KV	SANGAREDDY	08.00	14.30	06.30		B/D DUE TO TREE FALLEN ON LINE	
25		KONDAPUR	GANGARAM	11KV	SANGAREDDY	07.00	11.00	04.00		B/D DUE TO 11KV CONDUSTOR SNAPPED	
26		KONDAPUR	MAREPALLY	11KV	SANGAREDDY	07.00	11.30	04.30		B/D DUE TO INSULATOR BURST	-
27		KONDAPUR	ALIABAD	11KV	SANGAREDDY	00.00	09.30	09.30		B/D DUE TO HEAVY RAIN FALL	-
28		MALKAPUR	MALLEPALLY	11KV	SANGAREDDY	02.00	11.30	09.30		B/D DUE TO INSULATOR BURST	-
29		CHERYAL	CHERYAL	11KV	SANGAREDDY	05.20	09.00	03.40		B/D DUE TO PH TO PH	-
30		CHERYAL	KANDI	11KV	SANGAREDDY	05.20	14.30	09.10		B/D DUE TO INSULATOR BURST	-
31		CHERYAL	INDRAKARAN	11KV	SANGAREDDY	05.20	09.40	04.20		B/D DUE TO JUMPER CUT	-
32		AROOR	AROOR	11KV	SANGAREDDY	01.50	04.00	02.10		B/D DUE TO RAIN FALL	-
33		AROOR	MADDIKUNTA	11KV	SANGAREDDY	02.00	07.00	05.00		B/D DUE TO RAIN FALL	-
34		SANGAREDDY-II	KALBGUR	11KV	SANGAREDDY	06.00	17.00	11.00		B/D DUE TO HEAVY RAIN FALL	-
35		SANGAREDDY-II	KOSLA	11KV	SANGAREDDY	06.30	09.00	02.30		B/D DUE TO PH TO PH	-
36		SANGAREDDY-II	MANJEERA	11KV	SANGAREDDY	05.30	09.30	04.00		B/D DUE TO (MANJEERA PUMP HOUSE INSIDE PROBLEM)	-
37		CHERYAL	TURBOVENT	11KV	SANGAREDDY	05.20	11.50	06.30		B/D DUE TO INSULATOR BURST	-
38		AROOR	EXPRESS	11KV	SANGAREDDY	02.30	07.00	04.30		B/D DUE TO RAIN FALL	-
39		EP-IP-II	EXPORT	11KV	SANGAREDDY	07.55	12.43	04.48		B/D DUE TO JUMPER CUT& DISC FAIL	-
40		ISNAPUR	PATODIA	11KV	SANGAREDDY	16.15	17.20	01.05		B/D DUE TO TREE FALLEN ON LINE	-
41		ISNAPUR	IDA-I	11KV	SANGAREDDY	06.05	09.15	03.10		B/D DUE TO (METALCRAFT INDUSTRIALCT PT FAIL )11KV AB SWITCH OPEN	-
42		ISNAPUR	IDA -ISNAPUR	11KV	SANGAREDDY	06.05	09.05	03.00		B/D DUE TO TREE FALLEN ON LINE	-
1		Thornal	Appanapally	11KV		01.00	16.18	15.18		Pin Insulator burst	
2		Raghavapur	Raorukula	11KV		00.00	10.15	10.15		Tree branches fallen on the line	
3		Raghavapur	Bachaipally	11KV		00.00	10.35	10.35		11KV Jumper Cut	

4		Raghavapur	Raghavapur Town Indl	11KV		00.00	07.20	07.20		Face to face	
5		Laxmidevipally	Ibrahimpur	11KV		05.50	06.45	00.55		EL/OL	
6		Tadapakally	Tadapakally	11KV		06-04-2018 21:00	07-04-2018 11:00	14.00		Tree branches fallen on the line	
7		Tadapakally	Venkatapur	11KV		06-04-2018 21:00	07-04-2018 12:30	15.30		DTR brass patties fallen down	
8		Irkode	Chinnagundavelly	11KV		00.00	07.30	07.30		11KV Jumper Cut	
9		Irkode	Indl	11KV		00.00	08.00	08.00		Insulator fail	
10		Chellapur	Chellapur	11KV		01.00	07.00	06.00		Tree branches fallen on the line	
11		Chellapur	Rajakkapet	11KV		01.00	07.00	06.00		Tree branches fallen on the line	
12		Chellapur	Godugumarri	11KV		01.00	07.00	06.00		Tree branches fallen on the line	
13		Pedda Cheekode	Pedda Cheekode	11KV		02.00	10.00	08.00		Insulator fail	
14		Jangapally	Jangapally	11KV		07.45	11.15	03.30		Tree branches fallen on the line	
15		Jangapally	Veerareddyally	11KV		07.45	11.15	03.30		Tree branches fallen on the line	
16		Mirdoddy	Mirdoddy	11KV		10.00	10.30	00.30		Insulator Burn	
17		Mirdoddy	Mirdoddy	11KV		11.36	12.20	00.44		Insulator Burn	
18	SDPT	Pedda Chepyala	Pedda Chepyala	11KV		00.00	09.00	09.00		Tree branches fallen on the line	
19		Pedda Chepyala	Alwala	11KV		00.20	10.40	10.20		Tree branches fallen on the line	
20		Kasulabad	Kasulabad	11KV		06-04-2018 21:30	07-04-2018 11:00	13.30		Tree branches fallen on the line	
21		Potharam(S)	Mirzapoor	11KV		12.50	14.50	02.00		B/D	
22			Potharam(S) Rural	11KV		13.40	14.35	00.55		B/D	
23		Katkoor	Mallaram	11KV		06.30	09.30	03.00		B/D	
24			Kannaram	11KV		06.30	12.00	05.30		Disc Change	
25		Gugilla	Thimmayapally	11KV		06.30	07.30	01.00		B/D	
26			Thimmayapally	11KV		10.45	11.15	00.30		B/D	
27			Gagillapoor	11KV		01.00	08.25	07.25		B/D	
28		KOHEDA	Thegalakuntapally	11KV		06.00	11.00	05.00		Jumper Cut	
29			Venkateshwarapally	11KV		06.00	09.00	03.00		B/D	
30			IVRCL	11KV		09.00	10.00	01.00		B/D	
31			Sriramulapalli	11KV		05.00	06.00	01.00		B/D	
32		Thotapally	Anthakpet	11KV		06.00	07.00	01.00		B/D	
33		Chityal	Thaduru	11KV		04.50	10.30	05.40		Disk Fail	
34		Cheryal	Cheryal-Town	11KV		04.55	11.30	06.35		Tree branches fallen on the line	
35		Dulmitta	Dulmitta Agl	11KV		07.00	09.30	02.30		Tree branches fallen on the line	
36			Arjunapatla	11KV		05.00	09.30	04.30		Tree branches fallen on the line	
37			Lingapoor	11KV		05.15	11.00	05.45		Insulator change	
1	RR S	Rajendranagar	Uppar pally(UPALLY)	11KV	RJNR	05.54	08.20	02.26	B/D	11kv Insulator Failed and Disc Failed at golden heights	
2		Rajendranagar	Pahadi	11KV	RJNR	05.52	07.40	01.48	B/D	Stick fallen on 11KV line at Diamondcity	
1		Mayurinagar	Ramnareshanagar	11KV	Kukatpally	04.05	07.30	03.25	EL&OL	11kv Pin Insultor Failure at Ram nareshanagar	-
2		Mayurinagar	Prashtha Nagar	11KV	Kukatpally	04.30	07.00	02.30	EL&OL	Due Heavy Rain	
3		Mayurinagar	K T R Colony	11KV	Kukatpally	04.30	06.15	01.45	EL&OL	Tree Branches Fallen On The 11kv line Pratap Reddy Colony	
4		Mayurinagar	G R R R	11KV	Kukatpally	04.00	06.15	02.15	EL&OL	Due Heavy Rain	

5		Nizampet	Nizampet	11KV	Kukatpally	04.20	06.10	01.50	EL&OL	11Kv Pin Insulator Failure at Kamma Sangam Bhavys	
6		Nizampet	Srinivasa colony	11KV	Kukatpally	04.20	05.26	01.06	EL&OL	Due Heavy Rain	
7		Vijayanagar	Allwyn colony	11KV	Kukatpally	04.10	05.40	01.30	OL	Due Heavy Rain	
8		Vijayanagar	Aruna Society	11KV	Kukatpally	04.15	06.00	01.45	OL	Due Heavy Rain	
9		Huda Truck Park	Sangeeta Nagar	11KV	Kukatpally	04.50	06.10	01.20	EL	Due Heavy Rain	
10		Prashtha Nagar	Mythri Nagar	11KV	Kukatpally	04.00	05.50	01.50	EL&OL	Due Heavy Rain	
11		KPHB	BhagyNagar	11KV	Kukatpally	04.10	05.30	01.20	EL&OL	Due Heavy Rain	
12		Vemana Colony	Bhavanipuram	11KV	Kukatpally	03.53	08.04	04.11	EL&OL	11kv Pin Insulator Failure At H D FC Bank Rajander reddy Colony	
13		J T PL	PJR Enclave	11KV	Kukatpally	04.15	07.50	03.35	EL&OL	11kv Pin Insulator Failure At Road -7 & 11Kv Disk Failure At Road - 10	
14		Madinaguda	H M T Maqtha	11KV	Kukatpally	04.00	07.00	03.00	EL&OL	11kv Pin Insulator Failure At Gopi Guest House	
15		Madinaguda	Reddy Labs	11KV	Kukatpally	04.00	08.00	04.00	EL&OL	Due Heavy Rain	
16		BachuPally	S M S	11KV	Kukatpally	06.00	07.05	01.05	EL&OL	Tree Branches Fallen On the 11kv Line At Bollram	
17		H M T Hills	police Station	11KV	Kukatpally	04.42	05.45	01.03	EL&OL	T/F brass patti cut At Pt No 64 jalavyu vihar	
18	RR N	J D M SS-II	Phase-4	11KV	Jeedimetla	04.13	09.12	04.59	BD	11KV Endy Kit Failure At Petrol Pump Phase-4 & 11kv Disk Failure At Phase -4	
19		J D M SS-IV	AAI Matha	11KV	Jeedimetla	04.15	06.20	02.05	EL&OL	Due Heavy Rain	
20		J D M SS-IV	Vasudha	11KV	Jeedimetla	04.17	06.20	02.03	EL&OL	Due Heavy Rain	
21		J D M SS-IV	Tagorea	11KV	Jeedimetla	07.30	10.05	02.35	EL&OL	Ct Bt Failed At Sai Sree company	
22		Suraram	Rajavi Gandhi nagar	11KV	Jeedimetla	04.25	07.00	02.35	EL&OL	Due Heavy Rain	
23		Suraram	Sree Ram Nagar	11KV	Jeedimetla	04.30	07.00	02.30	EL&OL	Due Heavy Rain	
24		Suraram	GCB-II	11KV	Jeedimetla	04.45	06.45	02.00	EL&OL	GCB-II post Of Insulator failure In Su station	
25		Suraram	Sai Baba Nagar	11KV	Jeedimetla	06.45	08.35	01.50	EL&OL	2 Nos 11kv Pin Insulator Failure & 11kv Jumpers Cut At Pandu Basti sai Baba Nagar	
26		J D M SS-I	Balaji	11KV	Jeedimetla	04.30	06.30	02.00	EL&OL	Due Heavy Rain	
27		Aleap	DR Colony Cable	11KV	Jeedimetla	08.30	09.30	01.00	EL&OL	Tree branches Fallen on the 11kv Line At Pt No 79 Pragathi nagar	
28		UMCC	HAL Colony	11KV	Medchal	04.30	06.00	01.30	BD	HG Fuse Pin Insulator failed at PP Nagar	
29		Kompally	NCL	11KV	Medchal	05.30	06.10	00.40	BD	Tree fallen on the 11KV Line at NCL	
30		Kompally	Petbasheerabad	11KV	Medchal	05.20	06.00	00.40	BD	Tree fallen on the 11KV Line at NCL South	
31		Subash Nagar	Ramaraj Nagar	11KV	Medchal	06.02	08.10	02.08	BD	CTPT failed and replaced at Mahendra Company	
32		Subash Nagar	Saibaba Nagar	11KV	Medchal	06.22	06.50	00.28	BD	11KV Jumper cut and replaced at MN Reddy Nagar	
33		Ravalkole	Ganapati	11KV	Medchal	04.40	06.55	02.15	BD	11KV Jumper opened at Snehafarm	
34		Bandamadaram	Railapur	11KV	Medchal	07.30	08.55	01.25	BD	11KV Disc failed at Reliance Towers	
35		Medchal	CMR	11KV	Medchal	06.35	08.05	01.30	BD	Tree fallen on the 11KV at IDA Bus Stop	
36		Kandlakoya	Kandlakoya	11KV	Medchal	05.00	07.45	02.45	BD	Tree fallen on the 11KV Line at Gubba Cold Storage	
37		Shameerpet	Thumkunta	11KV	Medchal	05.10	07.35	02.25	BD	11KV Pin Insulator Failed in SS	
1		Moula Ali	Moula Ali	11kv	SKP	06.56	07.48	00.52		Tree branches fallen on 11Kv line at ZTS (Foc Naresh/Kistafer)	-
2		Nacharam Indore	Gouthami Pipes	11kv	HBG	05.00	07.06	02.06		Tree fallen on 11kv line near Raja Rajeswari Industries	
3		IICT	CCMB	11kv	HBG	04.50	06.40	01.50		Line patrolling but no visible fault and AB Switch opened at HMT Nagar	
4		Chengicherla	My Villas	11kv	Keesar	05.45	06.25	00.40		11KV Pin insulaor failed at Pusulagudem	

5	RR E	CRPF	Chennapur	11kv	Keesar	08.35	09.50	01.15		Line patrolling but no visible fault		
6		Keesara	Vardhana	11kv	Keesar	06.05	09.25	03.20		Flexi fallen on 11KV line at Kundanapally		
7		Balaji Nagar	Sai Baba	11kv	Keesar	04.30	07.00	02.30		Line patrolling but no visible fault		
8		Aushapur	Aushapur	11kv	Keesar	07.00	11.50	04.50		11KV line cut at Jamlapet Road		
9		Aushapur	Sandupatlaguda	11kv	Keesar	07.40	08.40	01.00		Line patrolling but no visible fault		
10		Aushapur	Eduabad	11kv	Keesar	07.00	11.45	04.45		11KV Disc failed at Enkiryal Road		
11		Aushapur	Madharam	11kv	Keesar	10.50	13.30	02.40		Line patrolling but no visible fault		
12		Ghatkesar	Kondapur	11kv	Keesar	06.10	08.40	02.30		Line patrolling but no visible fault		
13		Ghatkesar	Dano	11kv	Keesar	08.50	10.45	01.55		Tree fallen on 11kv line at Yamanumpet		
14		Peerzathiguda	Chenna Reddy Thota	11kv	Keesar	10.00	11.00	01.00		Cover fallen on 11KV line at Chenna Reddy Thota Colony		
15		Pocharam	Pocharam	11kv	Keesar	05.05	08.45	03.40		11KV Disc failed at Pocharam		
1		HYD N	Osm. University	Osm. University	11kv	V	04.30	06.25	01.55	EL	No Visible Fault	-----
2			Monda Market	Dharma Kanta	11kv	V	04.45	06.00	01.15	EL,OL-Rph	Tree branches fallen on lines at B.S.N.L Office	-----
3			Osm. University	Mettuguda	11kv	V	04.45	08.00	03.15	EL	Tree branches fallen on lines at Mettuguda	-----
4			Seethaphalmandi	Seethaphalmandi	11kv	V	05.30	06.50	01.20	EL,OL	No Visible Fault	-----
5	Seethaphalmandi		Namal Gundu	11kv	V	06.05	07.45	01.40	EL	No Visible Fault	-----	
6	Lalaguda		Chenna Reddy	11kv	V	06.15	09.05	02.50	EL	Pin Insulator flash over at Aditya Super Market	-----	
7	Vasanthapuri		Siripuri	11kv	V	04.28	07.08	02.40	EL,OL	No Visible Fault	-----	
8	James Street		Chikoti Complex	11kv	V	04.50	07.06	02.16	EL,OL	Pin Insulator flash over at M.G Road	-----	
9	I.D.P.L		Shivalayam	11kv	VI	04.30	06.00	01.30	All Indication	No Visible Fault	-----	
10	I.D.P.L		Bala Nagar	11kv	VI	04.35	06.30	01.55	EL	No Visible Fault	-----	
11	Bowenpally		B.B.R Hospital	11kv	VI	05.15	07.30	02.15	EL	Flexi fallen on lines at B.B.R Hospital	-----	
12	Bhudevi Nagar		Rama Raju Nagar	11kv	VI	06.20	10.00	03.40	EL,OL	Breaker fault at SS	Arranged B/F on 11KV Kalinga Enclave feeder	
13	Road No.12		Road No.10	11kv	X	02.40	03.50	01.10	EL,OL-Yph	AB Cable fault at Gowri Shanker Colony	-----	
14	Maitrivanam		Saradhi Studio	11kv	X	04.50	06.05	01.15	EL	No Visible Fault	-----	
15	N.I.M.S		Andhra Jyothi	11kv	X	06.56	08.00	01.04	EL	Cable fault	Arranged B/F on 11KV Venkateshwara Temple feeder	
1		Miralam	Hasan Nagar	11kv	III	05.08	06.20	01.12	EL,OL	No Visible Fault	-----	
2		Ch' Baradari	Bilal Nagar	11kv	III	04.15	05.30	01.15	EL	No Visible Fault	-----	
3		Ch' Baradari	Ch' Baradari	11kv	III	04.17	05.30	01.13	EL	No Visible Fault	-----	
4		Ch' Baradari	Gazi Banda (Govt. Polytechnic)	11kv	III	04.20	05.45	01.25	EL	No Visible Fault	-----	
5		Aliyabad	Sather Bagh	11kv	III	04.23	06.06	01.43	EL	No Visible Fault	-----	
6		Panjesha	Bibi Bazar	11kv	III	04.27	05.35	01.08	EL,OL	No Visible Fault	-----	
7		Panjesha	Sultan Shahi	11kv	III	04.28	07.44	03.16	EL	AB Cable fault at Ashok Lodge	-----	
8		Falaknuma	Falaknuma OH	11kv	III	04.35	07.55	03.20	EL	11KV Cable touching to Pole at Rythu Bazar	-----	
9		Falaknuma	Chatrinaka	11kv	III	04.37	07.25	02.48	All Indication	Pin Insulator flash over at Nagi Reddy Nagar	-----	
10		Salarjung	Q.Q Stadium	11kv	III	04.38	07.25	02.47	EL	Twisted HT lines at High Court	-----	
11		Salarjung	Purani Haveli	11kv	III	04.40	08.00	03.20	EL,OL-Rph	DTR Cable fault at Metro Agarbathi	-----	
12		Attapur	HUDA Colony	11kv	III	04.21	05.55	01.34	EL,OL	DTR's fault at HUDA Colony	-----	
13		Panjesha	Metherwadi	11kv	III	05.36	07.21	01.45	All Indication	No Visible Fault	-----	
14		Hyderguda	Hyderguda	11kv	III	06.00	07.08	01.08	EL	No Visible Fault	-----	
15		C.R.P.F	Balapur	11kv	III	05.50	07.10	01.20	EL,OL	HT Jumper cut at Balapur Road	-----	



16	HYD S	Falaknuma	Ravindra Naik Nagar	11kv	III	05.32	07.05	01.33	EL,OL-Rph	Kite Sticks fallen on lines at R.N.Nagar	----
17		Moosarambagh	Moosarambagh	11kv	VIII	04.44	06.30	01.46	OL-R&Bph	Cable End Kit failed at Tanishq Jewellers	----
18		Kanchanbagh	Darga	11kv	VIII	04.23	07.00	02.37	EL,OL-Bph	No Visible Fault	----
19		Salarjung	Sadath Nagar	11kv	VIII	04.30	07.30	03.00	OL-R&Yph	No Visible Fault	----
20		Laxmi Nagar	Vinay Nagar	11kv	VIII	06.16	07.55	01.39	All Indication	No Visible Fault	----
21		Laxmi Nagar	Dhobighat	11kv	VIII	06.20	10.20	04.00	EL	Cable fault	Arranged B/F on 11KV Vinay Nagar feeder
22		Gunj	Palton	11kv	VIII	05.12	07.44	02.32	EL,OL-Bph	DTR Jumper cut at Anand Nagar Colony	----
23		Malakpet B-Block	Ekalavya Nagar	11kv	VIII	04.33	06.20	01.47	OL	No Visible Fault	----
24		Malakpet B-Block	C-Quarters	11kv	VIII	04.25	08.05	03.40	EL	No Visible Fault	----
25		Jiyaguda	Nalla Pochamma Temple	11kv	IX	04.50	06.50	02.00	EL	No Visible Fault	----
26	E.N.T	Jam Bagh	11kv	IX	04.10	06.40	02.30	EL,OL-R&Bph	No Visible Fault	----	
27	E.N.T	Gurudwara	11kv	IX	04.15	06.35	02.20	EL,OL-Bph	No Visible Fault	----	
28	E.N.T	E.N.T	11kv	IX	04.22	06.22	02.00	OL-R&Bph	No Visible Fault	----	
29	Jiyaguda	Nalla Pochamma Temple	11kv	IX	09.15	10.30	01.15	EL,OL	Bamboo Stick fallen on lines at Nalla Pochamma Temple	----	
1	HYD C	Lake View	Dilkusha	11KV	I	04.07	05.45	01.38	EL	No Visible Fault	----
2		Indira Park	Indian Bulls	11KV	I	04.40	11.00	06.20	EL,OL	Moisture formed in R.M.U at Indian Bulls	-
3		Lumbini Park	Avanathi Nagar	11KV	I	09.40	10.45	01.05	EL,OL	Pin Insulator flash over at Avanathi Nagar	-
4		Golnaka	Moulana Azad Nagar	11KV	II	04.44	06.57	02.13	EL,OL	Earth fault at Shyam Nagar	-
5		Chilkaiguda	Parsigutta	11KV	II	05.00	07.05	02.05	EL	Kite Sticks fallen on lines at Parsigutta	-
6		A.C.Guards	Nilofer Hospital	11KV	VII	04.40	07.25	02.45	EL	Net Cable fallen on lines at Nilofer Hospital	-
7		Langer House	Military Hospital	11KV	VII	05.22	07.45	02.23	EL	CT PT fault at Military Area	-
8		S.D.Hospital	Ahmed Nagar OH	11KV	VII	05.35	06.55	01.20	EL	Faulty loads 11KV Police Mess feeder	-
9		I.T.I Mallepally	Afzal Sagar	11KV	VII	04.08	07.02	02.54	EL	Cable fault at Bharth Petrol Pump	-
10		Golconda	O.U Colony	11KV	VII	03.55	06.40	02.45	EL,OL-Rph	AB Cable fault at Shivalayam Temple	-
11		Golconda	Darga OH	11KV	VII	04.08	07.25	03.17	EL,OL-Rph	Tree branches fallen on lines at Shaikpet	-
12		Mothi Mahal	Risala Bazar	11KV	VII	04.13	07.39	03.26	EL,OL-Rph	Faulty loads 11KV Golconda OH feeder	-
13		Toli Chowki	Hakeemsha	11KV	VII	04.10	06.30	02.20	All Indication	Tree branches fallen on lines at Shaikpet Nala	-
14		I.T.I Mallepally	Zaheera Masjid	11KV	VII	04.29	05.37	01.08	EL	No Visible Fault	-
15		I.T.I Mallepally	P.S Nagar	11KV	VII	05.37	07.27	01.50	EL,OL	No Visible Fault	-
16		A.S.R Raju Nagar	A.S.R Raju Nagar	11KV	VII	07.20	08.27	01.07	EL	Kite Sticks fallen on lines at A.S.R.R Nagar	-
17		Nampally	Red Hills	11KV	VII	04.58	06.15	01.17	EL	Tree branches fallen on lines at Red Hills	-
18		Langer House	Fathe Darwaza	11KV	VII	05.40	08.57	03.17	EL,OL	Tree branches fallen on lines at HUDA Park	-

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Kodangal	Kodangal	33kv	Mahabubnagar	06.05	08.10	02.05	E/L	2no Pin insulator damaged and Line Phase to Phase	Kodangal	-
2		220KV Palakonda	Kodur	33kv	Mahabubnagar	02.30	10.30	08.00	E/L	Tree Branches Removing on the Line & AB Switch opened at 4Pole Structure Supply Stood OK	Kodur	
3		Thirumalaipally	Willamkonda	33kv	Wanaparthy	02.15	05.30	03.15	OL	Insulator damaged	Willamkonda	
4		Kothur	Raghavendra	33kv	Jadcherla	03.45	10.45	07.00	OL	Reconnecting Jumper at Ishan Gas Company	Raghavendra	
5		Kothur	Thimmapur	33kv	Jadcherla	03.40	07.25	03.45	OL	Insulator damaged	Thimmapur	
6		Balanagar	G.R Cable	33kv	Jadcherla	04.10	09.30	05.20	E/L & O/L	for Near Hari Om Industry Line Conductor Cut & Replaced	G.R Cable	
7		Puttapad	Nancherla	33kv	Narayanapet	04.30	07.30	03.00	E/L	Insulator damaged	Nancherla	
8		Marikal	Gunmukla	33kv	Narayanapet	03.30	06.10	02.40	E/L	Pin Insulator damaged and Tree branch fallen on the line	Gunmukla	
9		Marikal	Koilkonda Water Grid	33kv	Narayanapet	04.18	10.00	05.42	E/L	for 2No Pin Insulator Replaced & Tree Cutting	Koilkonda Water Grid	
10		Nagarkurnool	Telkapally	33kv	Nagarkurnool	05.20	07.00	01.40	E/L	No Visible fault Supply Stude OK	Telkapally	
11		Achampet	Uppununthala	33kv	Nagarkurnool	03.50	08.00	04.10	E/L	for Insulator Replaced at Uppununthala	Uppununthala	
1	NLG	Madgulapally	Thipparthi	33kv	Nalgonda	06.40	09.00	02.20	E/L	33Kv Insulator Failed	Cheruvupally ,thipparthi(1:00)	
2		Aitipamula	Kethepally	33kv	Nalgonda	07.00	12.50	05.50	E/L	33Kv Pin Insulator Failed	Cherukupally,Kethepally	
3		Aitipamula	Arlagaddagudem	33kv	Nalgonda	06.50	01.00	06.10	E/L	33Kv Insulator Failed	Arlagaddagudem,Maroor	
4		Kanagal	Gurrampode	33kv	Nalgonda	07.50	08.30	00.40	E/L	33Kv Insulator Failed	Gurrampode,Pochampally	
5		220KV NKP	Eduloor	33kv	Nalgonda	09.25	10.00	00.35	E/L	33Kv Insulator Failed		Alternate supply given 132KV S.Gouraram
6		Kanagal	Pagidimarri	33kv	Nalgonda	07.50	10.30	02.40	E/L	Tree branch fallen on 33KV line	Pagidimarri	
7		Yerrabelly	Mushampally	33kv	Miryalaguda	04.00	11.00	07.00	E/L	Tree branch fallen on 33KV line	Shantinagar, Velugupally, Mushampally	Alternate supply Nalgonda
8		Yerrabelly	Pulimamidi	33kv	Miryalaguda	09.00	11.00	02.00	E/L	Tree branch fallen on 33KV line	Pulimamidi, Ramadugu	Alternate supply haliya
9		Yerrabelly	Mupparam	33kv	Miryalaguda	09.00	12.50	03.10	E/L	Tree branch fallen on 33KV line	Mupparam	
10		Yerrabelly	Kannekal	33kv	Miryalaguda	09.00	13.00	04.00	E/L	Tree branch fallen on 33KV line	Kannekal, Guntipally, Kamareddygudem	Alternate supply 33Kv Mupparam
11		Gudapur	Gudapur	33kv	Nalgonda	08.00	10.15	02.15	E/L	33KV Jumper Cut		
12		Sh Gowraram	Nakerakla	33kv	Nalgonda	06.30	09.10	02.40	E/L	Heavy gale and wind	CH. Annaram, Kadaparthi	
13		Sh Gowraram	Akkenapally	33kv	Nalgonda	06.30	09.10	02.40	E/L	Heavy gale and wind	Akkenapally, Bairuvunibanda	
14		Sh Gowraram	Akaram	33kv	Nalgonda	06.30	09.10	02.40	E/L	Heavy gale and wind	Akaram, Wangamarthy	
15		Wadapally	A.D.Pally	33kv	Miryalaguda	08.10	13.45	05.35	E/L	33Kv Line snapped	A.D.Pally, K.N.Konda	
16		Suryapet	S.V Collage	33kv	Suryapet	10.00	11.40	01.40	E/L	insulator flashover near 132KV Suryapet SS	S.V Collage	
17		Suryapet	Yerkaram	33kv	Suryapet	09.20	14.00	04.40	E/L	Lighting Arrestor failed	Yerkaram	
18		Thingathurty	Reddygudem	33kv	Suryapet	10.10	14.30	04.20	E/L	insulator flashover	Reddygudem	
19		Thingathurty	Annaram	33kv	Suryapet	10.10	12.50	02.40	E/L	Jumper Replacement near 33/11KV Annaram SS	Annaram	
20		BIBINAGAR	KONDAMADUGU	33kv	BHONGIR	06.32	07.45	01.15	E/L	B/D EL 33 KV INSULATOR FAILURE	KONDAMADUGU	
21		BIBINAGAR	VENKIRYALA	33kv	BHONGIR	07.30	09.05	01.35	E/L	B/D EL 132 KV SS CABLES FAILURE	VENKIRYALA	
22		KOLANPAK	RAGUNATHPUR	33kv	BHONGIR	08.20	12.05	03.45	E/L	B/D EL R FACE JUMPER CUT IN 132 KV KOLANPAK	RAGUNATHPUR	
23		HANMAPUR 220	THURKAPALLY	33kv	BHONGIR	05.15	08.50	03.35	E/L	B/D ELINSULATOR FAILURE	THURKAPALLY	
24	MOTKUR	AZIMPET	33kv	BHONGIR	07.45	12.35	05.00	E/L	B/D INSULATOR FAILURE	AZIMPET		
1	Kandhi	HFC I	33kv	Sangareddy	01.55	11.30	09.35			B/D due to Tree fallen on line	HFC I	-
2		HFC II	33kv		01.55	17.30	15.35			BD due to Insulator failed	HFC II	
3		Alkabeer	33kv		02.25	14.20	11.55			BD due to Insulator failed	Alkabeer	

4	MDK	Zaheerabad	Hadnoor	33kv	Zaheerabad	04.30	10.30	06.00		B/D due to Tree fallen on line loads tag on Mirzapur feeder	Hadnoor			
5			Mirzapur B	33kv			04.30	07.00	02.30		BD due to Insulator failed	Mirzapur B		
6			Old Allahna	33kv			04.30	07.40	03.10		BD due to Insulator failed	Old Allahna		
7			Sadashivapet	Koheer	33kv	Sangareddy	04.25	10.40	06.15		BD due to Line problem Loads tag on Jharasangem feeder	Koheer		
8				Manjeera	33kv			04.30	18.50	14.20		BD due to Insulator failed	Manjeera	
9			Pashamailaram	Nandigama	33kv			02.00	14.10	12.10		BD due to 2no Insulators failed	Nandigama	
10			Gummadidala	GPSS-1	33kv	Patancheru	01.30	10.15	08.45		BD due to Insulator flashover	GPSS-1		
11					33kv		13.05	15.40	02.35					
12			Chegunta	Narsingi	33kv	Toopran	01.20	09.05	07.45		BD due to Insulators failed & Tree fallen on line	Narsingi		
13			Kowdipally	Venkatraopet	33kv	Medak	02.45	09.30	06.45		BD due to Tree fallen on line	Venkatraopet		
14			Peddashankaramet	Burugupally	33kv			04.45	11.20	06.35		BD due to Tree fallen on line	Burugupally	
15			Narsapur	Arobindow	33kv			02.45	11.20	08.35		BD due to Insulators failed	Arobindow	
16			Medak	Shankarampet	33kv			13.02	17.00	03.58		BD due to Tree fallen on line	Shankarampet	
17			Manoharabad	Toopran	33kv	Toopran	04.15	10.15	06.00		BD due to Insulators failed	Toopran		
1		SDPT	Habsipur	Thimmapur	33kv	SDPT	09.05	10.55	01.00		Tree branches fall	Thimmapur		
2				Palamakula	Narmetta		33kv	06.30	08.00	01.30		Line Fault	Narmetta	
1		RR S	220kv Shamshabad	33kv Shapur	33kv	RJNR	04.15	07.20	03.05	B/D	Due to Heavy rain and wind and gale No Fault	33kv Shapur	-	
2			220kv Shivaram pally	33kv Gaganpahad	33kv	RJNR	06.19	12.25	06.06	B/D	Due to Heavy rain and wind and gale No Fault alternate supply arranged on 33steel mill Feeder	33kv Gaganpahad	-	
1	RR N	132KV Medchal	33KV Kompally	33kv	Medchal	08.20	11.23	03.03	BD	Lighting Arrester failed and replaced in SS	33KV Kompally	-		
2			132KV Medchal	33KV Steel mill	33kv	Medchal	09.50	20.45	10.55	BD	33KV Cable Endkit failed & replacement at Steel mill company & B Phase Jumper replacement in SS	33KV Steel mill	-	
3			132KV Medchal	33KV Athiwelly	33kv	Medchal	07.12	08.18	01.06	BD	Tree fallen on the 33KV Line at Athiwelly	33KV Athiwelly	-	
4			132KV Medchal	33KV Aliabad	33kv	Medchal	08.18	11.33	03.15	BD	No Fault	33KV Aliabad	-	