

**Status Report on Breakdowns (Urban / Rural)****Urban**

| S.No | Circle       | No.of Feeders Existing Urban |             | Breakdowns occurred during the day |          | Attended during the day |          | Time taken for restoring the supply |          |                                |          | Remarks (Pending) |
|------|--------------|------------------------------|-------------|------------------------------------|----------|-------------------------|----------|-------------------------------------|----------|--------------------------------|----------|-------------------|
|      |              | 33KV                         | 11KV        | 33KV                               | 11KV     | 33KV                    | 11KV     | Rectified (Within 24 Hours)         |          | Not Rectified (Above 24 Hours) |          |                   |
|      |              |                              |             |                                    |          |                         |          | 33KV                                | 11KV     | 33KV                           | 11KV     |                   |
| 1    | MBN          | 18                           | 107         |                                    |          |                         |          |                                     |          |                                |          |                   |
| 2    | NLG          | 22                           | 358         |                                    |          |                         |          |                                     |          |                                |          |                   |
| 3    | MDK          | 97                           | 359         |                                    |          |                         |          |                                     |          |                                |          |                   |
| 4    | RR(S)        | 53                           | 234         |                                    |          |                         |          |                                     |          |                                |          |                   |
| 5    | RR(N)        | 54                           | 550         |                                    | 3        |                         | 3        |                                     | 3        |                                |          |                   |
| 6    | RR(E)        | 168                          | 403         |                                    |          |                         |          |                                     |          |                                |          |                   |
| 7    | Hyd          | 194                          | 1044        |                                    |          |                         |          |                                     |          |                                |          |                   |
|      | <b>Total</b> | <b>606</b>                   | <b>3055</b> | <b>0</b>                           | <b>3</b> | <b>0</b>                | <b>3</b> | <b>0</b>                            | <b>3</b> | <b>0</b>                       | <b>0</b> |                   |

**Rural**

| S.No | Circle             | No.of Feeders Existing Rurals |             | Breakdowns occurred during the day |           | Attended during the day |           | Time taken for restoring the supply |           |                                |          | Remarks (Pending) |
|------|--------------------|-------------------------------|-------------|------------------------------------|-----------|-------------------------|-----------|-------------------------------------|-----------|--------------------------------|----------|-------------------|
|      |                    | 33KV                          | 11KV        | 33KV                               | 11KV      | 33KV                    | 11KV      | Rectified (Within 24 Hours)         |           | Not Rectified (Above 24 Hours) |          |                   |
|      |                    |                               |             |                                    |           |                         |           | 33KV                                | 11KV      | 33KV                           | 11KV     |                   |
| 1    | MBN                | 107                           | 849         | 4                                  | 3         | 4                       | 3         | 4                                   | 3         |                                |          |                   |
| 2    | NLG                | 144                           | 988         |                                    | 10        |                         | 10        |                                     | 10        |                                |          |                   |
| 3    | MDK                | 107                           | 933         | 1                                  | 53        | 1                       | 53        | 1                                   | 53        |                                |          |                   |
| 4    | RR(S)              | 58                            | 396         |                                    |           |                         |           |                                     |           |                                |          |                   |
| 5    | RR(N)              | 38                            | 114         |                                    |           |                         |           |                                     |           |                                |          |                   |
| 6    | RR(E)              | 22                            | 133         |                                    |           |                         |           |                                     |           |                                |          |                   |
|      | <b>Total</b>       | <b>476</b>                    | <b>3413</b> | <b>5</b>                           | <b>66</b> | <b>5</b>                | <b>66</b> | <b>5</b>                            | <b>66</b> | <b>0</b>                       | <b>0</b> |                   |
|      | <b>Grand Total</b> | <b>1082</b>                   | <b>6468</b> | <b>5</b>                           | <b>69</b> | <b>5</b>                | <b>69</b> | <b>5</b>                            | <b>69</b> | <b>0</b>                       | <b>0</b> |                   |

## TSSPDCL - LMRC / Corporate office

Date: 09.04.2018

| S.No | Circle | Name of 33/11KV SS | Name of 11 KV Feeder | Vol  | Name of the Division | From  | To    | Duration | Relay Indication | Cause of Breakdown   | Alternate Supply Arranged |
|------|--------|--------------------|----------------------|------|----------------------|-------|-------|----------|------------------|--|---------------------------|
| 1    | MBNR   | Damargidda         | Marlabeedu           | 11KV | Mahabubnagar         | 11.30 | 12.30 | 01.00    |                  | 11KV Tree fallen on conductor Near Damaragidda Thanda (Vi) | -                         |
| 2    |        | Tankara            | Gudimalkapur         | 11KV | Mahabubnagar         | 14.10 | 14.30 | 00.20    |                  | 11KV Phase to Phase Near Gudimalkapur (Vi)                 | -                         |
| 3    |        | Rajapur            | Rajapur              | 11KV | Jadcherla            | 15.05 | 16.20 | 01.15    |                  | Tree Fallen on 11 kv line near NT Ramarao thota at Rajapur | -                         |
| 1    | NLG    | Nuthankal          | Somla thanda         | 11KV | Suryapet             | 04.30 | 07.55 | 03.25    | E/L              | 11Kv Disk & Insulator flashover                            | -                         |
| 2    |        | Mukundapuram       | Dacharam             | 11KV | Huzurnagar           | 12.50 | 14.10 | 01.20    | E/L              | 11kv Disk Failure near Dhacharm (v)                        | -                         |
| 3    |        | Eduloor            | Kurumarthy           | 11KV | Nalgonda             | 13.30 | 15.00 | 01.30    | E/L              | 11Kv Jumper cut  |                           |
| 4    |        | Pamanagundla       | Pittampally          | 11KV | Nalgonda             | 06.30 | 09.35 | 03.05    | E/L              | 11Kv Pin Insulators failed                                 |                           |
| 5    |        | A.D.Pally          | Mudimanikya lift     | 11KV | Miryalguda           | 08.10 | 13.40 | 05.30    | E/L              | heavy gale and wind, Tree branches on 11KV line            |                           |
| 6    |        | Agamothkur         | Agamothkur           | 11KV | Miryalguda           | 06.20 | 12.35 | 06.15    | E/L              | 11Kv disc insulator failed                                 |                           |
| 7    |        | Agamothkur         | Bommakal             | 11KV | Miryalguda           | 06.15 | 13.30 | 07.15    | E/L              | 11KV Pin insulator Failed                                  |                           |
| 8    |        | Dindi              | Dindi rural          | 11KV | Devarakonda          | 08.01 | 08.20 | 00.19    | E/L              | 11Kv Jumper cut  | -                         |
| 9    |        | Dindi              | Thirumalagiri        | 11KV | Devarakonda          | 09.53 | 16.55 | 07.02    | E/L              | 11Kv HV line cut   | -                         |
| 10   |        | Ghanapur           | G.B.Pally            | 11KV | Devarakonda          | 09.20 | 18.00 | 08.40    | E/L              | 4No. 11Kv insulator fail                                   | -                         |
| 1    | MDK    | Isnapur            | patodia              | 11KV | Sangareddy           | 17.30 | 17.55 | 00.25    |                  | B/D Due to Jumper Cut 11 KV line melting at Chitkul Vg     | -                         |
| 2    |        | IK Pet             | Erdhanoor            | 11KV | Sangareddy           | 03.00 | 12.00 | 09.00    |                  | B/D Due to conductor snapped near Rudram                   | -                         |
| 1    |        | Kondamrajpally     | Gatlamalyala         | 11KV | SDPT                 | 05.20 | 09.00 | 03.40    |                  | 11 KV Wire cut   |                           |
| 2    |        | Kondamrajpally     | Kondamrajpally       | 11KV | SDPT                 | 05.20 | 12.00 | 06.40    |                  | Insulater fail   |                           |
| 3    |        | Thornal            | Appanapallay         | 11KV | SDPT                 | 01.00 | 15.22 | 14.22    |                  | Insulater fail, 11kv/LT                                    |                           |
| 4    |        | Thornal            | Thornal              | 11KV | SDPT                 | 05.15 | 08.00 | 02.45    |                  | Insulater fail   |                           |
| 5    |        | Thornal            | Thornal              | 11KV | SDPT                 | 10.50 | 12.30 | 01.40    |                  | Insulater fail   |                           |
| 6    |        | Chinthamadka       | Chinthamadka         | 11KV | SDPT                 | 04.30 | 09.45 | 05.15    |                  | Insulater fail   |                           |
| 7    |        | Kammarlapally      | Kothapally           | 11KV | SDPT                 | 09.30 | 14.18 | 04.48    |                  | Tree branches fall on the line                             |                           |
| 8    |        | Kammarlapally      | Alipur               | 11KV | SDPT                 | 08.30 | 10.00 | 01.30    |                  | Tree branches fall on the line                             |                           |
| 9    |        | Gurralagondi       | Gurralagondi         | 11KV | SDPT                 | 04.30 | 11.08 | 06.38    |                  | Insulater fail   |                           |
| 10   |        | Gurralagondi       | Malyala              | 11KV | SDPT                 | 04.30 | 07.40 | 03.10    |                  | Insulater fail   |                           |
| 11   |        | Gonepally          | Mandapally           | 11KV | SDPT                 | 09.10 | 09.50 | 00.40    |                  | Disk fail  |                           |
| 12   |        | Chandlapur         | Gangapur             | 11KV | SDPT                 | 10.00 | 10.30 | 00.30    |                  | Tree branches fall on the line                             |                           |
| 13   |        | Dubbak             | Lachapet             | 11KV | SDPT                 | 10.40 | 16.05 | 05.25    |                  | Tree branches fall on the line                             |                           |
| 14   |        | Peddacheekode      | Peddacheekode        | 11KV | SDPT                 | 04.00 | 09.30 | 05.30    |                  | Insulater fail   |                           |
| 15   |        | Gambeerpur         | Potharam             | 11KV | SDPT                 | 08.00 | 09.00 | 01.00    |                  | 11 KV Wire cut   |                           |
| 16   |        | Raghothampally     | Gosanpally           | 11KV | SDPT                 | 10.45 | 12.42 | 01.57    |                  | Disk fail  |                           |
| 17   |        | Pothareddypet      | Rameshwarampally     | 11KV | SDPT                 | 03.50 | 09.05 | 05.15    |                  | 11 KV Wire cut   |                           |
| 18   |        | Pothareddypet      | Pothareddypet        | 11KV | SDPT                 | 05.10 | 09.00 | 03.50    |                  | 11 KV Wire cut   |                           |
| 19   |        | Dharmajipet        | Dharmajipet          | 11KV | SDPT                 | 11.00 | 15.00 | 04.00    |                  | Tree branches fall on the line                             |                           |
| 20   |        | Dharmajipet        | Dharmajipet          | 11KV | SDPT                 | 19.00 | 21.00 | 02.00    |                  | Tree branches fall on the line                             |                           |
| 21   |        | Jangapally         | Veerareddypally      | 11KV | SDPT                 | 07.25 | 10.15 | 02.50    |                  | Disk fail  |                           |

|    |      |                         |                                     |               |      |            |       |       |       |                            |   |   |
|----|------|-------------------------|-------------------------------------|---------------|------|------------|-------|-------|-------|----------------------------|---|---|
| 22 | SDPT | Jangapally              | Veerareddypally                     | 11KV          | SDPT | 12.40      | 16.00 | 03.20 |       | Disk fail                  |   |   |
| 23 |      | Peddachepyala           | Peddachepyala                       | 11KV          | SDPT | 12.00      | 13.00 | 01.00 |       | Jumper cut near kunta      |   |   |
| 24 |      | Baddipadga              | Baddipadga                          | 11KV          | SDPT | 07.00      | 10.00 | 03.00 |       | Disk fail                  |   |   |
| 25 |      | HUSNABAD                | POTLAPALLY                          | 11KV          | SDPT | 09.50      | 10.50 | 01.00 |       | B/D                        |   |   |
| 26 |      | POTHARAM                | POTHARAM RURAL                      | 11KV          | SDPT | 08.00      | 09.00 | 01.00 |       | B/D                        |   |   |
| 27 |      |                         | MIRZAPOOR                           | 11KV          | SDPT | 16.00      | 17.00 | 01.00 |       | B/D                        |   |   |
| 28 |      | KATKUR                  | RAMAVARAM & MALLARAM                | 11KV          | SDPT | 06.30      | 09.30 | 03.00 |       | B/D                        |   |   |
| 29 |      |                         | KANNARAM                            | 11KV          | SDPT | 06.30      | 12.00 | 05.30 |       | B/D                        |   |   |
| 30 |      | THOTAPALLY              | MALLAMPALLY                         | 11KV          | SDPT | 07.00      | 10.00 | 03.00 |       | B/D                        |   |   |
| 31 |      | GANDIPALLY              | RAMAVARAM                           | 11KV          | SDPT | 09.10      | 11.35 | 02.25 |       | B/D                        |   |   |
| 32 |      | DHARMARAM               | Dharmaram(R.)                       | 11KV          | SDPT | 08.35      | 10.35 | 02.00 |       | B/D                        |   |   |
| 33 |      | 33/11KV SS GUGGILLA     | GAGILLAPUR                          | 11KV          | SDPT | 05.40      | 08.00 | 02.20 |       | B/D                        |   |   |
| 34 |      | KOHEDA                  | VENKATESHWARAPALLY                  | 11KV          | SDPT | 06.00      | 09.00 | 03.00 |       | B/D                        |   |   |
| 35 |      |                         | THEEGALAKUNTAPALLY                  | 11KV          | SDPT | 06.00      | 11.00 | 05.00 |       | B/D                        |   |   |
| 36 |      |                         | CANNAL                              | 11KV          | SDPT | 09.00      | 10.00 | 01.00 |       | B/D                        |   |   |
| 37 |      |                         | SRIRAMULAPALLY                      | 11KV          | SDPT | 05.00      | 06.00 | 01.00 |       | B/D                        |   |   |
| 38 |      | 33/11KV SS Chityal      | Chityal Agl                         | 11KV          | SDPT | 04.55      | 11.30 | 06.35 |       | TREE FALLEN                |   |   |
| 39 |      |                         | Dom mata                            | 11KV          | SDPT | 05.30      | 12.40 | 07.10 |       | DTR FAILURE                |   |   |
| 40 |      |                         | Thadoor                             | 11KV          | SDPT | 04.50      | 10.30 | 05.40 |       | DISC FAILURE               |   |   |
| 41 |      | 33/11KV SS Dhoolmitta   | Lingapur                            | 11KV          | SDPT | 05.15      | 11.00 | 05.45 |       | INSULTER CHANGE            |   |   |
| 42 |      |                         | Arjunpatla                          | 11KV          | SDPT | 05.00      | 09.30 | 04.30 |       | TREE FALLEN                |   |   |
| 43 |      |                         | Dhoolimitta Agl                     | 11KV          | SDPT | 07.00      | 09.30 | 02.30 |       | TREE FALLEN                |   |   |
| 44 |      | 33/11KV SS Komuravelly  | Kadavergu                           | 11KV          | SDPT | 05.20      | 08.20 | 03.00 |       | INSULATOR FAILED           |   |   |
| 45 |      |                         | Kistampet                           | 11KV          | SDPT | 05.25      | 07.05 | 01.30 |       | DUE TO HEAVY GAIL & WIND   |   |   |
| 46 |      |                         | Inapur + Posanpally + Inapur 24 hrs | 11KV          | SDPT | 05.00      | 11.00 | 06.00 |       | DUE TO HEAVY GAIL & WIND   | -   |   |
| 47 |      | 33/11KV SS Nagapuri     | Nagapuri                            | 11KV          | SDPT | 06.00      | 10.40 | 04.40 |       | DISC FAILED                | -   |   |
| 48 |      |                         | Pothireddypalli                     | 11KV          | SDPT | 07.00      | 12.00 | 05.00 |       | DUE TO HEAVY GAIL & WIND   | -   |   |
| 49 |      | 33/11KV SS Bekkal       | Bairanpally                         | 11KV          | SDPT | 08.50      | 11.20 | 02.30 |       | LINE TO LINE               | -   |   |
| 50 |      |                         | Kutigal                             | 11KV          | SDPT | 07.00      | 09.00 | 02.00 |       | JUMPER CUT                 | -   |   |
| 51 |      | 33/11KV SS Cherial Town | Cherial-Town                        | 11KV          | SDPT | 10.05      | 14.45 | 05.40 |       | conductor snap at 2 places | -   |   |
| 1  |      | RR N                    | Jeedimetla Ss-II                    | Uttam Biscuit | 11KV | Jeedimetla | 06.00 | 07.45 | 01.45 | EL & OL                    | 11kv Disk Failure& 11KV Jumper cut At Dp colony   | - |
| 2  |      |                         | Subash Nagar                        | Ramaraj Nagar | 11KV | Medchal    | 04.55 | 06.10 | 01.15 | BD                         | 11KV Jumper cut & replacement at Mahendra Shoroom | - |
| 3  |      |                         | Subash Nagar                        | Suchitra      | 11KV | Medchal    | 04.55 | 05.55 | 01.00 | BD                         | 11KV Line cut at Bommarilu Restaurent & Yes mart  | - |

TSSPDCL - LMRC / Corporate office

Date: 09.04.2018

| S.No | Circle | Name of 132/33KV SS | Name of 33 KV Feeder | Vol  | Name of the Division | From  | To    | Duration | Relay Indication | Cause of Breakdown                             | Sub Stations Effected | Alternate Supply Arranged |
|------|--------|---------------------|----------------------|------|----------------------|-------|-------|----------|------------------|--|-----------------------|---------------------------|
| 1    | MBNR   | Mahabubnagar        | Machanpally          | 33KV | Mahabubnagar         | 19.55 | 22.40 | 02.45    | O/L              | Tree Branches Fallen on the Line at Appaipally | Machanpally           | -                         |
| 2    |        | Kothur              | Thimmapur            | 33KV | Jadcherla            | 19.20 | 20.58 | 01.38    | E/L              | Insulator Damaged Near Penjerla Road           | Thimmapur             | -                         |
| 3    |        | Sri Rangapur        | Mogiligidda          | 33KV | Jadcherla            | 17.45 | 18.45 | 01.00    | O/L              | Due to Heavy Wind                              | Mogiligidda           | -                         |
| 4    |        | Puttapad            | Salkarpet            | 33KV | Narayanpet           | 18.22 | 19.50 | 01.28    |                  | Due to Heavy Wind                              | Salkarpet             | -                         |
| 1    | MDK    | Jogipet             | Laxmi sagar          | 33KV | Sangareddy           | 14.30 | 18.30 | 04.00    |                  | B/D Due to Insulator failure                   | Laxmi sagar           | -                         |