

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	RR(S)	53	234									
5	RR(N)	54	550		1		1		1			
6	RR(E)	168	403		2		2		2			
7	Hyd	194	1044									
	Total	606	3055	0	3	0	3	0	3	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988	1	7	1	7	1	7			
3	MDK	107	933		3		3		3			
4	RR(S)	58	396									
5	RR(N)	38	114									
6	RR(E)	22	133									
	Total	476	3413	1	10	1	10	1	10	0	0	
	Grand Total	1082	6468	1	13	1	13	1	13	0	0	

TSSPDCL - LMRC / Corporate office

Date: 13.04.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Ravulapally	Thurpugudem	11KV	Suryapet	08.40	11.30	02.50	EL	Pin Insulator flashover	-
2		Gaddipaly	Medaram	11KV	Huzurnagar	02.00	06.00	04.00	EL	Due to 11Kv line cutted near Medaram village	-
3		Siripuram	Vallapuram	11KV	Huzurnagar	06.00	08.25	02.25	EL	Due to 11 Insulator failure near Vallapuram village	-
4		Huzurnagar	Lakkavaram	11KV	Huzurnagar	04.22	07.00	02.38	OL	Due to jumper cutted near Lakkavaram village	-
5		Cherkupally	Bandevagu	11KV	Nalgonda	13.00	15.05	02.05	E/L	11 KV line cut at nearby village	-
6		Urumadla	Elikatte	11KV	Nalgonda	10.10	14.20	04.10	E/L	11 KV Insulators failed	-
7		Chinthapally	Power gird	11KV	Devarakonda	13.35	15.19	01.44	E/L	Jumper Cut	-
1	MDK	Narsingi	Narsingi	11KV	Medak	14.50	15.50	01.00		B/D Due to Jumper cut at arkela village	-
2		Minpur	Yousufpet	11KV	Medak	09.05	11.40	02.35		B/D Due to Jumper cut	-
3		SRD-T-II	Khosla	11KV	Sangareddy	16.25	18.15	01.50		B/D Due to Conductor Snapped	-
1	RR N	Aleap	Doctor's colony	11KV	Jeedimetla	16.35	17.40	01.05	EL OL	Gardenmizaru fan on the 11KV line near plot no 1753 at pragathi nagar	-
1	RR E	FRUITMARKET	SHIVALAYAM	11KV	JAROOKINAGAR	15.28	16.50	01.22	EL/OL	11KV LINE AB SWITCH JUMPER CUT AT COWATHAM MORAL SCHOOL VIKAS NAGAR	-
2		BAGASINGNAGAR	POST OFFICE	11KV	JAROOKINAGAR	09.04	10.05	00.54	EL/OL	COUPLER NET BRANCHES FALL ON 11KV LINE AT VENKATESHWER COLONY ROAD NO 6	-

TSSPDCL - LMRC / Corporate office

Date: 13.04.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	NLG	K.M.Pally	Angadipeta	33KV	Devarakonda	12.20	15.10	02.50		Jumper Cut	Angadipeta	-