

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	RR(S)	53	234									
5	RR(N)	54	550		1		1		1			
6	RR(E)	168	403									
7	Hyd	194	1044		2		2		2			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>0</b>	<b>3</b>	<b>0</b>	<b>3</b>	<b>0</b>	<b>3</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988	1	6	1	6	1	6			
3	MDK	107	933									
4	RR(S)	58	396									
5	RR(N)	38	114									
6	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>1</b>	<b>6</b>	<b>1</b>	<b>6</b>	<b>1</b>	<b>6</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>1</b>	<b>9</b>	<b>1</b>	<b>9</b>	<b>1</b>	<b>9</b>	<b>0</b>	<b>0</b>	

TSSPDCL - LMRC / Corporate office

Date: 14.04.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Durajpally	Durajpally	11KV	Suryapet	11.40	14.30	02.50	E/L	11Kv Conductor snapped	-
2		Mukundapuram	Kalluru	11KV	Huzurnagar	09.00	13.20	05.20	E/L	11KV Line snapped at Kalluru (v)	-
3		Keethavarigudem	Laxmipuram	11KV	Huzurnagar	11.25	13.15	01.50	E/L	11kv Line snapped at Laxmipuram (v)	-
4		Baironibanda	Kothapally	11KV	Nalgonda	11.15	15.20	04.05	E/L	11Kv Insulaor Failed	-
5		Nemmani	Merlakunta	11KV	Nalgonda	09.00	11.00	02.00	E/L	11Kv Jumper Cut	-
6		Mamidala	Areguem	11KV	Nalgonda	04.00	09.20	05.20	E/L	11Kv Jumper Cut	-
1	RR N	JDM SS - 1	JETL	11KV	Jeedimetla	11.20	13.20	02.00	EL OL	11KV AB Cable Failure near Bread Company at JETL Line.	-
1	HYD N	Patigadda	Ranigunj	11KV	Sec-Bad	03.04	04.13	01.09	EL	Road Crossing Cable damaged at Railway Bridge	Arranged B/F on 11KV D.V Colony & 11KV Botany School feeders
1	HYD C	Public Garden	Telugu University	11KV	Saifabad	14.15	15.40	01.25	EL,OL-Yph	Cable fault Opp SS	Arranged B/F on 11KV Nampally Railway Station fdr

TSSPDCL - LMRC / Corporate office

Date: 14.04.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	NLG	Wadapally	Damarcherla	33KV	Miryalguda	00.15	07.20	07.05	E/L	33KV insulator flash over		-