

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	RR(S)	53	234									
5	RR(N)	54	550		1		1		1			
6	RR(E)	168	403		3		3		3			
7	Hyd	194	1044									
	Total	606	3055	0	4	0	4	0	4	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	2	1	2	1	2	1			
2	NLG	144	988		5		5		5			
3	MDK	107	933	3	4	3	4	3	4			
4	RR(S)	58	396									
5	RR(N)	38	114									
6	RR(E)	22	133									
	Total	476	3413	5	10	5	10	5	10	0	0	
	Grand Total	1082	6468	5	14	5	14	5	14	0	0	

TSSPDCL - LMRC / Corporate office

Date: 15.04.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Udithyal	Udithyal	11KV	Jadcherla	11.02	13.10	02.08		Ht/Lt Near Veerannapally Village DTR Side	-
1	NLG	Gumpula Thirumalagiri	Gunjaloor	11KV	Suryapeta	10.00	12.10	02.10	E/L	Insulator failure	-
2		Koppole(K)	Koppole(K)	11KV	Nalgonda	10.56	15.30	04.34	E/L	11 KV Insulaor Failed	-
3		Thurkapally	M.Gowrararam	11KV	Nalgonda	09.20	13.10	03.50	E/L	11 KV Jumper Cut	-
4		Madugulapally	Kukkadam	11KV	Nalgonda	09.50	12.50	03.00	E/L	11 KV AB Switch Problem	-
5		Datherpally	Janagampally	11KV	Bhongiri	07.40	09.40	02.00	EL	11Kv Jumper Snapped , 11Kv Insultor failed at Rallajangam wagu	-
1	MDK	Nizampur	Venkatapur	11KV	Sangareddy	14.30	18.30	04.00		B/D Due to Jumper cut at Venkatapur (V)	-
2		Athmakur	Athmakur	11KV	Sangareddy	15.50	17.33	01.43		B/D Due to Insulater Failed	
3		Athmakur	Yellaram	11KV	Sangareddy	16.00	17.40	01.40		B/D Due to Jumper Broken	
4		Munipally	Mallikajunpally	11KV	Sangareddy	16.00	20.00	04.00		B/D due ot Jumper cut	
1	RR N	Shameerpet	Shameerpet	11KV	Medchal	07.50	12.20	04.30	BD	11KV Disc failed at Shanthinikesthan School,Bommarajpet	-
1	RR E	Aushapur	Sandupatlaguda	11KV	Keesar	07.30	09.00	01.30		11KV Pin Insulator failed at Edulabad	-
2		Aushapur	Madharam	11KV	Keesar	07.30	10.00	02.30		11KV Jumper cut at Madharam Village	-
3		Aushapur	Aushapur	11KV	Keesar	09.00	16.00	07.00		11KV Aushapur Feeder breaker relay fault at SS Yard	-

TSSPDCL - LMRC / Corporate office

Date: 15.04.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Makthal	Maganoor	33KV	Mahabubnagar	10.00	13.30	03.30	EL	Pin Binding Failed at Wadvat(V)	Maganoor	-
2		Kalwakurthy	Vangoor	33KV	Nagarkurnool	02.20	04.05	01.45		CT Blost at 132KV Kalwakuthy SS.	Vangoor	-
1	MDK	Pashamailaram	Manjeera	33KV	Sangareddy	16.30	17.30	01.00		B/D due to Tree fallen on the line at Kalbgoor Village.	Manjeera	-
2		Narayankhed	Poosalpad	33KV	Jgoiept	14.30	16.30	02.00		B/D due to Pin Insulator fail.	Poosalpad	-
3	SDPT	Siddipet	Palamakula	33KV	Narmetta	10.20	11.20	01.00		Line Snaped	Palamakula	-