

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	RR(S)	53	234									
5	RR(N)	54	550		1		1		1			
6	RR(E)	168	403		1		1		1			
7	Hyd	194	1044		2		2		2			
	Total	606	3055	0	4	0	4	0	4	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	2	1	2	1	2	1			
2	NLG	144	988		3		3		3			
3	MDK	107	933									
4	RR(S)	58	396									
5	RR(N)	38	114									
6	RR(E)	22	133									
	Total	476	3413	2	4	2	4	2	4	0	0	
	Grand Total	1082	6468	2	8	2	8	2	8	0	0	

TSSPDCL - LMRC / Corporate office

Date: 16.04.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	K.C.Road	Chindarpally	11KV	Mahabubnagar	12.08	16.05	03.57		11KV Conductor cut at Venkatapur Thanda (Vi)	-
1	NLG	Janpahad	Ravipahad	11KV	Huzurnagar	15.25	17.00	01.35	E/L	11 kv line snapped at Ravipahad village	-
2		Koppole	Koppole	11KV	Nalgonda	09.00	10.30	01.30	E/L	11 KV Line cut	-
3		Azmpuram	Chenamnenipally	11KV	Devarakonda	15.03	16.43	01.40	E/L	Jumper Cut	-
1	RR N	Athiwelly	Dabeerpur	11KV	Medchal	18.55	19.35	00.40	BD	11KV Pin Insulator Failed at near Oyster company	-
1	RR E	Mallapur-2	AP Colony	11KV	Habsiguda	10.32	11.12	00.40		11KV UG Cable failed near Laxmi Narsimha Function Hall Opposite due to JCB Work	-
1	HYD C	Erramanzil	Red Rose	11KV	Saifabad	02.16	03.20	01.04	EL,OL	Cable fault at Rajiv Gandhi Statue	Arranged B/F on 11KV I.C.Quarters fdr
2	HYD S	Aliabad	Sharada College	11KV	Charminar	03.45	05.30	01.45	EL,OL	Cable fault at Laxmi Nagar (Kept off DTR at Laxmi Nagar)	-

TSSPDCL - LMRC / Corporate office

Date: 16.04.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Makthal	Narwa	33KV	Narayanapet	17.30	20.50	03.20	EL	Pole damaged	Makthal	-
2		Makthal	Paspula	33KV	Narayanapet	17.30	21.15	03.45	EL	Pin bindings failed and Pole damaged	Makthal	-