

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	RR(S)	53	234									
5	RR(N)	54	550									
6	RR(E)	168	403									
7	Hyd	194	1044		2		2		2			
	Total	606	3055	0	2	0	2	0	2	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		7		7		7			
3	MDK	107	933	1	3	1	3	1	3			
4	RR(S)	58	396									
5	RR(N)	38	114									
6	RR(E)	22	133									
	Total	476	3413	1	10	1	10	1	10	0	0	
	Grand Total	1082	6468	1	12	1	12	1	12	0	0	

TSSPDCL - LMRC / Corporate office

Date: 17.04.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	Zaheerabad	Machnoor	33KV	Zaheerabad	18.30	20.30	02.00		B/D due to Tree fallen on line Alternate supply arrengeed from Jharasangem feeder	Machnoor	-

TSSPDCL - LMRC / Corporate office

Date: 17.04.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Bopparam	Kotapahad	11KV	Suryapeta	14.00	16.30	02.30	E/L	Insulator failed	-
2		Madhanapoor	Madhanapoor	11KV	Devarakonda	08.00	10.00	02.00	E/L	Conductor Snapped	-
3		Dindi	Dindi	11KV	Devarakonda	09.00	12.10	03.10	E/L	Jumper cut	-
4		Siripuram	Siripuram	11KV	Huzurnagar	15.00	18.00	03.00	E/L	11KV Line cut	-
5		Urlugonda	Karkayalagudem	11KV	Huzurnagar	09.00	12.00	03.00	E/L	Jumper cut	-
6		Tripuraram	Duggepally	11KV	Miryalagudem	14.00	15.00	01.00	E/L	Jumper cut	-
7		Mupparam	Utkoor	11KV	Miryalagudem	15.30	17.30	02.00	E/L	Insulator failed	-
1	MDK	Cheryal	Turbovent	11KV	Sangareddy	14.33	17.25	17.50		B/D due to Tree fallen on line	-
2		Thogita	H.Ghanpur	11KV	Medak	07.55	10.10	02.15		B/D due to Bird fallen on 11 KV line	-
3		H.Ghanpur	Aurangabad	11KV	Medak	09.10	11.30	02.20		B/D due to 11 KV Jumper cut.	-
1	HYD S	Panjasha	Panjasha	11KV	III	09.39	10.48	01.09	EL,OL	2No. DTR's fault at Panjasha	-----
1	HYD C	Fever Hospital	Tourist Hotel	11KV	II	07.30	09.32	02.02	EL	Cable fault	Partial fdr charged & remaining loads added on 11KV Moulana Azad Nagar feeder