

Status Report on Breakdowns (Urban / Rural)**Urban**

| S.No | Circle | No.of Feeders Existing Urban | | Breakdowns occurred during the day | | Attended during the day | | Time taken for restoring the supply | | | | Remarks (Pending) |
|------|--------------|------------------------------|-------------|------------------------------------|----------|-------------------------|----------|-------------------------------------|----------|--------------------------------|----------|-------------------|
| | | 33KV | 11KV | 33KV | 11KV | 33KV | 11KV | Rectified (Within 24 Hours) | | Not Rectified (Above 24 Hours) | | |
| | | | | | | | | 33KV | 11KV | 33KV | 11KV | |
| 1 | MBN | 18 | 107 | | | | | | | | | |
| 2 | NLG | 22 | 358 | | | | | | | | | |
| 3 | MDK | 97 | 359 | | | | | | | | | |
| 4 | RR(S) | 53 | 234 | | 4 | | 4 | | 4 | | | |
| 5 | RR(N) | 54 | 550 | 1 | 1 | 1 | 1 | 1 | 1 | | | |
| 6 | RR(E) | 168 | 403 | | | | | | | | | |
| 7 | Hyd | 194 | 1044 | | | | | | | | | |
| | Total | 606 | 3055 | 1 | 5 | 1 | 5 | 1 | 5 | 0 | 0 | |

Rural

| S.No | Circle | No.of Feeders Existing Rurals | | Breakdowns occurred during the day | | Attended during the day | | Time taken for restoring the supply | | | | Remarks (Pending) |
|------|--------------------|-------------------------------|-------------|------------------------------------|-----------|-------------------------|-----------|-------------------------------------|-----------|--------------------------------|----------|-------------------|
| | | 33KV | 11KV | 33KV | 11KV | 33KV | 11KV | Rectified (Within 24 Hours) | | Not Rectified (Above 24 Hours) | | |
| | | | | | | | | 33KV | 11KV | 33KV | 11KV | |
| 1 | MBN | 107 | 849 | 5 | | 5 | | 5 | | | | |
| 2 | NLG | 144 | 988 | 1 | 5 | 1 | 5 | 1 | 5 | | | |
| 3 | MDK | 107 | 933 | | 1 | | 1 | | 1 | | | |
| 4 | RR(S) | 58 | 396 | 1 | | 1 | | 1 | | | | |
| 5 | RR(N) | 38 | 114 | | | | | | | | | |
| 6 | RR(E) | 22 | 133 | | | | | | | | | |
| | Total | 476 | 3413 | 7 | 6 | 7 | 6 | 7 | 6 | 0 | 0 | |
| | Grand Total | 1082 | 6468 | 8 | 11 | 8 | 11 | 8 | 11 | 0 | 0 | |

TSSPDCL - LMRC / Corporate office

Date: 18.04.2018

| S.No | Circle | Name of 132/33KV SS | Name of 33 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Sub Stations Effected | Alternate Supply Arranged |
|------|--------|---------------------|----------------------|------|----------------------|-------|-------|----------|------------------|---|-----------------------|---|
| 1 | MBNR | Wanaparthy | Kodair | 33KV | Wanaparthy | 16.45 | 18.10 | 01.25 | | LA failed at 132KV SS Wanaparthy | Kodair | - |
| 2 | | Achampet | Amrabad | 33KV | Nagarkurnool | 04.15 | 09.55 | 05.40 | EL | 2 Nos Insulator Failed near Mananoor SS | Amrabad | - |
| 3 | | 220KV Singotam | Narsaipally | 33KV | Nagarkurnool | 10.04 | 11.34 | 01.30 | EL | Tree Fallen on the line near Mahasamudram | Narsaipally | Isolator opened 11.34hrs at Narsaipally |
| 4 | | Wanaparthy | Chinnamaroor | 33KV | Wanaparthy | 22.20 | 00.10 | 01.50 | O/L | Due to Heavy Wind & Rain | Chinnamaroor | Pathapally(V) Towards |
| 5 | | Alampur | Shantinagar-1 | 33KV | Gadwal | 23.06 | 23.42 | 00.36 | E/L | Due to Heavy Wind & Rain | Shantinagar-1 | AB Switch Opened at Ramanuram |
| 1 | NLG | Miryalguda | Tripuraram | 33KV | Miryalguda | 02.00 | 11.00 | 09.00 | E/L | 33 KV insulater failure at Srinivas nagar | Tripuraram | - |
| 1 | RR S | Pargi | Savithri-I | 11KV | VKB | 05.40 | 07.30 | 01.50 | | Jumper cut | | - |
| 1 | RR N | 132KV Medchal | 33KV Devarayamjal | 33KV | Medchal | 14.45 | 15.10 | 00.25 | BD | 33KV Cable damaged at 132KV Medchal SS | 33KV Devarayamjal | - |

TSSPDCL - LMRC / Corporate office

Date: 18.04.2018

| S.No | Circle | Name of 33/11KV SS | Name of 11 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Alternate Supply Arranged |
|------|--------|--------------------|----------------------|------|----------------------|-------|-------|----------|------------------|-------------------------------------|---------------------------|
| 1 | NLG | Jammigadda | Kesaram | 11KV | Suryapet | 12.30 | 15.11 | 02.41 | E/L | 11Kv Jumper cut | - |
| 2 | | Mukundapuram | Somaram | 11KV | Huzurnagar | 06.30 | 12.30 | 06.00 | E/L | 11KV Line snapped at Somaram (v) | - |
| 3 | | Marrur | M.G.Pally | 11KV | Nalgonda | 13.35 | 16.20 | 02.45 | E/L | 11 KV Jumper Cut | - |
| 4 | | Mushampally | Mushampally | 11KV | Nalgonda | 06.00 | 11.20 | 05.20 | E/L | 11 KV Line Insulator Failed | - |
| 5 | | Thoragal | Thangallevarrigudem | 11KV | Nalgonda | 13.10 | 16.50 | 03.40 | E/L | 11 KV Jumper Cut | - |
| 1 | MDK | Nagapur | Thimmaipally | 11KV | Medak | 12.00 | 14.00 | 02.00 | | B/D due to 11Kv insulator failed | - |
| 1 | RR S | NIRD | Appad | 11KV | Rajndranagar | 10.23 | 12.22 | 01.59 | | Cable fault | - |
| 2 | | Nanakramguda | Manjeera Daimond | 11KV | Cybercity | 10.56 | 12.17 | 01.21 | | Phase to Phase | - |
| 3 | | ESCI | Divyasree | 11KV | Cybercity | 04.24 | 10.00 | 05.36 | | UG Cable damage | - |
| 4 | | Ayyappa Society | Hundai | 11KV | Cybercity | 13.19 | 15.40 | 02.21 | | UG Cable damage | - |
| 1 | RR N | Bachupally | S MS | 11KV | Kukatpally | 13.25 | 15.00 | 01.35 | EL&OL | 11kv Pole daimage At bollram x Road | - |