

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	RR(S)	53	234		1		1		1			
5	RR(N)	54	550									
6	RR(E)	168	403		1		1		1			
7	Hyd	194	1044		3		3		3			
	Total	606	3055	0	5	0	5	0	5	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	4		4		4				
2	NLG	144	988	2	5	2	5	2	5			
3	MDK	107	933		1		1		1			
4	RR(S)	58	396									
5	RR(N)	38	114									
6	RR(E)	22	133									
	Total	476	3413	6	6	6	6	6	6	0	0	
	Grand Total	1082	6468	6	11	6	11	6	11	0	0	

TSSPDCL - LMRC / Corporate office

Date: 22.04.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Dirsenpally	Alugunoor	11kv	Suryapet	13.30	14.50	01.20	E/L	Disk failed	-
2		Palakeedu	Bothalapalem	11kv	Huzurnagar	06.40	08.45	02.05	E/L	11 KV Jumper open at Bothalapalem village	-
3		Matoor	Matoor	11kv	Miryalaguda	09.00	12.00	03.00	E/L	11KV disc insulator failed near Vaagu and conductor snapped	-
4		K.M.Pally	C.A.Pally	11kv	Devarakonda	13.30	17.55	04.25	E/L	Jumper Cutt	-
5		Ghanapuram	Polkampally	11kv	Devarakonda	12.00	13.00	01.00	E/L	Conductor Sanpped	-
1	MDK	MUNIPALLY	MALLIKARJUNA PALLY	11kv	SANGAREDDY	01.00	10.30	09.30		B/D DUE TO POLE DAMAGE AT MALLIKARJUNAPALLY	-
1	RR S	CBIT	Gandipet	11kv	ibrahimbagh	03.50	05.01	01.11	B/D	11kv Pole Damaged at villaskey opposite Due To Lorry Dashed	-
1	RR E	Narapally	Narapally- Industrial	11kv	Keesara	11.40	14.40	03.00		11KV Cable and End Kit failed near Mcdonald Narapally Main Road	-
1	HYD C	Industrial Area	Azamabad Key SS UG	11kv	II	02.35	04.04	01.29	EL,OL-Bph	Cable fault	Arranged B/F on 11KV Shastry Nagar fdr
1	HYD N	Chilkaiguda	P.R Nagar	11kv	V	11.30	12.40	01.10	EL	Tree branches on lines at Shantha Residency	Arranged B/F on 11KV S.P.College fdr (2no DTR Kept Off)
1	HYD S	C.R.P.F	Jamal Banda	11kv	III	13.25	14.50	01.25	EL,OL-Rph	Cable fault at SS	Arranged B/F on 11KV Salala fdr

TSSPDCL - LMRC / Corporate office

Date: 22.04.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Wanaparthy	Revally	33kv	Wanaparthy	20.02	21.35	01.33	O/L	Back Feeding Supply Taken to 33KV Peddakothapally Feeder	Revally	-
2		Ghanpur	Lattupally	33kv	Wanaparthy	19.03	20.30	01.27	O/L	Alternate Supply Arraged to 132KV Nagarkurnool SS	Lattupally	-
3		Nagarkurnool	Rakonda	33kv	Nagarkurnool	17.10	19.30	02.20	E/L	33KV Jumper Cut near Mantatigadda	Rakonda	-
4		Achampet	Veltoor	33kv	Nagarkurnool	16.30	21.25	04.55	E/L	Due to Heavy Gale & Wind and Bus Isulator Problem	Veltoor	-
1	NLG	Kandhukur	Singarajupally	33kv	Devarakonda	15.20	19.45	04.25	OL	Jumper cut	Singarajupally	-
2		Ramannapet	Voligonda	33kv	Bhongiri	02.35	08.35	06.00	EL	33KV Line in Paddy Fallen on Line near Tummalagudem village	Voligonda	-