

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	RR(S)	53	234									
5	RR(N)	54	550									
6	RR(E)	168	403		1		1		1			
7	Hyd	194	1044		3		3		3			
	Total	606	3055	0	4	0	4	0	4	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1	6	1	6	1	6			
2	NLG	144	988		8		8		8			
3	MDK	107	933									
4	RR(S)	58	396									
5	RR(N)	38	114									
6	RR(E)	22	133									
	Total	476	3413	1	14	1	14	1	14	0	0	
	Grand Total	1082	6468	1	18	1	18	1	18	0	0	

TSSPDCL - LMRC / Corporate office

Date: 23.04.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Devarkadra	Lalkota	11KV	Mahabubnagar	08.30	10.30	02.00		11KV Conductor cut at Gopulapur (Vi)	-
2		Maddur	Ayyawaripally	11KV	Mahabubnagar	08.15	11.00	02.45		11KV Jumper cut at Pediripad (vi)	-
3		Kandoor	Komireddypally	11KV	Jadcherla	09.00	11.00	02.00		11kv Insulator fail near Komireddypally	-
4		Janampet	Polkampally	11KV	Jadcherla	05.00	08.30	03.30		11kv Jumper cut near Buchireddy Bai	-
5		Rajapur	Mudireddypally	11KV	Jadcherla	09.00	13.00	04.00		11kv Phase to Phase near Mudireddypally	-
6		Gundlapotlapally	Kallepally	11KV	Jadcherla	13.00	16.30	03.30		11kv wire cut near Kallepally	-
1	NLG	Phanigiri	Etooru	11KV	Suryapet	02.30	06.40	04.10	EL	11 KV Line cut	-
2		S.V Collage	Layola Agl	11KV	Suryapet	03.30	07.10	03.40	EL	Insulator failure	-
3		Tekumatla	Pillalamarry	11KV	Suryapet	03.15	06.30	03.15	EL	Conductor Snapped	-
4		Repala	Narasimhulagudem	11KV	Huzurnagar	04.00	07.30	03.30	EL	Jumper cut	-
5		Devarakonda	Manampally	11KV	Devarakonda	07.20	09.30	02.10	EL	Jumper cut	-
6		Singarajupally	Bramanapally	11KV	Devarakonda	07.00	10.30	03.30	EL	Insulator failure	-
7		Tukkapuram	Gouse nagar	11KV	Bhongir	05.00	08.30	03.30	EL	11 KV Line cut	-
8		Kondamadugu	Kondamadugu	11KV	Bhongir	05.30	07.30	02.00	EL	Jumper cut	-
1	RR E	Narapally	Narapally- Industrial	11KV	Keesara	11.40	14.40	03.00		11KV Cable and End Kit failed near Mcdonald Narapally Main Road	-
1	HYD C	Golnaka	Shivalayam	11KV	Azamabad	08.54	12.23	03.29	EL,OL	Cable fault	
2		Golnaka	Moulana Azad Nagar	11KV	Azamabad	10.33	12.55	02.22	EL,OL	Cable fault	
3	HYD S	Panjesha	Panjesha	11KV	Charminar	11.37	13.16	01.39	OL	Cable fault at Opp: Macca Masjid	

TSSPDCL - LMRC / Corporate office

Date: 23.04.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Balanagar	Sibalco	33KV	Jadcherla	17.25	19.50	02.25	EL	Disc Insulator at Highway Road Balanagar	Sibalco	-