

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	RR(S)	53	234									
5	RR(N)	54	550		2		2		2			
6	RR(E)	168	403									
7	Hyd	194	1044		1		1		1			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>0</b>	<b>3</b>	<b>0</b>	<b>3</b>	<b>0</b>	<b>3</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988	1	14	1	14	1	14			
3	MDK	107	933	2	4	2	4	2	4			
4	RR(S)	58	396									
5	RR(N)	38	114									
6	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>3</b>	<b>18</b>	<b>3</b>	<b>18</b>	<b>3</b>	<b>18</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>3</b>	<b>21</b>	<b>3</b>	<b>21</b>	<b>3</b>	<b>21</b>	<b>0</b>	<b>0</b>	

TSSPDCL - LMRC / Corporate office

Date: 25.04.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	NLG	Munagala	Nadigudem	33KV	Huzurnagar	09.30	14.15	04.45	EL/OL	33 kv jumper cut at Near Nadigudem sub station	Nadigudem	-
1	MDK	Zaheerabad	Buchinelly	33KV	Zaheerabad	02.40	12.40	10.00		BD due to 33KV underline Cable brust	Buchinelly	-
2		Ramayampet	Konapur	33KV	Toopran	16.45	19.20	02.35		BD due to Insulator failed at Konapur	Konapur	-

## TSSPDCL - LMRC / Corporate office

Date: 25.04.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Adivemla	Kunchamarthy	11KV	Suryapet	02.30	07.00	04.30	E/L	Jumper cut	-
2		Bopparam	Bopparam	11KV	Suryapet	03.40	07.55	04.15	E/L	Insulator failed	-
3		Nemmani	Merlakunta	11KV	Nalgonda	07.30	12.15	04.45	E/L	11KV line cut at Thondalvai Chervu	-
4		Pamanagundla	Ismailpally	11KV	Nalgonda	06.15	11.45	05.30	E/L	11KV line cut at Pamanagundla(V)	-
5		Pamanagundla	Pittampally	11KV	Nalgonda	08.20	11.30	03.10	E/L	11KV line cut at Kammagudem(V)	-
6		Baironibanda	N.G.Kothapally	11KV	Nalgonda	06.00	11.05	05.05	E/L	11KV lines melted at villages side	-
7		Peddathanda ss	Pallephad	11KV	Bhongir	06.20	07.25	01.05	O/L	11Kv Jumper snapped at Mothiram thanda LM ravi 9491369150	-
8		Ch.Laxmapur ss	Malkapur	11KV	Bhongir	05.20	10.20	05.00	E/L	Tree Branches Fallen on line Kotyathanda Rajvalli	-
9		B.ramaram ss	Jalalpur	11KV	Bhongir	04.30	09.00	04.30	E/L	Tree Branches Fallen on line at Jalal pur	-
10		Paladugu ss	Dattappagudem	11KV	Bhongir	06.00	09.55	03.55	O/L	Due to heavy gale & wind	-
11		Laxmapur ss	Laxmapur	11KV	Bhongir	06.50	12.40	05.50	O/L	ARIYA NAIZAMULA 11KV INSULATER FAILD	-
12		Naryanapur	K.k gudem	11KV	Bhongir	06.00	08.30	02.30	O/L	Tree Branches Fallen on line near Jankamma cheruvu Poles 11KV ,	-
13		Naryanapur	Gudimalkapuram	11KV	Bhongir	06.00	09.15	03.15	E/L	Tree Branches Fallen on line near Shivalayam veedhi	-
14		Naryanapur	Kothagudem	11KV	Bhongir	06.00	11.05	05.05	E/L	Tree Branches Kothagudem ALM RAVINDRA MOHAN	-
1	MDK	Kondapur	Gangaram	11KV	Sangareedy	14.00	19.00	05.00		B/D due to 11KV Jumper cut (ONLY 3-PH)	
2		Cheryal	Kandhi	11KV	Sangareedy	07.30	09.45	02.15		B/D due to 11KV Jumper cut	
3		Kistareddypet	Sulthanpur Idl	11KV	Sangareedy	02.20	10.30	08.10		BD due to Disk failed	
4		EPIP-II	EXPORT	11KV	Sangareedy	00.00	08.00	08.00		B/D due to Tree fallen on line	
1	RR N	Bommarajpet	Karkalamma	11KV	Medchal	05.30	08.44	03.14	BD	11KV Line Cut & Replaced at Sunil Thota	-
2		GP Pally	Malla Reddy	11KV	Medchal	12.40	15.20	02.40	BD	11KV Cable end kit failed in SS	-
1	HYD N	Nehru Nagar	Rezimental Bazar	11KV	V	09.05	10.40	01.35	EL	Cable fault at Sangeeth X Road	Arranged B/F on 11KV Railway Reservation fdr