

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	RR(S)	53	234									
5	RR(N)	54	550									
6	RR(E)	168	403									
7	Hyd	194	1044	1	2	1	2	1	2			
	Total	606	3055	1	2	1	2	1	2	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		8		8		8			
3	MDK	107	933		5		5		5			
4	RR(S)	58	396									
5	RR(N)	38	114									
6	RR(E)	22	133									
	Total	476	3413	0	13	0	13	0	13	0	0	
	Grand Total	1082	6468	1	15	1	15	1	15	0	0	

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Penpahad	Anajipuram	11KV	Suryapet	02.40	06.30	03.50	E/L	11KV Conductor snapped	No
2		Arlagaddagudem	Mangalapally	11KV	Nalgonda	05.10	09.20	04.10	E/L	11 KV Jumper cut at Mangalapally (V)	No
3		Eduloor	Naregudem	11KV	Nalgonda	06.00	08.20	02.20	E/L	11 KV Line insulator Failed	No
4		Palakeedu	Sajjapuram	11KV	Huzurnagar	13:30	16:00	2:30	E/L	11 KV Line snapped	No
5		Repala	N.S.Gudem	11KV	Huzurnagar	05.00	07.00	02.00	E/L	11 KV Jumper cut at Mangalapally (V)	No
6		Chandempeta	Chinriyala	11KV	Devarakonda	6:55	9:45	2:50	E/L	Conductor snapped	No
7		Paladugu	Dattappagudem	11KV	Bhongiri	07.30	11.00	03.30	E/L	11 KV Insulator failed	No
8		Agamothkur	Agamothkur	11KV	Miryalaguda	06.00	09.00	03.00	E/L	Conductor snapped	No
1	MDK	Venkatraopet	Railpur	11KV	Medak	11:10	13:10	2:00		11 KV Insulator failed	No
1	SDPT	Dhoolmitta	Lingapur	11KV	Husnabad	12.15	15.00	02.45		Conductor Snapped and rectified	No
2		Komuravelly	Inapur	11KV	Husnabad	06.15	09.15	03.00		Tree branch fallen and rectified	No
3		Bejjanki	Regulapally	11KV	Husnabad	00.00	09.00	09.00		Insulator failed and rectified	No
4		Potharam	Keshavapur	11KV	Husnabad	19:00	19:40	0:40		Jumper cut and rectified	No
1	HYD S	Falaknuma	Vattepally	11KV	Charminar	19.45	21.23	01.38	OL-Yph	Over load due to addition loads of 11KV Falaknuma UG Cable fdr	Partial fdr charged & remaining loads added on 11KV G.S.Darga fdr
1	HYD C	Public Garden	Nampally Railway Station	11KV	Saifabad	00.37	01.50	01.13	OL	Twisted Lines at Vysya Bank	No

TSSPDCL - LMRC / Corporate office

Date: 27.04.18

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	HYD N	132KV Erragadda	Jana Priya	33KV	Allwyn	19.55	20.24	00.29	All Indication	Cable fault	Jana Priya	Loads transferred onto 132KV Erragadda SS via 33KV L.D.P.L. fdr