

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		5		5		5			
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044		16		16		16			
	Total	606	3055	0	22	0	22	0	22	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1		1		1				
2	NLG	144	988		6		6		6			
3	MDK	107	933		2		2		2			
4	SDPT			4	9	4	9	4	9			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	5	17	5	17	5	17	0	0	
	Grand Total	1082	6468	5	39	5	39	5	39	0	0	

TSSPDCL - LMRC / Corporate office

Date: 01.08.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Nagarkurnool	Manthathi	33KV	Nagarkurnool	11.16	14.55	03.39	E/L	Manthathi Feeder Loads Tag On to 33KV Nagarkurnool Feeder	Manthathi	Manthathi Feeder Loads Tag On to 33KV Nagarkurnool Feeder
1	Siddipet	Mustyala	Cherial	33KV	Husnabad	20.25	20.54	00.29		BD OL Wind & Rain	CHERIAL	-
2		Mustyala	Tharigoppula	33KV	Husnabad	15.55	17.15	01.20		OL WIND & RAIN	Tharigoppula	-
3		Palamakula	Narmetta	33KV	Siddipet	16.08	17.10	01.02		Heavy Rain	Narmetta	-
4		Palamakula	Narmetta	33KV	Siddipet	20.44	22.25	01.41		Heavy Rain	Narmetta	-

TSSPDCL - LMRC / Corporate office

Date: 01.08.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Mamidala	Godhavari Gudem	11KV	Nalgonda	03.00	09.40	06.40	E/L	11KV Line Jumper Cut	-
2		Nereda	Nereda AGL	11KV	Nalgonda	08.00	11.10	03.10	E/L	11 KV Line Insulator Failed	-
3		Arlagadda Gudem	Thatikal	11KV	Nalgonda	06.27	09.50	03.23	E/L	11KV Line Jumper Cut	-
4		B.Annaram	Balajinagar	11KV	Miryalguda	07.00	13.00	06.00	E/L	11KV Insulator failed	-
5		Reddygudem	Reddygudem	11KV	Suryapet	08.45	10.50	02.05	E/L	Conductor snapped	-
6		Dondapadu	Kakatiya	11KV	Huzurnagar	02.10	05.00	02.50	E/L	Due to 11Kv line snapped	-
1	MDK	Gaddapotharam	Kajipally	11KV	Patancheru	16.50	19.35	02.45		B/D due to Conductor sanpped	-
2		Gummadidala	Mambapur	11KV	Patancheru	18.20	22.10	03.50		B/d due to Tree branches fallen on the line near Narsapur X road.	-
1	Siddipet	Gouravelly	Gudatipally	11KV	Husnabad	17.20	18.05	00.45		BD wind & rain	-
2		Bejjanki	Kalllepally	11KV	Husnabad	18.10	22.30	04.20		BD wind & rain	-
3		Bejjanki	Muthannapet	11KV	Husnabad	18.30	21.50	03.20		BD wind & rain	-
4		Koheda	Koheda Town	11KV	Husnabad	16.30	17.15	00.45		BD conductor snapped	-
5		Shanigaram	Gundareddypally	11KV	Husnabad	16.00	19.20	03.20		BD conductor snapped	-
6		Cherial Town	Rollabanda Agl	11KV	Husnabad	21.00	21.40	00.40		BD Tree fallen	-
7		Guruvannapet	Guruvannapet	11KV	Husnabad	15.00	18.00	03.00		1PH OK,3PH BD	-
8		Dhoolmitta	Arjunpatla	11KV	Husnabad	16.00	19.15	03.15		BD wind & rain	-
9		Gagillapur	Gagillapur Agl	11KV	Husnabad	18.00	22.15	04.15		BD wind & rain	-
1	RR N	Thurkapally	Thurkapally	11KV	Medchal	17.00	19.30	02.30	BD	11KV Pin Insulator failed at Thurkpally Village	-
2		Aliabad	HBL	11KV	Medchal	17.35	18.35	01.00	BD	No Fault	-
3		Kolthur	Anantharam	11KV	Medchal	19.10	20.10	01.00	BD	11KV Pin Insulator failed at Anantharam Village	-
4		Yellampet	IDA	11KV	Medchal	18.25	19.05	00.40	BD	11KV Jumper cut and replaced at Bisco Seeds Company	-
5		Ravalkole	IDA	11KV	Medchal	19.05	21.30	02.25	BD	11KV Pin Insulator failed at Kasimbhai Thanda	-
1	RR E	Pocharam	Pocharam	11KV	Keesara	10.55	11.55	01.00		Bird fallen on 11kv line at pocharam	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	HYD N	Bowenpally	Jaya Nagar	11KV	VI	23.35	00.40	01.05	EL,OL	Pin Insulator flash over at Jaya Nagar	-
2		H.A.L	India Rubber	11KV	VI	23.20	00.35	01.15	EL	Pin Insulator flash over at Plot No.38, T.I.E Bala Nagar	-
3		Prasasan Nagar	Woods Apartment	11KV	X	23.35	01.00	01.25	EL	Disc Insulator flash over near SS	-
4		Toli Chowki	Road No. 86	11KV	X	23.30	00.50	01.20	EL	Tree branches on lines at Raghuveera House	-
5		Toli Chowki	Hanuman Temple	11KV	X	23.25	02.00	02.35	All Indication	Tree branches on lines at D.Srinivas House	-
1	HYD S	Falaknuma	Ravindra Naik Nagar	11KV	III	03.10	07.07	03.57	EL,OL	Breaker problem at SS	Arranged B/F on 11KV Jangammet OH fdr
2		Kandikal Gate	G.M.Chowni	11KV	III	04.50	06.20	01.30	EL	Pin Insulator flash over G.M.Chowni	-
3		Falaknuma	Jangam Mett OH	11KV	III	16.10	18.25	02.15	EL	Disc flash over at Khadri Chaman	17:05 Hrs partial 10Amps charged
4		Panjesha	Metherwadi	11KV	III	17.55	19.15	01.20	OL	Cable fault	Arranged B/F on 11KV Gowlipura fdr
5		Panjesha	Panch Mohalla	11KV	III	23.55	01.30	01.35		Pin Insulator flash over at Govt.School	-
1	HYD C	Langer House	Netaji Nagar	11KV	VII	20.45	21.56	01.11	EL	HT Jumper cut at Lorry Adda, Netaji Nagar	-
2		Zamistanpur	Jama Osmania	11KV	II	21.04	22.10	01.06	EL,OL-Rph	No Visible Fault	-
3		Amberpet	6no Road	11KV	II	20.45	22.53	02.08	EL,OL	O/G Rph AB Switch & Cable End Kit fault at SS	-
4		Chilkaiguda	Golconda X Road	11KV	II	22.55	00.10	01.15	EL	Banner fallen onlines at Golden Café	-
5		Bathakammakunta	Ayyappa Temple	11KV	II	23.32	00.41	01.09	EL	No Visible Fault	-
6		Bathakammakunta	D.D.Colony	11KV	II	23.32	02.38	03.06	EL	Pin Insulator flash over at Water Works	at 00.27 hrs Partial feeder charged