

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		1		1		1			
6	RR(N)	54	550									
7	RR(E)	168	403		3		3		3			
8	Hyd	194	1044	1	3	1	3	1	3			
	Total	606	3055	1	7	1	7	1	7	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1		1		1				
2	NLG	144	988		7		7		7			
3	MDK	107	933		4		4		4			
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	11	1	11	1	11	0	0	
	Grand Total	1082	6468	2	18	2	18	2	18	0	0	

TSSPDCL - LMRC / Corporate office

Date: 03.08.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Makthal	Jaklair	33KV	Narayanapet	20.50	23.20	02.30	E/L	Pin Insulator Damaged and Replaced at Lingampally Village	Makthal	-
1	HYD C	132KV Asif Nagar	Mothi Mahal	CEN	Asif Ngr	10.05	10.20	00.15	EL	Cable damaged by GHMC wing near Andhra Floor Mill	132KV Asif Nagar	Loads transferred onto 132KV J' Hills SS via 33KV Mothi Mahal fdr

TSSPDCL - LMRC / Corporate office

Date: 03.08.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Gundepuri	Gundepuri	11KV	Suryapet	11.30	14.20	02.50	E/L	Conductor snapped	-
2		Alingapuram	Raghavapuram	11KV	Huzurnagar	12.00	14.00	02.00	EL/OL	Due 11Kv Insulator failure	-
3		Garidepally	Ponugodu	11KV	Huzurnagar	03.35	06.30	02.55	EL	Due to tree branch fall on 11Kv line	-
4		Chilukur	Kondapuram	11KV	Huzurnagar	05.35	07.35	02.00	EL	Due 11kv Disk failure	-
5		Raghunadapalem	Nakkalagudem	11KV	Huzurnagar	03.30	06.45	03.15	EL	Due 11Kv jumper cutted	-
6		Mamidala	Mamidala	11KV	Nalgonda	14.00	17.00	03.00	E/L	11KV jumper cut	-
7		Mothkur	Anajipur	11KV	Bhongiri	14.20	17.20	03.00	O/L	11KV Line Snapped	-
1	MDK	Bollaram - II	Vipla	11KV	Patancheru	16.05	16.55	00.50		BD due to Jumper cut	-
2		B.B.Pur	B.B.Pur	11KV	Medak	12.30	16.55	04.25		B/D DUE TO TREE FALL ON 11KV LINE	-
3		Kowdipally	Mohd Nagar	11KV	Medak	12.00	17.50	05.50		B/D DUE TO 11KV WIRE CUT	-
4		Gangaram	Bandapothugal	11KV	Medak	15.00	17.20	02.20		B/D DUE TO 11KV INSULATOR FAILURE	-
1	RR S	Mathrusri Nagar	Vishwambera	11KV	Gachibowli	10.55	12.25	01.30	BD	Tree branches fallen on the 11kv line at Vishwambera Villas	-
1	RR E	Mallapur	Noma	11KV	HBG	12.35	13.35	01.00		25KVA T/F Brash patti cut at Gokula nagar	-
2		NGRI	Scientist colony	11KV	HBG	15.02	16.15	01.13		11kv Cble fail at white house HBg main road	-
3		Sainikpuri	Defence Colony	11KV	SKP	12.50	13.55	01.05		100Kva T/F Copper Patti cut at Nirmal Nagar (LM Chandu)	-
1	HYD N	Pragatools	TC Bala Nagar	11KV	Bowenpally	13.02	16.55	03.53	OL-Rph	Feeder charged at 13:07 Hrs but Hand tripped at 13:09 Hrs for removing tree branches on lines & restrining snapped HT line at IDA Bala Nagar	-
2		H.A.L	Sri Rama	11KV	Bowenpally	15.50	18.10	02.20	EL,OL-Rph	HT Jumper cut at Usha Company	-
1	HYD C	Gudimalkapur	Murad Nagar	11KV	Mehdipatanam	16.49	18.05	01.16	EL	Cable fault	Arranged B/F on 11KV LIC Office feeder