

Status Report on Breakdowns (Urban / Rural)

Urban

| S.No | Circle | No.of Feeders Existing Urban | | Breakdowns occurred during the day | | Attended during the day | | Time taken for restoring the supply | | | | Remarks (Pending) |
|------|--------------|------------------------------|-------------|------------------------------------|----------|-------------------------|----------|-------------------------------------|----------|--------------------------------|----------|-------------------|
| | | 33KV | 11KV | 33KV | 11KV | 33KV | 11KV | Rectified (Within 24 Hours) | | Not Rectified (Above 24 Hours) | | |
| | | | | | | | | 33KV | 11KV | 33KV | 11KV | |
| 1 | MBN | 18 | 107 | | | | | | | | | |
| 2 | NLG | 22 | 358 | | | | | | | | | |
| 3 | MDK | 97 | 359 | | | | | | | | | |
| 4 | SDPT | | | | | | | | | | | |
| 5 | RR(S) | 53 | 234 | | | | | | | | | |
| 6 | RR(N) | 54 | 550 | | 3 | | 3 | | 3 | | | |
| 7 | RR(E) | 168 | 403 | | 2 | | 2 | | 2 | | | |
| 8 | Hyd | 194 | 1044 | | 1 | | 1 | | 1 | | | |
| | Total | 606 | 3055 | 0 | 6 | 0 | 6 | 0 | 6 | 0 | 0 | |

Rural

| S.No | Circle | No.of Feeders Existing Rurals | | Breakdowns occurred during the day | | Attended during the day | | Time taken for restoring the supply | | | | Remarks (Pending) |
|------|--------------------|-------------------------------|-------------|------------------------------------|-----------|-------------------------|-----------|-------------------------------------|-----------|--------------------------------|----------|-------------------|
| | | 33KV | 11KV | 33KV | 11KV | 33KV | 11KV | Rectified (Within 24 Hours) | | Not Rectified (Above 24 Hours) | | |
| | | | | | | | | 33KV | 11KV | 33KV | 11KV | |
| 1 | MBN | 107 | 849 | 2 | | 2 | | 2 | | | | |
| 2 | NLG | 144 | 988 | | 4 | | 4 | | 4 | | | |
| 3 | MDK | 107 | 933 | | | | | | | | | |
| 4 | SDPT | | | 1 | 2 | 1 | 2 | 1 | 2 | | | |
| 5 | RR(S) | 58 | 396 | | | | | | | | | |
| 6 | RR(N) | 38 | 114 | | | | | | | | | |
| 7 | RR(E) | 22 | 133 | | | | | | | | | |
| | Total | 476 | 3413 | 3 | 6 | 3 | 6 | 3 | 6 | 0 | 0 | |
| | Grand Total | 1082 | 6468 | 3 | 12 | 3 | 12 | 3 | 12 | 0 | 0 | |

TSSPDCL - LMRC / Corporate office

Date: 08.08.2018

| S.No | Circle | Name of 132/33KV SS | Name of 33 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Sub Stations Effected | Alternate Supply Arranged |
|------|----------|---------------------|----------------------|------|----------------------|-------|-------|----------|------------------|---|-----------------------|---------------------------|
| 1 | MBNR | Makthal | Paspula | 33KV | Narayanpet | 08.45 | 12.50 | 04.05 | E/L&O/L | Bird Fallen on the 33KV Line near Boinpally (V) | Paspula | - |
| 2 | | Makthal | Paspula | 33KV | Narayanpet | 18.05 | 22.05 | 04.00 | E/L | Pin Insulator Damaged at Paspula. | Paspula | - |
| 1 | Siddipet | Thunkibollaram | Chilasagar | 33KV | Gajwel | 19.25 | 20.25 | 01.00 | | Brakdown due to OL | Chilasagar | - |

TSSPDCL - LMRC / Corporate office

Date: 08.08.2018

| S.No | Circle | Name of 33/11KV SS | Name of 11 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Alternate Supply Arranged |
|------|----------|--------------------|----------------------|------|----------------------|-------|-------|----------|------------------|--|---------------------------|
| 1 | NLG | Athmakur (S) | Gottimukkalgudem | 11KV | Suryapet | 15.00 | 16.40 | 01.40 | E/L | Jumper cut | - |
| 2 | | Kopple | Bheemaram | 11KV | Nalgonda | 04.45 | 08.20 | 03.35 | E/L | 11 KV Jumper Cut at Bheemaram (V) | - |
| 3 | | Ch.Mamidi | Velmakanne | 11KV | Nalgonda | 09.50 | 12.20 | 02.30 | E/L | 11 KV Line Jumper Cut at Ch.Mamidi (V) | - |
| 4 | | Mushampally | Mushampally AGL | 11KV | Nalgonda | 10.10 | 11.50 | 01.40 | E/L | 11 KV Line Insulator Failed | - |
| 1 | Siddipet | Cherial Town | Rollabanda Agl | 11KV | Husnabad | 14.15 | 15.40 | 01.25 | | OL CONDUTOR FELT ON HG FUSE | - |
| 2 | | Mustyal | Cherial Agl | 11KV | Husnabad | 15.40 | 16.50 | 01.10 | | BD DUE TO MONKEY DIED | - |
| 1 | RR N | Kompally | Kompally | 11KV | Medchal | 21.03 | 21.53 | 00.50 | | Tree fallon on the 11KV Line at Aparna Gate | - |
| 2 | | Jagathgirigutta | Jagathgirigutta | 11KV | Medchal | 21.15 | 22.05 | 00.50 | | 11KV AB Cable end kit failed at Anjaiah nagar Road no 6 | - |
| 3 | | Subhash nagar | Padma Nagar | 11KV | Medchal | 21.20 | 22.20 | 01.00 | | No Fault | - |
| 1 | RR E | NGRI | Habsiguda | 11KV | Habsiguda | 01.30 | 04.05 | 02.35 | | 11KV Pin Insulator failed and Lizard fallen on line near St.No.04 at Habsiguda | - |
| 2 | | Chakripuram | SV Nagar | 11KV | Keesara | 18.46 | 19.30 | 00.44 | | Tree branches touched to 11kv line at SV Nagar Road No.02 | - |
| 1 | HYD C | Bathakamma Kunta | Ayyappa Nagar | 11KV | II | 21.38 | 22.52 | 01.14 | EL | Pin Insulator falsh over at Vaishanavi Apts | - |