

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		2		2		2			
6	RR(N)	54	550		6		6		6			
7	RR(E)	168	403		7		7		7			
8	Hyd	194	1044		7		7		7			
	Total	606	3055	0	22	0	22	0	22	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	7	3	5	3	5	3	2		2Nos. 33KV Still
2	NLG	144	988		23		23		23			
3	MDK	107	933	1	3	1	3	1	3			
4	SDPT			1	3	1	3	1	3			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	9	32	7	32	7	32	2	0	
	Grand Total	1082	6468	9	54	7	54	7	54	2	0	

TSSPDCL - LMRC / Corporate office

Date: 11.08.18

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Balanagar	Rajapur	33KV	Jadcherla	07.30	09.10	01.40	E/L	CTPT Problem Rectified	Rajapur	No
2		Balanagar	Surya Jyothi	33KV	Jadcherla	22.30	00.00	01.30	E/L	Not Rectified Due to Rain	Surya Jyothi	No
3		Amarchintha	Atmakur	33KV	Wanaparthi	20.51	21.05	00.14	E/L	Due to Heavy Rain	Atmakur	At 21:05 hrs. Alternate Supply taken to 33KV Amarchintha Feeder
4		Nagarkurnool	lthole	33KV	Nagarkurnool	16:15	18:00	1:45	E/L	No visible fault	lthole	No
5		Nagarkurnool	lthole	33KV	Nagarkurnool	23:45	0:00	0:15	E/L	Not Rectified Due to Rain	lthole	No
6		Achampet	Amrabad	33KV	Nagarkurnool	7:15	8:50	1:35	E/L	AB Switch Opened at Mannanoor	Amrabad	No
7		Achampet	Uppunthala	33KV	Nagarkurnool	06.20	08.15	01.55	E/L	AB Switch Opened at Uppunthala	Uppunthala	No
1	MDK	Gummadidala	Dundigal	33KV	Patancheru	18:15	19:00	0:45		Disc failed	Dundigal	No
1	SDPT	Siddipet	Palamakula	33KV	Patancheru	8:52	9:28	0:36		Breakdown	Palamakula	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Kourampet	Bandameedipally	11KV	Jadcherla	02.40	07.05	04.25		11 Kv insulator failure Near bandameedipally(V)	No
2		Kourampet	Bandameedipally	11KV	Jadcherla	08.55	09.40	00.45		11 KV Wire cut near Shankaraiahpally(V)	No
3		Rajapur	Mallepally	11KV	Jadcherla	09.00	13.00	04.00		11 KV Disc failure near Rajapur (V)	No
1	NLG	Bibigudem	Chivemla	11KV	Suryapet	11:50	13:50	2:00	E/L	Conductor Snapped	No
2		Kasarabadha	Thalla Kampahad	11KV	Suryapet	06.10	09.00	02.50	E/L	Insulator failed	No
3		Palakeedu	Nagireddy gudem	11KV	Huzurnagar	03.40	07.15	03.35	EL	Due to Tree branch fallen on the 11kv line	No
4		Palakeedu	Bothalapalem	11KV	Huzurnagar	02.55	07.00	04.05	EL	Due to 11Kv Insulator failure	No
5		Gaddipally	Gaddipally	11KV	Huzurnagar	08.00	12.15	04.15	EL	Due to 11Kv Disk failure	No
6		Gaddipally	Medaram	11KV	Huzurnagar	06.00	10.45	04.45	EL	Due to 11KV line cutted	No
7		Huzurnagar	Burugadda	11KV	Huzurnagar	07.00	10.15	03.15	EL	Due to 11Kv Insulator failure	No
8		Turkapally	Hyjalapuram	11KV	Nalgonda	07.32	13.44	06.12	E/L	11KV jumper cut	No
9		Koppol(K)	Bheemaram	11KV	Nalgonda	12.35	14.50	02.15	E/L	11KV Insulator failed	No
10		Koppol(K)	Koppole	11KV	Nalgonda	05.40	08.30	02.50	E/L	11KV Insulator failed	No
11		Veliminedu	Gundrampally	11KV	Nalgonda	07.05	13.35	06.30	E/L	11KV Insulator failed	No
12		Indugula	Malapurajugudem	11KV	Nalgonda	07.00	09.30	02.30	O/L	11KV Insulator failed	No
13		Rajupeta	Bandlavarigudem	11KV	Nalgonda	08.20	10.40	02.20	E/L	HT/ LT line melting	No
14		Eduloor	Gadibaigudem	11KV	Nalgonda	11.00	13.10	02.10	E/L	11KV jumper cut	No
15		Palem	Ogodu	11KV	Nalgonda	07.40	12.30	04.50	E/L	11KV jumper cut	No
16		Annaparthi	Cherlapall AGL	11KV	Nalgonda	12.50	15.30	02.40	O/L	Tree branches fallen on line	No
17		AD Pally	Mudimanikyam	11KV	Miryalaguda	13.30	17.20	03.50	E/L	Tree branches fallen on the 11KV line	No
18		Agamothkur	Agamothkur	11KV	Miryalaguda	11.40	12.00	00.20	O/L	Disc failure	No
19		Guntipally	Yerrabelli	11KV	Miryalaguda	02.00	06.20	04.20	E/L	Insulator failure	No
20		Peddavooru	Battugudem	11KV	Miryalaguda	20.20	23.10	02.50	E/L	Disc failure	No
21		Rajavaram	Juvvichettu thanda	11KV	Miryalaguda	09.00	10.00	01.00	E/L	Insulator failure	No
22		Settipalem	Settipalem-2	11KV	Miryalaguda	00.00	03.25	03.25	O/L	Insulator failure	No
23		Chada	Kolanpaka	11KV	Bhongir	6:00	15:00	9:00	EL	Due to Heavy Gale & Wind 11kv Disc failed near Muthireddy Gudeam Villge	No
1	MDK	Kistareddypet	Industrial	11KV	Patancheru	0:20	2:24	2:04		BD due to Jumper cut	No
2		Patancheru	MIA-II	11KV	Patancheru	14.00	15.55	01.55		BD due to Disc failed	No
3		Cheryal	Kandi	11KV	Sangareddy	06.15	09.55	03.40		BD due to Phase to Phase	No
1	SDPT	Rebarthy	Ladnoor	11KV		07.30	13.15	05.45		Insulator failure same rectified	No
2		Husnabad	Husnabad Town-II	11KV		09.45	10.25	00.40		Tree branch fallen same rectified	No
3		Katkur	Katkur Rural	11KV		07.00	11.00	04.00		Insulator failure same rectified	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	RR S	IIIT	Kendriya Vihar	11KV	Gachibowli	10:20	13:10	2:50		11k Cable fallen on Main road at IIIT Sub station	No
2		L & T	PJR Nagar	11KV	Gachibowli	17.01	18.56	01.55		11kv Disc failed near Sirnu patel street at Telecom nagar	No
1	RR N	Mayurinagar	Cable	11KV	Kukatpally	5:15	6:30	1:15		Tripped on EL/OL	No
2		Jeedimetla SS IV	A A I Matha	11KV	Jeedimetla	17.26	18.26	01.00		T/F HG fuse Failure At paddamma Temple Subasha Nagar	No
3		Bahadurapally	Indiramma Colony	11KV	Jeedimetla	20.50	22.50	02.00		11kv pin Insulator failure at Bahadurapally High school	No
4		Subhash nagar	Jairam Nagar	11KV	Medchal	19.10	21.05	01.55		Tree fallan on the 11KV Line at Godhavari Homes	No
5		Aliabad	HBL	11KV	Medchal	17.50	18.50	01.00		11KV Pin Insulator Failed at paper company, Aliabad	No
6		Yellampet	IDA	11KV	Medchal	21:10	22:10	1:00		Tree fallan on the 11KV Line at Sangamhelth care	No
1	RR E	Cherelapally-I	EC Computer	11KV	Sainikpuri	23:55	0:50	0:55		11Kv Post of Insuletor failure at MVTNFO Sarvece (Artisan/Bikshapathi)	No
2		Cherelapally-I	Phase-I	11KV	Sainikpuri	07.10	08.40	01.30		11Kv Insulator failed (a hole occurred on the top of the insulator) at Surana Chowrasta Due to Heavy Rain (AE)	No
3		Sainikpuri	Eshwar puri	11KV	Sainikpuri	20.28	21.20	00.52		11Kv Pin Insulator failed at Out colony and AB Switch opened (AE)	No
4		Kushaiguda	Rukminipuri	11KV	Sainikpuri	19.00	19.45	00.45		1Kv Pin Insulator failed at Adhishwara (AE)	No
5		Vinayak Nagar	Devi Nagar	11KV	Sainikpuri	00.45	01.25	00.40		11Kv Pin Insulator failed at Sitharam Nagar (AE/OP)	No
6		Mallapur	Noma	11KV	Habsiguda	16.30	17.50	01.20		11KV Pin Insulator failed at Jinuarm Colony	No
7		Nagaram	S.N Colony	11KV	Keesara	19:17	20:47	1:30		11KV AB Switch sparked at Rampally 'X' Road	No
1	HYD N	Seethaphalmandi	Namal Gundu	11KV	Sec'bad	10.35	11.50	01.15	EL,OL-Rph	AB Cable fault at Anna Nagar (DTR Kept off)	No
2		Clock Tower	Sangeeth	11KV	Sec'bad	14:02	15:25	1:23	All Indication	Disc Insulator falsh over at BPL & HT Jumper cut at Millennium Church	No
3		Chilkaigua	Pragatools	11KV	Sec'bad	19:00	21:30	2:30	EL,OL-Rph	Cable fault at Musheerabad X Road	Arranged B/F on 11KV C.C.Nagar fdr
4		Road No.13	Gowri Shanker Nagar	11KV	Jublee Hills	1:50	3:18	1:28	EL,OL	Tree branches fallen on lines at Gowri Shanker Nagar	No
1	HYD C	Golconda	Narayanamma College	11KV	Mehdipatnam	07.40	09.40	02.00	EL	Pin Insulator flash over at Sri Nidhi Apts	No
2		S.D Hospital	Khadi Bhandar	11KV	Mehdipatnam	09.05	10.26	01.21	EL,OL-Bph	Pin Insulator flash over at behind Cha Cha Nehru Park	No
3		S.D Hospital	Ahmed Nagar OH	11KV	Mehdipatnam	11.02	12.45	01.43	EL,OL-Bph	Bird fault on lines at S.D Hospital Qrts	No