

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		6		6		6			
6	RR(N)	54	550	1	16	1	16	1	16			
7	RR(E)	168	403		8		8		8			
8	Hyd	194	1044		11		11		11			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>1</b>	<b>41</b>	<b>1</b>	<b>41</b>	<b>1</b>	<b>41</b>	<b>0</b>	<b>0</b>	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	2	5	2	5	2	5			
2	NLG	144	988		18		18		18			
3	MDK	107	933									
4	SDPT				18		18		18			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>2</b>	<b>41</b>	<b>2</b>	<b>41</b>	<b>2</b>	<b>41</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>3</b>	<b>82</b>	<b>3</b>	<b>82</b>	<b>3</b>	<b>82</b>	<b>0</b>	<b>0</b>	

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Pollepally	Vallur	11KV	Jadcherla	01.00	09.00	08.00		11 kv wire cut near vallur (v)	-
2		Pollepally	Udandapur	11KV	Jadcherla	05.30	12.30	07.00		Tree fallen on 11 kv near Kistaram (v)	-
3		Udityal	Udityal	11KV	Jadcherla	00.52	06.18	05.26		Tree fallen on 11 kv near Adivi bavulu at udityal (v)	-
4		Nawapet	Lokirev	11KV	Jadcherla	11.00	13.00	02.00		11 kv insulator fail near lokirev (v)	-
5		Nawapet	Rudraram	11KV	Jadcherla	05.30	07.30	02.00		11 kv disk fail near Rudraram (v)	-
1	NLG	Nandanam®	Nagireedy pally	11KV	Bhongir	02.00	07.30	05.30	E/L	Heavy Gale & Wind 2 no's 11kv Insulator Failed near Errambally (V)	-
2		Motakondur	Vartoor	11KV	Bhongir	19.00	20.45	01.45	E/L	Heavy Gale & Wind 11Kv Disc Failed Near otore (V)	-
3		Mukundapuram	Mamailla Madava	11KV	Suryapet	06.00	07.25	01.25	E/L	11Kv Jumper cut	-
4		Nadigudem	Brundavanapuram	11KV	Huzurnagar	05.10	07.40	02.30	E/L	11Kv Insulator failure	-
5		Siripuram	Vallapuram	11KV	Huzurnagar	03.30	06.45	03.15	E/L	11Kv Disk failed	-
6		Mukundapuram	Dacharam	11KV	Huzurnagar	03.00	06.00	03.00	E/L	11Kv jumper cut	-
7		Damarcherla	Damarcherla Agl	11KV	Miryalaguda	06.00	11.00	05.00	E/L	11Kv Insulator failure	-
8		A.D.Pally	Veerlapalem	11KV	Miryalaguda	10.00	14.00	04.00	E/L	11Kv Insulator failure	-
9		Haliy	Ibrahimpeta	11KV	Miryalaguda	07.00	11.00	04.00	E/L	11Kv Insulator failure	-
10		Laxmidivigudem	Ravulapenta	11KV	Miryalaguda	06.00	11.00	05.00	E/L	11Kv Insulator failure	-
11		Aitipamula	R.C.Puram	11KV	Nalgonda	01.35	07.15	05.40	E/L	11 KV Jumper Cut	-
12		Eduloor	Munukuntla	11KV	Nalgonda	09.30	11.40	02.10	E/L	11 KV Jumpe Cut at Munukuntla	-
13		Eduloor	G.B.Gudem	11KV	Nalgonda	08.20	11.18	02.58	E/L	11 KV Jumpe Cut at G.B.Gudem (V)	-
14		Thurkapally	Thurkapally	11KV	Nalgonda	06.53	09.40	02.47	E/L	HT/LT Line Melt at Thurkapally	-
15		Palivela	Palivela	11KV	Nalgonda	07.30	11.40	04.10	O/L	11 KV Jumpe Cut at Palivela (V)	-
16		Thipparthi	Indloor	11KV	Nalgonda	06.30	11.10	04.40	E/L	11 KV Line Insulator Failed	-
17		Thipparthi	G.G.Palem	11KV	Nalgonda	06.30	12.10	05.40	E/L	11 KV Line Insulator Failed	-
18		Rajupeta	Jonnagaddalagudem	11KV	Nalgonda	06.00	10.00	04.00	E/L	11 KV Jumper Cut	-
1	SDPT	KATKUR	KATKUR EXPRESS	11KV	SDPT	01.10	06.00	04.50		BREAK DOWN	-
2		KATKUR	RAMAVARAM & MALLARAM	11KV	SDPT	02.30	08.20	05.50		BREAK DOWN	-
3		KATKUR	KANNARAM	11KV	SDPT	04.10	11.20	07.10		BREAK DOWN	-
4		BEJJANKI	BEJJANKI & RWS	11KV	SDPT	14.00	16.30	02.30		BREAK DOWN	-
5		REGULAPALLY	REGULAPALLY	11KV	SDPT	09.08	10.50	01.42		BREAK DOWN	-
6		REGULAPALLY	MALLAMCHERUVU	11KV	SDPT	08.44	10.44	02.00		BREAK DOWN	-
7		Guruvannapet	Posanpally	11KV	SDPT	01.40	04.15	02.35		BREAK DOWN	-
8		Komuravelly	Komuravell 24 Hrs	11KV	SDPT	00.00	06.15	06.15		BREAK DOWN	-
9		Komuravelly	Inapur + Posanpally + Inapur 24 hrs	11KV	SDPT	06.30	10.30	04.00		BREAK DOWN	-
10		Bekkal	Bairanpally	11KV	SDPT	01.50	09.00	07.10		BREAK DOWN	-
11		Bekkal		11KV	SDPT	10.30	11.15	00.45		ISF	-
12		Bekkal	Thornala	11KV	SDPT	10.30	11.15	00.45		ISF	-
13		Bekkal	Kutigal	11KV	SDPT	10.30	11.15	00.45		ISF	-
14		Bekkal	Kondapur	11KV	SDPT	10.30	11.15	00.45		ISF	-
15		Rebarthy	Maddur	11KV	SDPT	03.25	08.25	05.00		BREAK DOWN	-
16		Rebarthy	Gagillapur Agl	11KV	SDPT	12.00	21.59	09.59		BREAK DOWN	-
17		Marmamula	Marmamula	11KV	SDPT	10.35	12.40	02.05		BREAK DOWN	-
18		Marmamula	Marmamula	11KV	SDPT	14.00	16.43	02.43		BREAK DOWN	-
1	RR S	Upparpally	RTA Office	11KV	RJNR	08.30	09.30	01.00	B/D	Treebranches Fallen on 11kv Line at Ganesh Nagar	-
2		NPA	Hasan nagar	11KV	RJNR	03.55	04.50	00.55	B/D	11kv insulator Failed at necklace road	-
3		Rajendranagar	Upparpally	11KV	RJNR	04.15	05.38	01.23	B/D	11kv Cable Failed at dairy form	-
4		Chanda Nagar	Mythri Nagar	11KV	GCB	09.40	11.00	01.20	B/D	Tree branches fallen on the 11kv Line at Reddy's School, Madinaguda	-
5		Gachibowli	Apama	11KV	GCB	23.20	01.50	02.30	B/D	1)11kv Pin-insulator failed at Nallagandla huda, Ratnadeep Super market 2)11kv Pin-insulator failed at Aditya Building (Backfeeding from Papireddy Colony Sub-Station)	-
6		IJM	9th Phase	11KV	KONDAPUR	00.46	02.01	01.15	B/D	11kv Disk failed at Srujana mall backside, 9th Phase	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	RR N	Vemana Colony	friends colony	11KV	Kukatpally	06.50	08.00	01.10	EL/OL	Ground Petroling No fault	-
2		Vemana Colony	friends colony	11KV	Kukatpally	11.35	12.30	00.55	EL/OL	11kvpin Insulator failure At satya Enclave	
3		Jeedimetla SS IV	BhagyLaxmi	11KV	Jeedimetla	00.51	02.10	01.19	EL/OL	Ground Petroling ( No Fault	
4		Jeedimetla SS V	Jagadambha	11KV	Jeedimetla	02.30	03.40	01.10	EL/OL	Tree Branches fallen On the 11KV Line at jagadabha industrie)	
5		Aleap	Punchatvati	11KV	Jeedimetla	14.00	16.00	02.00	EL/OL	11kv Conductor Snapped At Pt No 467 Apuroopa Colony	
6		Jeedimetla SS I	Su-drugs	11KV	Jeedimetla	05.45	06.45	01.00	EL/OL	11kv AB cable failure At Su-Drugs company	
7		Subhash nagar	Jeedimetla	11KV	Medchal	23.30	00.30	01.00	BD	11KV PinInsulator failed at Dandamudi Enclve	
8		Subhash nagar	Jayaram Nagar	11KV	Medchal	00.30	01.10	00.40	BD	Tree fallen on the 11KV Line at Jayaram nagar & 11KV Disc failed at Gayatri nagar	
9		UMCC	Mini Industry	11KV	Medchal	03.30	05.10	01.40	BD	11KV UG Cable failed at Indhra nagar (Back Feeding from 11KV HAL Colony & Sriram nagar feeder)	
10		UMCC	Mahadevpuram	11KV	Medchal	05.15	06.30	01.15	BD	11KV Disc failed at Kailasa hills	
11		UMCC	HAL Colony	11KV	Medchal	05.15	06.15	01.00	BD	11KV Pin Insulator failed at HAL Colony	
12		Laxmapur	MC Pally	11KV	Medchal	05.30	07.30	02.00	BD	No Fault ( Due to heavy wind & rain )	-
13		Laxmapur	Narayanapur	11KV	Medchal	05.30	07.30	02.00	BD	No Fault ( Due to heavy wind & rain )	-
14		Thurkapally	Thurkapally	11KV	Medchal	06.15	09.05	02.50	BD	11KV Pin Insulator at Prajay Water Plant	-
15		Aliabad	LGM Pet	11KV	Medchal	10.00	11.30	01.30	BD	11KV HG Fuse Insulator Failed at LGM pet Village	-
16		Kandlakoya	KV Reddy Nagar	11KV	Medchal	02.05	05.30	03.25	BD	Tree fallan on the 11KV Line at Prestage park	-
1	RR E	Vasanthapuri	Ganesh Temple	11KV	Sainikpuri	23.50	01.07	01.17		11Kv Pin Insulator failed at Sai Mithra Apt (LM Raj Shekar)	-
2		Sainikpuri	Defence Colony	11KV	Sainikpuri	00.50	01.48	00.58		Tree fallen on 11Kv line at SBO Colony FOC James)	-
3		IDA Uppal	Metro	11KV	Uppal	04.20	05.19	00.59		Tree fallen on 11kv line near Vodafone Company Opposite	-
4		Chakripuram	Shilpa Nagar	11KV	Keesar	00.45	02.25	01.40		Larry dashed to 11Kv pole at SN Colony	-
5		Aushapur	Madharam	11KV	Keesar	07.00	09.00	02.00		11KV Jumper cut at Madharam	-
6		Singapur	RGK	11KV	Keesar	01.00	03.30	02.30		11KV Disc failed at RGK-34 & 46 Block	-
7		Singapur	RGK	11KV	Keesar	12.00	13.00	01.00		11KV Disc failed at NTPC Backside	-
8		P&T Colony	Canara Nagar	11KV	Keesar	06.30	07.20	00.50		11KV Disc failed near Orange Super Market	-
1	HYD N	Osm. University	Keshava Nagar	11KV	V	02.50	05.20	02.30	OL-Rph	11KV Disc Insulators flash over & tree branches fallen on lines at Keshava Nagar	
1	HYD S	Karwan	Karwan	11KV	IX	00.10	01.45	01.35	All Indication	Cable fault at Opp: SS	Arranged B/F on 11KV Ganga Nagar feeder
2		Womens College	Ganesh Temple	11KV	IX	00.22	01.32	01.10	EL,OL-Rph	No Visible Fault	----
3		Vittalwadi	Ram Koti	11KV	IX	01.28	03.14	01.46	All Indication	No Visible Fault	Arranged B/F on 11KV Gayatri Hotel feeder
4		Sulthan Bazar	Sulthan Bazar	11KV	IX	01.33	03.30	01.57	OL-Bph	Insulator flash over at Sultan Bazar FOC	----
5		Aliyabad	Police Quarters	11KV	III	11.55	13.08	01.13	EL	3Way R.M.U Cable End Kit failed at Laldarwaza	----
1	HYD C	Vittalwadi	Y.M.C.A	11KV	II	01.30	03.30	02.00	All Indication	No Visible Fault	Arranged B/F on 11KV Preventive medicine feeder
2		Nampally	Amba Hospital	11KV	VII	01.56	03.30	01.34	EL	Disc Insulator flash over at vii School & tree branches fallen on lines at Hill Top Development	----
3		Karwan	Langer House Cable	11KV	VII	02.50	07.15	04.25	OL-Rph	Disc Insulator flash over & Cable fault at Langer House Cable	----
4		Toli Chowki	Hakeemsha	11KV	VII	05.15	07.50	02.35	EL,OL	Cable fault at Reliance Mart	Arranged B/F on 11KV Brindavan Colony feeder
5		Asif Nagar	Market Yard	11KV	VII	05.32	07.25	01.53	EL	Tree branches fallen on lines at Market Yard	----

## TSSPDCL - LMRC / Corporate office

Date: 12.08.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Wanaparthi	Revally	33KV	Wanaparthi	04.50	12.20	07.30	E/L	Insulator Flash Over at SS Back Side	Revally	-
2		Achampet	Amrabad	33KV	Nagarkurnool	03.20	06.30	03.10	E/L	Isolator Opened & Supply Stood OK	Amrabad	-
1	RR N	132KV LGM Pet	33KV LGM Pet	33KV	Medchal	02.25	04.46	02.21	BD	33KV Pin Insulator failed at Monsanto Company	33KV LGM Pet	-