

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403		2		2		2			
8	Hyd	194	1044		1		1		1			
	Total	606	3055	0	4	0	4	0	4	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988	1	6	1	6	1	6			
3	MDK	107	933	1	2	1	2	1	2			
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	2	8	2	8	2	8	0	0	
	Grand Total	1082	6468	2	12	2	12	2	12	0	0	

TSSPDCL - LMRC / Corporate office

Date: 15.08.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	NLG	Miryalaguda	Tripuraram	33KV	Miryalaguda	08.45	12.10	03.25	E/L	1No. String Insulator faied	Tripuraram	-
1	MDK	Kowdipally	Ch.Ghanpur	33KV	Medak	15.30	16.45	01.15		BD due to Disk failed	Ch.Ghanpur	-

TSSPDCL - LMRC / Corporate office

Date: 15.08.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Cherkupally	Tungaturthy	11KV	Nalgonda	08.47	10.50	02.03	E/L	11KV Insulator failed at SS-4	-
2		Rajupeta	Bandavarigudem	11KV	Nalgonda	07.40	11.20	03.40	E/L	11KV Insulator failed at SS-1	-
3		Pamanagundla	Yerrasanigudem	11KV	Nalgonda	06.50	11.05	04.15	E/L	11KV line cut at village end	-
4		Kudakuda	Iylapuram	11KV	Suryapet	11.30	13.50	02.20	E/L	11Kv Insulator failed	-
5		Dirsincherla	Somaram	11KV	Huzurnagar	05.00	08.15	03.15	E/L	11Kv Disk Failed	-
6		Janpahad	Janpahad	11KV	Huzurnagar	15.40	17.00	01.20	E/L	11Kv line cut	-
1	MDK	Gaddapotharam - I	SMS	11KV	Patancheru	02.00	03.15	01.15		BD due to Tree fallen on line	-
2		Gummadidala	Bell Remedies	11KV	Patancheru	02.05	09.05	07.00		BD due to Tree fallen on line & Insulator failed	-
1	RR N	Shameerpet	Thumkunta	11KV	Medchal	12.45	14.15	01.30	BD	Tree Fallen on the 11KV Line at Domas	-
1	RR E	Moula-Ali	Moula-Ali	11KV	SKP	08.20	09.35	01.15		11Kv kumper cut at Andal Nagar (L.Insp Venkateshwarulu)	-
2		NN Colony	Yella Reddy Guda	11KV	SKP	03.10	03.55	00.45		11Kv Pin Insulator failed at Yella Reddy Guda (AE)	-
1	HYD N	Macha Bollaram	Ayyappa Nagar	11KV	C-VI	01.55	03.20	01.25	EL,OL	Pin Insulator flash over at Alwal Pump House	-