

Status Report on Breakdowns (Urban / Rural)  
Urban

S.No	Circle	No.of Feeders Existing Urban						Breakdowns occurred during the daAttended during the day				Time taken for restoring the supply		Remarks (Pending)	
		33KV	11KV	33KV	11KV	33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)	Not Rectified (Above 24 Hours)		
1	MBN		18	107											
2	NLG		22	358											
3	MDK														
4	SDPT		97	359											
5	RR(S)		53	234			5		5			5			
6	RR(N)		54	550			12		12			12			
7	RR(E)		168	403			15		15			15			
8	Hyd		194	1044			4		4			4			
	Total		606	3055	0		36	0	36	0		36	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals						Breakdowns occurred during the daAttended during the day				Time taken for restoring the supply		Remarks (Pending)	
		33KV	11KV	33KV	11KV	33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)	Not Rectified (Above 24 Hours)		
1	MBN		107	849	2		3		2			3			
2	NLG		144	988	1		5		1			5			
3	MDK				1		15		1			15			
4	SDPT		107	933	1		4		1			4			
5	RR(S)		58	396											
6	RR(N)		38	114											
7	RR(E)		22	133											
	Total		476	3413	5		27	5	27	5		27	0	0	
	Grand Total		1082	6468	5		63	5	63	5		63	0	0	

TSSPDCL - LMRC / Corporate office

Date: 16.08.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Balanagar	Amith Cotton Mill	33KV	Rajapur	15.15	16.50	01.35	E/L&O/L	Jumpers Opened at Amith Cotton Industry	Balanagar	-
2		Maddur	Pallerla	33KV	Narayanapet	14.05	16.35	02.30	E/L	Due to Rain Jumpers Opened towards Dorepally	Maddur	-
1	NLG	Mothkur	Kapraipally	33KV	Bhongir	05.00	08.00	03.00	E/L	Pole no 63 1no Insulator Failed & Pole no 120 1no Insulator Failed Alternat Suply Tekan in Athmakur ss	Mothkur	-
1	MDK	Gummadidala	AFA	33KV	Patancheru	4:55	15:30	10:35		BD Due to Y PHASE B PHASE LIMBS BLAST ALONG WITH PTRS PULL OUT	Gummadidala	-
1	SDPT	THUNIKIBOLLARAM	SEETHARAMPALLY	33KV	Gajwel	23:15	10:55	11:40		DUE TO DISK FAILURE	THUNIKIBOLLARAM	

## TSSPDCL - LMRC / Corporate office

Date: 16.08.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Ponnakal	Rachala	11KV	Jadcherla	03.00	06.00	03.00		11KV Wire Cut Near Rachala	-
2		Bhoothpur	Bhoothpur(T)	11KV	Jadcherla	06.00	10.00	04.00		11KV Disc Fail Near Bhoothpur	-
3		Gangapur	Gangapur	11KV	Jadcherla	13.30	16.30	03.00		11KV Insulator Failed Near Gangapur	-
1	NLG	Aregudem	Chinnakaparth	11KV	Nalgonda	12.40	15.35	02.55	E/L	11KV lineInsulator Failure	-
2		Disenapally	Miryala	11KV	Suryapet	04.30	08.00	03.30	E/L	Insulator & Disc Flashover	-
3		Mattapally	Ramachandhrapuram	11KV	Huzurnagar	07.54	09.05	01.07	E/L	Due to 11Kv jumper cutted	-
4		Ananthagiri	Kistapuram	11KV	Huzurnagar	07.30	10.30	03.00	E/L	Due to Bird fall on 11Kv line	-
5		Rajapeat	Pamkunta	11KV	Bhongir	04.00	08.00	04.00	E/L	11Kv Line Sanpped & Tree Branches Fallne in Bolle Gudeam Vilage Near	-
1	MDK	Thogita	H.Ghanpur	11KV	Medak	13:00	16:00	3:00		B/D due to insulator faile.	-
2		B.B.Pur	B.B.Pur	11KV	Medak	0:30	12:25	11:55		B/D due to Tree branch fallan on the line.	-
3		Gavvalapally	Madur	11KV	Medak	7:55	12:38	4:43		B/D due to 11KV Insulator faile.	-
4		Narsapur	Reddypally	11KV	Medak	4:00	9:00	5:00		B/D Due to Tree fallan on the Conductor.	-
5		Moosapet	Nagulapally	11KV	Medak	13:40	16:10	2:30		B/D due to 11Kv insulator faile.	-
6		Kowdipally	Devulapally	11KV	Medak	3:00	8:10	5:10		B/D due to Insulator faile and line snapped	-
7		Kowdipally	Mohd Nagar	11KV	Medak	4:00	10:00	6:00		B/D due to Insulator faile.	-
8		Gangaram	Gangaram	11KV	Medak	6:00	9:00	3:00		B/D Due to insulator faile.	-
9		Podchanpally	Podchanpally-II	11KV	Medak	13:20	15:30	2:10		B/D due to 11Kv insulator faile.	-
10		Gandharpally	Gandharpally	11KV	Medak	12:40	15:38	2:58		B/D due to insulator faile.	-
11		Alladurg	Rampur	11KV	Medak	12:00	16:30	4:30		B/D due to Condtr Snapped.	-
12		SANGAREDDY-I	FASALWADI	11KV	SANGAREDDY	6:45	17:30	10:45		B/D due to Condtr Snapped.	-
13		CHERYAL	JULKAL	11KV	SANGAREDDY	11:10	15:43	4:33		B/D DUE TO TREE FALLEN ON THE LINE	-
14		CHERYAL	KANDI	11KV	SANGAREDDY	14:30	18:00	3:30		B/D DUE TO POLE FALLEN ON THE GROUND	-
15		CHERYAL	KALIVEMULA	11KV	SANGAREDDY	14:30	15:00	0:30		B/D DUE TO RAIN FALL	-
1	SDPT	KATKUR	MALLAPUR	11KV	Siddipet	5:00	11:00	6:00		LINE SNAPPED SAME RECTIFAIED	-
2		KOHEDA	THEGALAGUNTAPA	11KV	Siddipet	10:45	12:18	1:33		JUMPER BREAK SAME RECTIFAIED	-
3		GURUVANNAPET	POSANPALLI	11KV	Siddipet	5:05	9:05	4:00		11 KV DISC FAILUERE SAME RECTIFAIED	-
4		GURUVANNAPET	GURUVANNAPET	11KV	Siddipet	5:10	6:10	1:00		LINE SNAPPED SAME RECTIFAIED	-
1	RR S	Uppar pally-II	Parmareddy hills	11KV	RJNR	19:01	20:06	1:05	B/D	11KV Insulator failed at 315 KVA DTR Jalababnagar	-
2		Ibrahimbagh	Peddamangalram (IBGH)	11KV	RJNR	14:56	15:58	1:02	B/D	11KV Insulator replaced at Madhavi nagar	-
3		JNTU	B.S.Nagar	11KV	GCB	0:05	1:15	1:10	B/D	11kv DTR ABS Sparked at Plot NO.821 at B.S. Nagar (LABS Opened at B.S.Nagar)	-
4		Mathrusri Nagar	Vishwambara	11KV	GCB	0:00	1:30	1:30	B/D	11kv Disk failed at Shilpa Avenue, Vishwambara	-
5		Mathrusri Nagar	Mathrusri Nagar	11KV	GCB	3:00	4:20	1:20	B/D	11kv Pin-insulator failed at Plot NO.952, Mathrusri Nagar	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	RR N	Madinaguda	Pragathinagar	11KV	Kukatpally	0:35	2:05	1:30	EL/OL	Ground petroling No Fault	-
2		Madinaguda	Widiyo Colony	11KV	Kukatpally	4:20	5:27	1:07	EL/OL	11kv Jumper cut touched channel Near Sub station	-
3		Madinaguda	Reddy Labs	11KV	Kukatpally	0:38	10:40	10:02	EL	11kv AB Cable end kit failure near sub station	-
4		Nizampet	Srinivasa Colony	11KV	Kukatpally	2:45	4:35	1:50	EL/OL	11kv Pin Insultor Failed &11kv Endy Kit Failure at Chatanya Collage	-
5		Jeedimetla-IV	Axies	11KV	Jeedimetla	2:55	4:40	1:45	EL/OL	Ground petroling NO fault	-
6		Jeedimetla-III	U S P Organic	11KV	Jeedimetla	13:35	15:35	2:00	EL/OL	11kv AB cable failure at phase V	-
7		Pudur	Munirabad	11KV	Medchal	3:10	4:50	1:40		11KV Pin Insulator failed at Munirabad Village	-
8		Shameerpet	Nalsar	11KV	Medchal	2:10	3:15	1:05		11KV Pin Insulator failed at Shameerpet Village	-
9		Thurkapally	Yadaram	11KV	Medchal	0:00	3:30	3:30		Lizard fallen on the 11KV Line at Thurkapally Thanda	-
10		Laxmapur	MC Pally	11KV	Medchal	7:15	8:15	1:00		11KV Pin Insulator failed at Lingapur Thanda	-
11		Gowdavelly	Basaragadi	11KV	Medchal	8:00	9:15	1:15		Bird fallen on the 11KV Line at Gowdavelly X Road	-
12		Laxmapur	IDA Laxmapur	11KV	Medchal	11:50	13:10	1:20		Tree fallen on the 11KV Line at Durgamma Temple	-
1	RR E	NGRI	HMT Nagar	11KV	Habsiguda	1:30	3:00	1:30		11KV Cable failed near SS Yard due to Water Pipe line works	-
2		IICT	Nacharam	11KV	Habsiguda	2:30	5:30	3:00		11KV Insulator failed near Indhra School	-
3		Uppal	Aradsha Nagar	11KV	Habsiguda	1:50	3:20	1:30		Flexi fallen on 11kv line near Srinivasa Heights	-
4		Nacharam	Chandamama	11KV	Habsiguda	9:39	10:35	0:56		11KV Jumper cut at Road No.10 and 11KV 3Nos HG Fuse failed near Rac Kam Company at IDA Nacharam	-
5		Sainikpuri	Saipuri	11KV	Sainikpuri	2:15	2:45	0:30		Tre branches fallen on 11Kv line at Hasthinapuri Colony (Foc James)	-
6		Saketh	Pranam	11KV	Sainikpuri	23:52	0:50	0:58		Tripped on EL 11Kv Insulator failed at Saketh Phase-II (due to AB Switch Open LM Mallesh)	-
7		RGK	Kowkooor	11KV	Sainikpuri	3:00	4:15	1:15		Tree branches fallen on 11Kv line at Kumma Basthi (Foc Abbu/Srinu)	-
8		Kushaiguda	AS Rao Nagar	11KV	Sainikpuri	5:10	5:40	0:30		11Kv Disk failure at AS Rao Nagar (AE/AS Rao Nagar)	-
9		NN Colony	Bhavanarushi	11KV	Sainikpuri	21:10	22:50	1:40		11kv Line Cut at Main Road Saibaba Nagar and 11kv Jumper Cut at Sairam Nagar	-
10		Chakripuram	SV Nagar	11KV	Keesara	4:15	5:00	0:45		Tree branches touched to 11kv line at SV Nagar Road No.03	-
11		Aushapur	Madharam	11KV	Keesara	1:30	9:00	7:30		11KV Polymer Disc failed at Madharam	-
12		Singapur	IT Park	11KV	Keesara	16:25	17:25	1:00		11KV Disc failed near Double Bed Room Quarters near Infosys	-
13		P&T Colony	Canara Nagar	11KV	Keesara	1:50	4:15	2:25		11KV Disc failed at Budda Nagar	-
14		CRPF	Chennapur	11KV	Keesara	14:20	16:10	1:50		Line patrolling but no visible fault	-
15		Rampally Dayara	Vanneguda Indl	11KV	Keesara	7:40	8:20	0:40		HT Jumper cut near Sathi Reddy Crusher	-
1	HYD S	Miralam	Jahanuma	11KV	Charminar	0:50	2:20	1:30	EL	insulators flash over at Ayub Industry & Hakimsha	-
1	HYD C	Zamistanpur	Balaji Nagar	11KV	Azamabad	2:24	4:30	2:06	EL	Cable fault at Amber Nagar Katta	Arranged B/F on 11KV L.N.Nagar & Jamai Osmania feeders
2		Bathkammakunta	D.D.Colony	11KV	Azamabad	12:05	13:20	1:15	OL-Rph	Pin Insulator flash over at Justice Meena Kumari House	-
3		S.D Hospital	Ahmed Nagar Cable	11KV	Bowenpally	15:10	17:05	1:55	EL	Breaker problem at SS	Arranged B/F on 11KV Military fdr