

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		16		16		16			
7	RR(E)	168	403		4		4		4			
8	Hyd	194	1044		7		7		7			
	Total	606	3055	0	27	0	27	0	27	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1	1	1	1	1	1			
2	NLG	144	988	10	23	10	23	10	23			
3	MDK	107	933	2	4	2	4	2	4			
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	13	28	13	28	13	28	0	0	
	Grand Total	1082	6468	13	55	13	55	13	55	0	0	

TSSPDCL - LMRC / Corporate office

Date: 20.08.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Kothamolgara	L&T	11KV	Jadcherla	21.30	09.50	12.20		11 KV Insulator failure Near Paper Mill Side And 11 KV Disc Failure Near Seeds Company Side. At Kothamolgara.	-
1	NLG	Penpahad	SR Paalem	11KV	Suryapet	06.05	07.40	01.35	E/L	Insulator flashover	-
2		Reddygudem	Kothagudem	11KV	Suryapet	03.30	07.00	03.30	E/L	Conductor snapped	-
3		G.T Giri	Thirumala giri	11KV	Suryapet	03.10	06.50	03.40	E/L	Disc flashover	
4		R.C.puram	R.C.Puram	11KV	Suryapet	04.30	07.30	03.00	E/L	Insulator flashover	
5		Nuthankal	Yelkapally	11KV	Suryapet	06.05	08.55	02.50	E/L	Line Melt	
6		Nagaram	Wardhamanu kota	11KV	Suryapet	07.30	10.00	02.30	E/L	Jumper cut	
7		Palakeedu	Nagireddygudem	11KV	Huzurnagar	05.20	09.00	03.40	EL/OL	Insulator failed	
8		Gaddipally	Ponugodu	11KV	Huzurnagar	03.40	06.30	02.50	EL	HT/LT Touched	
9		Kandibanda	Gandinagar thanda	11KV	Huzurnagar	04.35	07.35	03.00	EL	11 KV INSULATOR Failed	
10		Munagala	Barakathgudem	11KV	Huzurnagar	00.00	01.30	01.30	EL	11 kv line snapped	
11		Mamidala	Mamidala	11KV	Nalgonda	05.00	13.00	08.00	E/L	11 KV Jumper Cut at Mamidala (V)	
12		Madgulapally	Dacharam	11KV	Nalgonda	11.40	14.20	02.40	E/L	11 KV Line Insulator Failed	
13		Rayanguda	G.Kondaram	11KV	Nalgonda	14.40	16.20	01.40	E/L	11 KV Jumper Cut	
14		Pullemla	Pullemla AGL	11KV	Nalgonda	08.00	12.10	04.10	E/L	11 KV Line Insulator Failed	
15		Nakrekal	Chandupatla	11KV	Nalgonda	12.10	16.00	12.10	E/L	11 KV Jumper Cut	
16		Narketpally	M.Yedavally	11KV	Nalgonda	07.40	11.30	12.10	E/L	11 KV Jumper Cut	
17	Tukkapur	Gousenagar	11KV	Bhongir	03.30	13.30	10.00	EL	11 kv 1 No pole damaged near gouse nagar village		
18	Kolanupaka	Kolanpaka Town	11KV	Bhongir	01.35	06.45	05.10	EL	HT/LT Near kolanupaka village near petrol bunk		
19	Raghunathpur	Challuru	11KV	Bhongir	05.15	11.00	05.45	EL	11kv disk failed near challuru village		
20	Bibinagar	Hidustan	11KV	Bhongir	01.45	06.20	04.35	EL	11kv insulator failed near Panchamuki temple bibinagar		
21	Kondamadugu	Anandagro Indus	11KV	Bhongir	04.30	08.30	04.00	EL	11kv disk failed near near Hanuman temple Kondamadugu village		
22	B.ramaram	Jalalpur	11KV	Bhongir	11.30	14.20	02.50	EL	11kv disk failed near Sc colony , B.ramaram village		
23	B.ramaram	Saiteja	11KV	Bhongir	11.25	13.50	02.25	EL	11kv insulator failed near Raghavapuram village		
1	MDK	ISNAPUR	IDEA-RUDRARAM	11KV	Sangareddy	04.04	07.54	03.50		B/D DUE TO 11KV DISK failure.	-
2		FASALWADI	MNR	11KV	Sangareddy	01.52	04.50	02.58		B/D DUE TO INSULATOR FAIL AT MNR 'X' ROAD	-
3		CHERYAL	KALIVEMULA	11KV	Sangareddy	04.00	09.00	05.00		B/D DUE TO 11KV LINE JUMPER CUT AT KALIVEMULA AGL	-
4		Gummadidala	Agrobell	11KV	Patancheru	08.20	10.20	02.00		B/D due to Disk failure.	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	RR N	J T P L	P N R hills	11KV	Kukatpally	02.10	03.20	01.10	EL/OL	11kv Pin Insulator Failure at Road 26 Pnr Hills	-
2		J T P L	K S R enclave	11KV	Kukatpally	02.00	05.30	03.30	EL/OL	11kv Pin Insulator Failure at Road 9 K S R Enclave	
3		Jeedimetla-II	ApuroopaColony	11KV	Jeedimetla	06.45	07.45	01.00	EL/OL	11kv Jumper Snapped At SRC Naik nagar	
4		Aleap	Doctors Colony	11KV	Jeedimetla	05.55	07.00	01.05	EL/OL	11kv pininsulator failure at plot:1075	
5		Suraram	Venkatram Nagar	11KV	Jeedimetla	01.06	04.16	03.10	EL	11kv pininsulator failure at Sainagar	
6		Kompally	Dholari Dhani	11KV	Medchal	17.00	17.45	00.45	No Fault		
7		Gowdavelly	IDA Gowdavelly	11KV	Medchal	04.00	06.55	02.55		11KV Line Cut & Replaced at Vibha Seeds, Gowdavelly X Road	
8		GP Pally	GP Pally	11KV	Medchal	13.50	16.30	02.40		Breaker Machanical Problem	
9		Pudur	Pudur	11KV	Medchal	07.15	09.15	02.00		2 Nos. 11KV Poles damaged at Sneha Farm	
10		Yellampet	IDA	11KV	Medchal	04.40	06.30	01.50		11KV Pin Insulator failed in SS	
11		Nuthankal	Oyster	11KV	Medchal	05.50	07.30	01.40		11KV Pin Insulator failed at Lingapur Road	
12		Gowdavelly	Ayodhya	11KV	Medchal	09.30	11.00	01.30		3 No. 11KV Poles damaged at Indiramma Colony	
13		Devarayamjal	Kottapet	11KV	Medchal	02.50	05.00	02.10		Tree Fallen on the 11KV Line at Devarayamjal Village	
14		Kolthur	Kolthur	11KV	Medchal	02.00	05.30	03.30		100KVA T/F failed at Jaganguda colony Road	-
15		ICICI	Bharathbiotech	11KV	Medchal	03.00	06.05	03.05		11KV Pin Insulator failed in SS	-
16		Laxmapur	Narayanapur	11KV	Medchal	10.30	13.10	02.40		11KV Pin Insulator Failed at Narayanpur Village	-
1	RR E	Moula-Ali	Gayatri Nagar	11KV	Sainikpuri	10.01	11.10	01.09		11Kv Disk failure at Andal nagar near Happy Homes (L.Insp Venkateshwarulu)	-
2		Kushaiguda	Kushaiguda	11KV	Sainikpuri	01.55	02.55	01.00		11Kv Post of Insuletor failure Kushaiguda Industry (AE/OP)	-
3		Kushaiguda	Sri Ram Nagar	11KV	Sainikpuri	12.00	15.50	03.50		11Kv Disk failure at Prasanth Nagar only 3 No Apartment DTR off at Break Down time (L.Insp Dhansi Ram)	-
4		Kushaiguda	Rukminipuri	11KV	Sainikpuri	23.20	23.50	00.30		11KV Pin Insulator failed at Adity Nagar	-
1	HYD C	Hyderguda	King Koti	11KV	I	02.10	03.50	01.40	EL	Insulator flash over beside King Koti Hospital	-----
2		Mothi Mahal	M.D Lines	11KV	VII	08.35	10.48	02.13	EL,OL-R&Bph	Pin Insulator flash over at Military Area	-----
3		Mothi Mahal	M.D Lines	11KV	VII	20.05	21.27	01.22	EL,OL-Bph	No Visible fault	Arranged B/F on 11KV Military Hospital fdr
4		Nampally	Nampally Hospital	11KV	VII	11.55	14.18	02.23	EL	HT Cable Jumper cut at Limra College	-----
5		Devi Bagh	Rama Talkies	11KV	III	13.15	14.45	01.30	EL,OL-Rph	Disc Insulator flash over at Kamatipura PS	-----
1	HYD N	Panjasha	Gulzarhouse	11KV	III	16.00	17.25	01.25	All Indication	2No. Pin Insulators flash over at Balala Complex	-----
1	HYD N	Madhapur	APIIC - I	11KV	X	06.45	09.00	02.15	EI,OL	Cable fault Opp. Rejaha	Arranged B/F on 11KV Infotech fdr

TSSPDCL - LMRC / Corporate office

Date: 20.08.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Polepally	Jadcherla	33KV	Jadcherla	00.05	02.10	02.05	E/L&O/L	Jumper cut near RPR Pipe Company	Jadcherla	-
1	NLG	Madgualaply	Buggabaigudem	33KV	Miryalaguda	17.00	17.35	00.35	E/L	220/33KV Miryalaguda Alternate supply arranged to 33Kv V.K.Phallem at 17:35	Buggabaigudem	-
2		Ramapuram	Mellacheruvu	33KV	Huzurnagar	03.00	06.50	03.50	EL/OL	33KV Insulator failed	Mellacheruvu	-
3		Dilshincherla	Keethavarigudem	33KV	Huzurnagar	05.00	08.30	03.30	EL/OL	33KV Disk failed	Keethavarigudem	
4		Kolanupaka	Sharajipeta	33KV	Bhongiri	04.25	08.40	04.15	EL/OL	Lighting arrest Flash over	Sharajipeta	
5		Kolanupaka	Kandukur	33KV	Bhongiri	03.35	04.00	00.25	E/L	Moment Fault	Kandukur	
6		Munagala	Nadigudem	33KV	Huzurnagar	04.20	04.30	00.10	E/L	Alternate supply	Nadigudem	
7		Bhongiri	M.R.Gudem	33KV	Bhongiri	01.25	08.25	07.00	E/L	33KV Disk failed	M.R.Gudem	
8		Suryapeta	Nemmikal	33KV	Suryapeta	22.40	06.50	08.10	E/L	Alternate from 07:00	Nemmikal	
9		Suryapeta	HPCL	33KV	Suryapeta	02.20	08.20	06.00	E/L	In yard clamp problem	HPCL	
10		Suryapeta	Sudhakar PVC	33KV	Suryapeta	06.25	08.25	02.00	E/L	Rectified	Sudhakar PVC	
1	MDK	Narayankhed	Sirgapur	33KV	Jogipet	00.30	02.30	02.00		BD due to Pin Insulator failed	Sirgapur	-
2		Sadashivapet	Koheer	33KV	Sangareddy	03.50	07.30	03.40		BD due to Insulator failure.	Koheer	-