

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403		2		2		2			
8	Hyd	194	1044		2		2		2			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>0</b>	<b>5</b>	<b>0</b>	<b>5</b>	<b>0</b>	<b>5</b>	<b>0</b>	<b>0</b>	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		2		2		2			
3	MDK	107	933									
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>0</b>	<b>2</b>	<b>0</b>	<b>2</b>	<b>0</b>	<b>2</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>0</b>	<b>7</b>	<b>0</b>	<b>7</b>	<b>0</b>	<b>7</b>	<b>0</b>	<b>0</b>	



TSSPDCL - LMRC / Corporate office

Date: 24.08.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Annaram	Annaram	11KV	Suryapet	14.50	16.30	01.40	E/L	11Kv Insulator failed	-
2		Eduloor	G.B.Gudem	11KV	Nalgonda	06.30	11.10	04.40	E/L	11KV Line Disc Failure	-
1	RR N	Nizampet	Journalist Colony	11KV	Kukatpally	02.40	04.00	01.20	OL	11kv line AB Cable failed at Road:9A, Bandari Lay-out	-
1	RR E	VP Nagar	Brundavani colony	11KV	SKP	16.25	17.30	01.05		11KV Line Snapad at Vp Nagar	-
2		MAllapur2	Ashok nagar	11KV	HBG	09.26	10.16	00.50		33kv Line cut & fallen on 11kv line at Ashok nagar	-
1	HYD N	NIMS	Rainbow	11KV	Banjarahills	23.20	03.08	03.48	All Indications	CT Bph heavy sparks & smokes at SS (No supply to 11KV Road No.1 partial fdr, due to B/F on 11KV Rainbow fdr	Arranged B/F on 11KV Road No.1 fdr
1	HYD C	Hyderguda	Hyderguda	11KV	Saifabad	00.50	01.55	01.05	EL,OL	DTR fault at Dadar India	-