

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		2		2		2			
7	RR(E)	168	403		2		2		2			
8	Hyd	194	1044		2		2		2			
	Total	606	3055	0	6	0	6	0	6	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		1		1		1			
2	NLG	144	988		6		6		6			
3	MDK	107	933		1		1		1			
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	8	0	8	0	8	0	0	
	Grand Total	1082	6468	0	14	0	14	0	14	0	0	

TSSPDCL - LMRC / Corporate office

Date: 29.08.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Janampet	Annasagar	11KV	Jadcherla	23.45	07.45	08.00		LT Wire Cut Near Ponnakal dhaba Side.	-
1	NLG	Cheedella	Thanigellagudem	11KV	Suryapeta	03.40	07.30	03.50	E/L	Conductor Snapped	-
2		Reddygudem	Kukkadam	11KV	Suryapeta	05.10	08.40	03.30	E/L	Conductor Snapped	-
3		Thurkapally	AJJalapuram	11KV	Nalgonda	07.00	09.20	02.20	E/L	Insulator failure	-
4		Urumadla	Elikatte	11KV	Nalgonda	03.00	06.00	03.00	E/L	Jumper cut	-
5		Amaravaram	Srinivasapuram	11KV	Huzurnagar	02.35	05.30	02.55	E/L	11KV Disk Failure	-
6		Mukundapuram	Somaram	11KV	Huzurnagar	08.00	10.45	02.45	E/L	11KV Jumper cut	-
1	MDK	Isnanpur	Kyasaram	11KV	Sangareddy	01.20	06.00	04.40		B/D due to Insulator failure near Kyasaram (V)	-
1	RR N	Gowdawelly	IDA Gowdavelly	11KV	Medchal	09.40	10.50	01.10		11KV Line Cut at HP Petrol Bunk, Basaragadi Village	-
2		Devarayamjal	Kottapet	11KV	Medchal	14.15	15.35	01.20		Tree fallen on the 11KV Line at Thurkoni Kunta, Devarayamjal	-
1	RR E	Moula ali	Gayatri Nagar	11KV	Sainikpuri	17.50	18.11	00.21		Lizard fallen on 11Kv line near A1 Resturant (L.Insp Venkateshwarulu)	-
2		Chengicherla	RTC	11KV	Keesara	10.35	11.25	00.50		11KV Jumper cut at RTC Colony Main Road	-
1	HYD C	Bathkammakunta	Saibaba Temple	11KV	II	13.22	14.30	01.08	OL-Rph	Brass Patti B/o at Park View Apts	-
2		Bathkammakunta	C.E.Colony	11KV	II	23.12	00.34	01.22	EL	Big tree fallen on Lines near Nanda Raj Goud PT	(23:28) Partial feeder Opened AB Switch at Nandaraj Goud PT