

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403		2		2		2			
8	Hyd	194	1044									
	Total	606	3055	0	3	0	3	0	3	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		7		7		7			
3	MDK	107	933									
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	7	0	7	0	7	0	0	
	Grand Total	1082	6468	0	10	0	10	0	10	0	0	

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Penpahad	Singireddy palem	11KV	Suryapet	7:30	10:00	2:30	E/L	Insulator failed	No
2		Munagala	Turkagudem	11KV	Huzurnagar	07.30	10.00	02.30	EL	11 KV Line snapped	No
3		Alingapuram	Gundlapahad	11KV	Huzurnagar	08.00	10.30	02.30	EL	11 KV Jumper cut	No
4		Raghunadapalem	Gundlapally	11KV	Huzurnagar	14.30	16.00	01.30	EL	11 KV Line snapped	No
5		Mukundapuram	Mukundapuram	11KV	Huzurnagar	15.20	17.00	01.40	EL	11 KV Line snapped	No
6		Urumadla	Elikatte	11KV	Nalgonda	06.30	11.20	04.50	EL	HT/LT Lines melt	No
7		Mushampally	Mushampally	11KV	Nalgonda	9:10	11:45	2:35	EL	11KV Line insulator failed	No
1	RR N	Shameerpet	Thumkunta	11KV	Medchal	8:50	10:05	1:15		11KV Brass Patti cut and replaced at Rambabu Poultry farm, Thumkunta	No
1	RR E	RGK	Barsipet	11KV	Sainikpuri	21:10	22:00	0:50		Bat fallen on 11KV line at near Modi Complex	No
2		Peerzathiguda	Uppal Hills	11KV	Keesara	07.20	08.16	00.56		Bird fallen on 160KVA DTR at Uppal Hills	No