

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403									
8	Hyd	194	1044		1		1		1			
	Total	606	3055	0	2	0	2	0	2	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		5		5		5			
3	MDK	107	933									
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	5	0	5	0	5	0	0	
	Grand Total	1082	6468	0	7	0	7	0	7	0	0	

TSSPDCL - LMRC / Corporate office

Date: 03.12.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Mattampally	Ramachandrapuram	11KV	Huzurnagar	03.30	06.30	03.00	E/L	11KV Line cut	-
2		Munagala	Turkagudem	11KV	Huzurnagar	14.10	15.45	01.35	E/L	11KV Jumper cut	-
3		Raghunadpalem	Gundlapally	11KV	Huzurnagar	06.35	09.40	03.05	E/L	11KV Jumper cut	-
4		Pamanagundla	Pittampally	11KV	Nalgonda	05.30	08.30	03.00	E/L	11KV Jumper cut	-
5		Urumadla	Yelikatte	11KV	Nalgonda	12.06	14.10	02.04	E/L	11KV Insulator failure	-
1	RR N	UMCC	Mahadevpuram	11KV	Medchal	01.15	01.55	00.40		11KV UG Cable Failed at Ramky group	-
1	HYD N	Road No.22	Obul Reddy	11KV	X	03.00	05.40	02.40	EL,OL-Yph	Cable fault at Road No.24	Partial fdr charged at 03:05Hrs, Remaining loads added on 11KV Road No.5 fdr