

Status Report on Breakdowns (Urban / Rural)

Urban

| S.No | Circle | No.of Feeders Existing Urban | | Breakdowns occurred during the day | | Attended during the day | | Time taken for restoring the supply | | | | Remarks (Pending) |
|------|--------------|------------------------------|-------------|------------------------------------|----------|-------------------------|----------|-------------------------------------|----------|--------------------------------|----------|-------------------|
| | | 33KV | 11KV | 33KV | 11KV | 33KV | 11KV | Rectified (Within 24 Hours) | | Not Rectified (Above 24 Hours) | | |
| | | | | | | | | 33KV | 11KV | 33KV | 11KV | |
| 1 | MBN | 18 | 107 | | | | | | | | | |
| 2 | NLG | 22 | 358 | | | | | | | | | |
| 3 | MDK | 97 | 359 | | | | | | | | | |
| 4 | SDPT | | | | | | | | | | | |
| 5 | RR(S) | 53 | 234 | | | | | | | | | |
| 6 | RR(N) | 54 | 550 | 1 | | 1 | | 1 | | | | |
| 7 | RR(E) | 168 | 403 | | | | | | | | | |
| 8 | Hyd | 194 | 1044 | | 1 | | 1 | | 1 | | | |
| | Total | 606 | 3055 | 1 | 1 | 1 | 1 | 1 | 1 | 0 | 0 | |

Rural

| S.No | Circle | No.of Feeders Existing Rurals | | Breakdowns occurred during the day | | Attended during the day | | Time taken for restoring the supply | | | | Remarks (Pending) |
|------|--------------------|-------------------------------|-------------|------------------------------------|----------|-------------------------|----------|-------------------------------------|----------|--------------------------------|----------|-------------------|
| | | 33KV | 11KV | 33KV | 11KV | 33KV | 11KV | Rectified (Within 24 Hours) | | Not Rectified (Above 24 Hours) | | |
| | | | | | | | | 33KV | 11KV | 33KV | 11KV | |
| 1 | MBN | 107 | 849 | | | | | | | | | |
| 2 | NLG | 144 | 988 | | 4 | | 4 | | 4 | | | |
| 3 | MDK | 107 | 933 | | | | | | | | | |
| 4 | SDPT | | | | | | | | | | | |
| 5 | RR(S) | 58 | 396 | | | | | | | | | |
| 6 | RR(N) | 38 | 114 | | | | | | | | | |
| 7 | RR(E) | 22 | 133 | | | | | | | | | |
| | Total | 476 | 3413 | 0 | 4 | 0 | 4 | 0 | 4 | 0 | 0 | |
| | Grand Total | 1082 | 6468 | 1 | 5 | 1 | 5 | 1 | 5 | 0 | 0 | |

TSSPDCL - LMRC / Corporate office

Date: 08.12.2018

| S.No | Circle | Name of 33/11KV SS | Name of 11 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Alternate Supply Arranged |
|------|--------|--------------------|----------------------|------|----------------------|-------|-------|----------|------------------|---|---------------------------|
| 1 | NLG | Mothkur | Aregudem | 11KV | Bhongiri | 05.00 | 08.00 | 03.00 | E/L | Jumper cut | - |
| 2 | | Raghunadpalem | Gundlapally | 11KV | Huzurnagar | 09.50 | 12.35 | 02.45 | E/L | Jumper cut | - |
| 3 | | Munagala | Munagala(T) | 11KV | Huzurnagar | 08.20 | 11.25 | 02.55 | E/L | Jumper cut | - |
| 4 | | Repala | Narasimhulagudem | 11KV | Huzurnagar | 11.40 | 13.30 | 01.50 | E/L | 11KV Line cut | - |
| 1 | RR N | 132KV Medchal | 33KV Keshavaram | 11KV | Medchal | 04.37 | 07.40 | 03.03 | BD | 33KV Jumper cut and replaced at Pudur Village | - |
| 1 | HYD S | Santosh Nagar | Moin Bagh | 11KV | Asmangadh | 16.35 | 17.45 | 01.10 | OL-R&Bph | Kite stick fault & O/G Jumper touching to Channel at SS | |

TSSPDCL - LMRC / Corporate office

Date: 08.12.2018

| S.No | Circle | Name of 132/33KV SS | Name of 33 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Sub Stations Effected | Alternate Supply Arranged |
|------|--------|---------------------|----------------------|------|----------------------|-------|-------|----------|------------------|---|-----------------------|---------------------------|
| 1 | RR N | 132KV Medchal | 33KV Keshavaram | 33KV | Medchal | 04.37 | 07.40 | 03.03 | BD | 33KV Jumper cut and replaced at Pudur Village | 33KV Keshavaram | - |