

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403		3		3		3			
8	Hyd	194	1044									
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>0</b>	<b>3</b>	<b>0</b>	<b>3</b>	<b>0</b>	<b>3</b>	<b>0</b>	<b>0</b>	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		3		3		3			
3	MDK	107	933		2		2		2			
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>0</b>	<b>5</b>	<b>0</b>	<b>5</b>	<b>0</b>	<b>5</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>0</b>	<b>8</b>	<b>0</b>	<b>8</b>	<b>0</b>	<b>8</b>	<b>0</b>	<b>0</b>	



TSSPDCL - LMRC / Corporate office

Date: 10.12.18

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Yerkaram	Dasthanda	11KV	Suryapet	12:43	14:42	1:59	E/L	11KV Insulator flashover	No
2		Mukundapuram	Dacharam	11KV	Huzurnagar	08.00	11.40	03.40	E/L	11KV Line snapped	No
3		Aitipamula	R.C.Puram	11KV	Nalgonda	14.40	16.50	02.10	E/L	Tree Fallen on the 11KV Line	No
1	MDK	Manoor	Pulkurthi	11KV	Jogipet	6:30	8:30	2:00		Conductor Snapped near Pulkurthi (V)	No
2		Cheryal	Kandi	11KV	Sangareddy	15.30	16.20	00.50		Jumper cut	No
1	RR E	Pocharam	Jodimetal	11KV	Keesara	3:10	3:50	0:40		Tree branches fallen on 11kv line	No
2		Narapilly	Apmeet	11KV	Keesara	00.35	01.30	00.55		Copper patti cut	No
3		Cherlapally	Rampally	11KV	Keesara	00.35	01.35	01.00		No visible fault	No