

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403									
8	Hyd	194	1044		2		2		2			
	Total	606	3055	0	3	0	3	0	3	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		1		1		1			
2	NLG	144	988		4		4		4			
3	MDK	107	933	1	2	1	2	1	2			
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	7	1	7	1	7	0	0	
	Grand Total	1082	6468	1	10	1	10	1	10	0	0	

TSSPDCL - LMRC / Corporate office

Date: 12.12.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	Gummadidala	GPSS-2	33KV	Patancheru	13.15	15.30	02.15		B/D Due to Conductor Snapped	GPSS-2	-

TSSPDCL - LMRC / Corporate office

Date: 12.12.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Bhoothpur	Amistapur	11KV	Jadcherla	02.30	08.15	05.45		11KV Jumper Cut Near Sheripally	-
1	NLG	Koduru	Thimmapuram	11KV	Suryapeta	07.00	09.10	02.10	E/L	Disk Flashover&Conductor Snapped	-
2		Agamothkur	Bommakala	11KV	Miryalaguda	05.00	08.00	03.00	E/L	11KV Conductor Snapped	-
3		Raghunadhpaalem	Nakkagudem	11KV	Huzurnagar	06.00	09.30	03.30	E/L	11KV Jumper cut	-
4		Kandibanda	Yerraram	11KV	Huzurnagar	08.00	09.00	01.00	E/L	11KV Disk Failure	-
1	MDK	Bonthapally	Jaishenkar	11KV	Patancheru	16.40	17.20	00.40		B/D Due to Conductor Snapped	-
2		Almaipet	Andole 24 Hrs	11KV	Jogipet	04.10	07.33	03.23		B/D Due to Jumper Cut	-
1	RR N	GP pally	GP pally	11KV	Medchal	03.10	04.10	01.00		Tree branch fallen on the 11KV line at Ayodhya Chowrasta	-
1	HYD C	Fever Hospital	Barkathpura Bus Depo	33KV	II	14.13	15.42	01.29	EL	AB Cable fault at Telangana Yuvatha Mandal	Isolated 5No DTRS
2		Industrial Area	Azamabad I.E	33KV	II	23.00	00.30	01.30	OL	No Visible Fault	----