

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		4		4		4			
6	RR(N)	54	550		7		7		7			
7	RR(E)	168	403		2		2		2			
8	Hyd	194	1044									
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>0</b>	<b>13</b>	<b>0</b>	<b>13</b>	<b>0</b>	<b>13</b>	<b>0</b>	<b>0</b>	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		7		7		7			
3	MDK	107	933	2	3	1	3		3	1		1no. 33KV Fdr Still
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>2</b>	<b>10</b>	<b>1</b>	<b>10</b>	<b>0</b>	<b>10</b>	<b>1</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>2</b>	<b>23</b>	<b>1</b>	<b>23</b>	<b>0</b>	<b>23</b>	<b>1</b>	<b>0</b>	

TSSPDCL - LMRC / Corporate office

Date: 13.12.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	Kandi	Aradhana	33KV	Sangareddy	19.45				B/D Still Continue		-
2		Gummadidala	AFA	33KV	Patancheru	20.55	23.35	02.40		B/D due to Disk failure near Bonthapally (V)		-

TSSPDCL - LMRC / Corporate office

Date: 13.12.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Koduru	Kommala	11KV	Suryapet	14.10	16.20	02.10	EL	Insulator flashover	-
2		Mattampally	Choutupally	11KV	Huzurnagar	06.40	07.34	00.54	EL	Due to 11Kv insulator failure	-
3		Mellacheruvu	Hemla thanda	11KV	Huzurnagar	06.23	09.30	03.07	EL	Due to 11Kv insulator failure	-
4		Bethavolu	J.P.Gudem	11KV	Huzurnagar	03.35	06.30	02.55	EL/OL	Due to Bird fall on 11kv line	-
5		Ch.Annaram	Gadibaigudem	11KV	Nalgonda	06.00	10.00	04.00	E/L	11KV line cut at nearby Gadibaigudem village	-
6		Koppole(K)	Koppole	11KV	Nalgonda	12.26	15.10	02.44	E/L	11KV jumper cut	-
7		Agamothkur	Bommakal	11KV	Miryalaguda	05.00	09.00	04.00	E/L	11KV conductor snapped & rectified	-
1	MDK	SRD T-II	No.3	11KV	Sangareddy	22.35	23.40	01.05		B/D Due to Disk failure at BSL Office	-
2		Collectorate	kothlapur	11KV	Sangareddy	19.45	23.40	03.55		B/D Due to Jumper cut	-
3		Patancheru	MIA-II	11KV	Sangareddy	20.45	01.00	04.15		B/D Due to insulator failed	-
1	RR S	Chanda Nagar	Huda Colony	11KV	Chanda Nagar	14.45	15.45	01.00		Tree fallen on the 11kv Line at Huda colony	-
2		Gachiobowli	Sudharshan Nagar	11KV	Chanda Nagar	14.50	15.50	01.00		Due to rain, No Visible fault found	-
3		ESCI	Lumbini Park	11KV	Chanda Nagar	09.50	10.58	01.08		11kv AB-Cable failed at Care Hospital, Pista House	-
4		Kaithlapur	IDAL	11KV	Chanda Nagar	21.25	22.43	01.18		Due to heavy rain, LABS Opened at IDAL gate	-
1	RR N	HMT	Quthbullapur	11KV	Medchal	21.05	22.05	01.00	BD	11KV Pin Insulator failed at Venkateshwara nagar	-
2		HMT	Manikya Nagar	11KV	Medchal	22.35	00.05	01.30	BD	11KV Pin Insulator failed at Indrasingh nagar	-
3		Kompally	Dholari Dhani	11KV	Medchal	21.20	21.45	00.25	BD	11KV Cable failed Backfeeding arranged to 11KV GBR Club feeder	-
4		HMT	Venkannahills	11KV	Medchal	23.45	00.35	00.50	BD	11KV Jumper cut & replacement at Boomireddy colony	-
5		Medicity	Rajabollaram	11KV	Medchal	03.00	04.30	01.30	BD	11KV Line Cut at Ganapur Village	-
6		GP Pally	Neighbourhood	11KV	Medchal	21.20	23.15	01.55	BD	Kite fallon on the 11KV Line at JK Seeds	-
7		Medchal	Checkpost	11KV	Medchal	21.15	22.50	01.35	BD	11KV Jumper cut & replacement in SS	-
1	RR E	Moula-Ali	Spectra	11KV	Sainikpuri	21.33	22.28	00.55		line AB Switch Open at Bharath Steel Company Feeder charged OK (Foc Narsihma Reddy)	-
2		Peerzathiguda	Peerzathiguda	11KV	Keesara	06.44	09.14	02.30		11KV jumper touch to cross arm at gayatri nagar	-