

Status Report on Breakdowns (Urban / Rural)

Urban

| S.No | Circle | No.of Feeders Existing Urban | | Breakdowns occurred during the day | | Attended during the day | | Time taken for restoring the supply | | | | Remarks (Pending) |
|------|--------------|------------------------------|-------------|------------------------------------|------------|-------------------------|------------|-------------------------------------|------------|--------------------------------|----------|-------------------|
| | | 33KV | 11KV | 33KV | 11KV | 33KV | 11KV | Rectified (Within 24 Hours) | | Not Rectified (Above 24 Hours) | | |
| | | | | | | | | 33KV | 11KV | 33KV | 11KV | |
| 1 | MBN | 18 | 107 | | | | | | | | | |
| 2 | NLG | 22 | 358 | | | | | | | | | |
| 3 | MDK | 97 | 359 | | | | | | | | | |
| 4 | SDPT | | | | | | | | | | | |
| 5 | RR(S) | 53 | 234 | | 5 | | 5 | | 5 | | | |
| 6 | RR(N) | 54 | 550 | 1 | 20 | 1 | 20 | 1 | 20 | | | |
| 7 | RR(E) | 168 | 403 | | 26 | | 26 | | 26 | | | |
| 8 | Hyd | 194 | 1044 | | 70 | | 70 | | 70 | | | |
| | Total | 606 | 3055 | 1 | 121 | 1 | 121 | 1 | 121 | 0 | 0 | |

Rural

| S.No | Circle | No.of Feeders Existing Rurals | | Breakdowns occurred during the day | | Attended during the day | | Time taken for restoring the supply | | | | Remarks (Pending) |
|------|--------------------|-------------------------------|-------------|------------------------------------|------------|-------------------------|------------|-------------------------------------|------------|--------------------------------|----------|-------------------|
| | | 33KV | 11KV | 33KV | 11KV | 33KV | 11KV | Rectified (Within 24 Hours) | | Not Rectified (Above 24 Hours) | | |
| | | | | | | | | 33KV | 11KV | 33KV | 11KV | |
| 1 | MBN | 107 | 849 | 2 | | 2 | | 2 | | | | |
| 2 | NLG | 144 | 988 | 1 | 8 | 1 | 8 | 1 | 8 | | | |
| 3 | MDK | 107 | 933 | 1 | 14 | 1 | 14 | 1 | 14 | | | |
| 4 | SDPT | | | 5 | 13 | 5 | 13 | 5 | 13 | | | |
| 5 | RR(S) | 58 | 396 | | | | | | | | | |
| 6 | RR(N) | 38 | 114 | | | | | | | | | |
| 7 | RR(E) | 22 | 133 | | | | | | | | | |
| | Total | 476 | 3413 | 9 | 35 | 9 | 35 | 9 | 35 | 0 | 0 | |
| | Grand Total | 1082 | 6468 | 10 | 156 | 10 | 156 | 10 | 156 | 0 | 0 | |

TSSPDCL - LMRC / Corporate office

Date: 14.12.2018

| S.No | Circle | Name of 132/33KV SS | Name of 33 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Sub Stations Effected | Alternate Supply Arranged |
|------|--------|---------------------|----------------------|------|----------------------|-------|-------|----------|------------------|---|-----------------------|--|
| 1 | MBNR | Maddur | Mogalmadka | 33KV | Narayanapet | 09.35 | 10.05 | 00.30 | | LA Blast | Maddur | Alternate Supply Arranged From 33KV Kankurthy SS at 10:05Hrs |
| 2 | | Wanaparthy | Kodair | 33KV | Wanaparthy | 13.45 | 15.38 | 01.53 | E/L & O/L | No Visible Fault was Found | Wanaparthy | NO |
| 1 | NLG | Hanmapur | Solepet | 33KV | Bhongir | 05.00 | 09.20 | 04.20 | EL/OL | Havey Rain 33kv Disc Fail near DSP Thota Ramilingampally Villge | Hanmapur | NO |
| 1 | MDK | Pashamailaram | BOC | 33KV | Sangareddy | 09.00 | 18.40 | 09.40 | | B/D Due to Jumper Cut Conductor Snapped | Pashamailaram | NO |
| 1 | SDPT | Palamakula | Gonepally | 33KV | Siddipet | 05.08 | 06.21 | 01.13 | | Due to Insuletor failed | Palamakula | NO |
| 2 | | Thunkibollaram | Seetharampally | 33KV | Gajwel | 01.30 | 07.45 | 06.15 | | Due to Insuletor failedlighting arrested blasted | Thunkibollaram | NO |
| 3 | | Thukkapur | Mirdoddy | 33KV | Gajwel | 20.30 | 11.55 | 08.35 | | Induction | Thukkapur | NO |
| 4 | | Duddeda | Bandaram | 33KV | Gajwel | 00.05 | 07.25 | 07.20 | | R-Phase lighting arrested blasted | Duddeda | NO |
| 5 | | Siddipet | Rangadampally | 33KV | Siddipet | 09.30 | 02.00 | 07.30 | | Due to Jumper cut | Siddipet | NO |
| 1 | RR N | 132KV Chintal | 33KV UMCC | 33KV | Medchal | 22.15 | 23.02 | 00.47 | | Kite fallen on 33KV Line at Pochamma Temple | 132KV Chintal | NO |

TSSPDCL - LMRC / Corporate office

Date: 14.12.2018

| S.No | Circle | Name of 33/11KV SS | Name of 11 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Alternate Supply Arranged |
|------|--------|--------------------|----------------------|------|----------------------|-------|-------|----------|------------------|--|---------------------------|
| 1 | NLG | Bibigudem | Munyanaik thanda | 11KV | Suryapet | 12.57 | 14.10 | 01.13 | E/L | 11Kv Disc flashover | - |
| 2 | | Huzurnagar | Singaram | 11KV | Huzurnagar | 12.40 | 14.00 | 01.20 | E/L | 11Kv Jumper Cut | - |
| 3 | | Agamothkur | Bommakal | 11KV | Miryalguda | 05.00 | 09.00 | 04.00 | E/L | 11Kv conductor snapped | - |
| 4 | | Rajapet | Narsapur Agl | 11KV | Bhongir | 02.30 | 08.55 | 06.25 | E/L | 11kv Insulator Fail near Gandamalla Villge | - |
| 5 | | Ragunathpur | Chaloor Agl | 11KV | Bhongir | 08.20 | 13.00 | 04.40 | E/L | 11kv Insulator Fail near Gouraipally Villge | - |
| 6 | | Kolanpaka | Somaram | 11KV | Bhongir | 08.45 | 15.25 | 06.40 | E/L | 11kv Insulator & Tree Branches Fallen at line near SS 10 | - |
| 7 | | Addagudur | Chollaramaram | 11KV | Bhongir | 01.10 | 11.20 | 10.10 | E/L | 11kv Insulator Fail near SS 07 Chinnapadishala village. 3phase B/d single phase ok | - |
| 8 | | Azeempet | Kanchanpally | 11KV | Bhongir | 00.20 | 09.45 | 09.25 | E/L | 11kv Insulator Fail near SS11 Kanchanapally Villge 3phase B/d single phase ok | - |
| 1 | MDK | Kistareddypet | Greenfiled | 11KV | Patancheru | 04.40 | 08.40 | 04.00 | | B/D Due to Jumper Cut | - |
| 2 | | Bonthapally | Ayappa | 11KV | Patancheru | 01.00 | 03.00 | 02.00 | | B/D Due to Conductor Snapped | - |
| 3 | | Gummadidala | Mabapur | 11KV | Patancheru | 02.15 | 04.15 | 02.00 | | B/D Due to Pin Insulator Faliure | - |
| 4 | | Bollaram - II | Vipla | 11KV | Patancheru | 19.00 | 00.00 | 05.00 | | B/D Due to Insualtor Failure | - |
| 5 | | Bollaram - II | Kotham | 11KV | Patancheru | 21.00 | 03.30 | 05.30 | | B/D Due to Conductor Snapped | - |
| 6 | | Bollaram - II | Shalini | 11KV | Patancheru | 21.50 | 01.40 | 03.50 | | B/D Due to Jumper Cut | - |
| 7 | | Bollaram - II | Rupa | 11KV | Patancheru | 20.30 | 00.20 | 04.20 | | B/D Due to Pin Insulator Failure Heavy wind and gail | - |
| 8 | | Kanakunta Agl | Kanakunta Agl | 11KV | Patancheru | 00.02 | 13.09 | 13.07 | | B/D Due to Insulator failure and Jumper Cut Heavy wind and gail | - |
| 9 | | Ranjole | Indl | 11KV | Zaheerabad | 03.00 | 07.25 | 04.20 | | B/D Due to Jumper Cut | - |
| 10 | | Gundla Machnoor | Industrial | 11KV | Jogipet | 01.00 | 08.00 | 07.00 | | B/D Due to Jumper Cut Heavy wind and gail | - |
| 11 | | Gundla Machnoor | Industrial | 11KV | Jogipet | 13.30 | 18.50 | 05.20 | | B/D Due to Conductor Snapped Jumper Cut | - |
| 12 | | Alamaipet | Sangupet | 11KV | Jogipet | 04.15 | 08.55 | 04.40 | | B/D Due to B/D Due to Insulator Failure Sangupet(V) | - |
| 13 | | Wasar | Naganpally | 11KV | Jogipet | 06.20 | 08.20 | 02.00 | | B/D Due to Jumper Cut near Naganpally(V) | - |
| 14 | | Munipally | Budhera | 11KV | Sangareddy | 11.30 | 13.09 | 01.39 | | B/D Due to Pin Insulator Failure | - |
| 1 | SDPT | Baswapur | Baswapur (R) | 11KV | Siddipet | 05.30 | 09.40 | 04.10 | | Insulator failure | - |
| 2 | | Guruvannapet | Guruvannapet | 11KV | Siddipet | 04.20 | 07.50 | 03.30 | | Due to rain fall | - |
| 3 | | Guruvannapet | Posanpally | 11KV | Siddipet | 00.30 | 09.30 | 09.00 | | Due to rain fall | - |
| 4 | | Komuravelly | Kadavergu | 11KV | Siddipet | 07.10 | 08.30 | 01.20 | | Insulator failure | - |
| 5 | | Mustyal | Veerannapet | 11KV | Gajwel | 01.20 | 09.30 | 08.10 | | Line problem | - |
| 6 | | Akkannapet | Akkannapet Rural | 11KV | Gajwel | 04.30 | 10.30 | 06.00 | | Insulator failure | - |
| 7 | | Thotapally | Anthakkapet | 11KV | Gajwel | 05.00 | 11.00 | 06.00 | | Insulator failure | - |
| 8 | | Thotapally | Mallampally | 11KV | Gajwel | 05.00 | 10.00 | 05.00 | | Insulator failure | - |
| 9 | | Gandipally | Gandipally | 11KV | Gajwel | 04.30 | 06.10 | 01.40 | | Insulator failure | - |
| 10 | | Gandipally | Ramavaram | 11KV | Gajwel | 04.50 | 10.30 | 05.40 | | Insulator failure | - |
| 11 | | Koheda | Sriramulapally | 11KV | Gajwel | 05.00 | 06.10 | 01.10 | | Insulator failure | - |

| S.No | Circle | Name of 33/11KV SS | Name of 11 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Alternate Supply Arranged |
|------|--------|--------------------|----------------------|------|----------------------|-------|-------|----------|------------------|--|---------------------------|
| 12 | | Koheda | Theegalakuntapally | 11KV | Gajwel | 05.00 | 11.40 | 06.40 | | Insulator failure | - |
| 13 | | Marmamula | Dharmaram | 11KV | Gajwel | 03.20 | 06.00 | 02.40 | | Insulator failure | - |
| 1 | RR S | Rajendranagar | Chinthamet | 11KV | Rajendra nagar | 00.02 | 01.05 | 01.03 | B/D | 11kv Insulator Failed at Basith Baba Darga | - |
| 2 | | Gachibowli | Sudharshan Nagar | 11KV | Gachibowli | 01.15 | 02.15 | 01.00 | B/D | 11kv Brosspatti cut and Disk failed at Sudharshan Nagar | - |
| 3 | | Chanda Nagar | Engineers Enclave | 11KV | Gachibowli | 03.40 | 07.00 | 03.20 | B/D | 11kv Pin-insulator failed at Community Hall(Due to heavy rain) | - |
| 4 | | Chanda Nagar | Tara Nagar | 11KV | Gachibowli | 04.00 | 07.00 | 03.00 | B/D | Tree fallen on the 11kv Line at Tara Nagar(Due to heavy rain) | - |
| 5 | | Mathrusri Nagar | Vishwambera | 11KV | Gachibowli | 02.50 | 04.40 | 01.50 | B/D | 11kv Pin-insulator failed at Plot NO.4950, Shilpa, (Due to heavy rain) | - |
| 1 | RR N | UMCC | Crusher | 11KV | Medchal | 23.00 | 00.40 | 01.40 | | Cloth fallen on the 11KV Line at Gajularamaram Village | - |
| 2 | | UMCC | RM Nagar | 11KV | Medchal | 23.00 | 01.30 | 02.30 | | Kite fallen on the 11KV Line at Chandragiri nagar | - |
| 3 | | UMCC | Mini Industry | 11KV | Medchal | 01.30 | 03.40 | 02.10 | | Kite fallen on the 11KV Line at Mini Industry | - |
| 4 | | Petbasheerbad | Balaji Hospital | 11KV | Medchal | 03.35 | 04.15 | 00.40 | | Tree fallen on the 11KV Line at Balaji Hospital back side | - |
| 5 | | HMT | Venkannahills | 11KV | Medchal | 00.40 | 01.25 | 00.45 | | Tripped on EL Indication(Due to Rain)(No fault) | - |
| 6 | | HMT | Ganesh nagar | 11KV | Medchal | 23.00 | 00.40 | 01.40 | | Tripped on EL Indication(Due to Rain)(No fault) | - |
| 7 | | Chinthal | Dwaraka Nagar | 11KV | Medchal | 01.15 | 04.00 | 02.45 | | Tripped on EL Indication(Due to Rain)(No fault) | - |
| 8 | | HMT | Manikya Nagar | 11KV | Medchal | 01.00 | 03.40 | 02.40 | | Tripped on EL Indication(Due to Rain)(No fault) | - |
| 9 | | Chinthal | Surya Nagar | 11KV | Medchal | 02.25 | 06.00 | 03.35 | | 11KV Cable failed at Surya nagar | - |
| 10 | | Chinthal | Dwaraka Nagar | 11KV | Medchal | 10.58 | 11.58 | 01.00 | | 11KV Disc failed at Prasanna Nagar | - |
| 11 | | Jeedimetla-IV | AAI Matha | 11KV | Jeedimetla | 07.50 | 08.55 | 01.05 | | 11kv Line Snapped & 11kv Pin Insultor Failure At BhagyLaxmi Colony | - |
| 12 | | Athiwelly | Dabeerpur | 11KV | Medchal | 02.00 | 06.20 | 04.20 | | Tree fallen on the 11KV Line at Lingapur Thanda | - |
| 13 | | Kistapur | IDA Hanuman | 11KV | Medchal | 02.30 | 06.05 | 03.35 | | 11KV PinInsulator failed at Suma Biscuits company | - |
| 14 | | Nuthankal | Oyster | 11KV | Medchal | 01.05 | 04.30 | 03.25 | | 11KV Pin Insulator Failed at Lingapur Road | - |
| 15 | | Medchal | IDA Kandlakoya | 11KV | Medchal | 00.05 | 02.15 | 02.10 | | Tripped on EL Indication(Due to Rain)(No fault) | - |
| 16 | | Medicity | Pudur | 11KV | Medchal | 07.00 | 10.00 | 03.00 | | Tree Branches fallen & 4th wire Line Stringing at Yellamma Temple & Gubba Thanda | - |
| 17 | | Athiwelly | Athiwelly | 11KV | Medchal | 00.09 | 02.29 | 02.20 | | Tree fallen on the 11KV Line at Athiwelly Village | - |
| 18 | | Keshavaram | Uddamarry | 11KV | Medchal | 06.30 | 08.40 | 02.10 | | 11KV Disc failed at Thallagadda Cheruvu,Keshavaram Village | - |
| 19 | | Athiwelly | PHI | 11KV | Medchal | 00.00 | 01.00 | 01.00 | | Tripped on EL Indication(Due to Rain)(No fault) | - |
| 20 | | Town Medchal | Balaji Nagar | 11KV | Medchal | 00.00 | 01.20 | 01.20 | | 11KV Disc failed at Chandra nagar | - |
| 1 | | Cherlapally-IV | Sun Raise | 11KV | Sainikpuri | 05.40 | 06.30 | 00.50 | | Metal scan & Post off Insulator failure at Ceepet ollege (L.Insp Satyanarayana) | - |
| 2 | | Sainikpuri | Ramalayam | 11KV | Sainikpuri | 01.06 | 02.35 | 01.29 | | Tree branches fallen on 11Kv line at Defence Colony (AE/SKP) | - |
| 3 | | Sainikpuri | Defence olony | 11KV | Sainikpuri | 01.25 | 02.30 | 01.05 | | Tree branches fallen on 11Kv line at Defence Colony (AE/SKP) | - |

| S.No | Circle | Name of 33/11KV SS | Name of 11 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Alternate Supply Arranged | |
|------|--------|--------------------|----------------------|-----------------|----------------------|---------|-------|----------|------------------|---|--|---|
| 4 | RR E | Sainikpuri | Sainikpuri | 11KV | Sainikpuri | 02.18 | 05.00 | 02.42 | | 11Kv Insulator failed at Defence Colony (AE/SKP) | | |
| 5 | | Kushaiguda | Kapra | 11KV | Sainikpuri | 00.05 | 01.30 | 01.25 | | 11Kv Disk failed at Varun Enlave (AE/Kushaiguda) | | |
| 6 | | VP Nagar | Deendayal Nagar | 11KV | Sainikpuri | 01.10 | 02.40 | 01.30 | | Ground petrolling done but no visible fault found (LM Narsihma) & Heavy Rain | | |
| 7 | | VP Nagar | Officers Colony | 11KV | Sainikpuri | 01.35 | 02.30 | 00.55 | | Tree branches fallen on 11Kv line at Venkateshwar Nagar (LM Narsimha) | | |
| 8 | | Moula-Ali | Malkajgiri | 11KV | Sainikpuri | 06.25 | 07.27 | 01.02 | | 11Kv Disk failed at RTC Colony (L.Insp Venkateshwarulu) | | |
| 9 | | Anandbagh | NMDC | 11KV | Sainikpuri | 23.55 | 02.45 | 02.50 | | 11Kv Pin Insulator failed at Surya Tower East Anandbagh (LM Babu) | | |
| 10 | | Polytechnice | Madhura nagar | 11KV | Habsiguda | 02.25 | 04.13 | 01.48 | | Coconut tree fallen on 11kv line at Gokul Hospital | | |
| 11 | | Street no 8 | Eggwood | 11KV | Habsiguda | 01.04 | 03.16 | 02.12 | | Tripped on EL/OL due to Tree fallen on 11kv & Disk fail at LS show room main road uppal | | |
| 12 | | IDA Uppal | Kamakshipuram | 11KV | Habsiguda | 05.40 | 07.10 | 01.30 | | 11KV disk fail at srinivasapuram st no 1 ramalayam temple | | |
| 13 | | IDA Uppal | Ram reddy nagar | 11KV | Habsiguda | 04.50 | 06.20 | 01.30 | | 11kv disk fail at Happy bar | | |
| 14 | | Nacharam indore | Ramreddy nagar | 11KV | Habsiguda | 01.05 | 03.20 | 02.15 | | Tripped on EL due to cement fallen on HG fuese insulator at Sawakar nagar new building | | |
| 15 | | Mallapur | Standed tiles | 11KV | Habsiguda | 01.05 | 02.30 | 01.25 | | 11kv Disk fail at cennar chemical company | | |
| 16 | | Mallapur2 | Surya nagar | 11KV | Habsiguda | 00.28 | 01.20 | 00.52 | | Tree branches fallen on 11kv line at My flower | | |
| 17 | | Nacharam | Bhagya nagar | 11KV | Habsiguda | 01.36 | 03.38 | 02.02 | | Gl wire fallen on 11kv line at bhagya nagar Opp | | |
| 18 | | Peerzathiguda | RTC | 11KV | Keesara | 01.00 | 04.26 | 03.26 | | 11KV Insulator failed at Sai Nagar Colony | - | |
| 19 | | Peerzathiguda | Peerzathiguda | 11KV | Keesara | 01.00 | 03.41 | 02.41 | | 11KV Insulator failed at Peerzathiguda Main Road | - | |
| 20 | | Cherlapally | Rampally | 11KV | Keesara | 00.30 | 07.25 | 06.55 | | Lighting erector failed at Cherlapally Industries due to rain | - | |
| 21 | | Chengicherla | RTC | 11KV | Keesara | 02.30 | 03.40 | 01.10 | | Tree branches fallen on 11kv line at RTC Colony | - | |
| 22 | | Saketh | Dammaiguda | 11KV | Keesara | 02.30 | 03.20 | 00.50 | | 11KV Insulator failed at Dammaiguda Village | - | |
| 23 | | Chakripuram | Simhapuri Colony | 11KV | Keesara | 23.47 | 03.43 | 03.56 | | Line patrolling but no visible fault due to heavy rain | - | |
| 24 | | Chakripuram | Ayyappa | 11KV | Keesara | 00.02 | 09.34 | 09.32 | | 11KV Insulator failed near Avisha Building | | |
| 25 | | Nagaram | Bandlaguda | 11KV | Keesara | 01.50 | 03.52 | 02.02 | | Line patrolling but no visible fault due to heavy rain and AB switch opened at Praja Sai Garden | - | |
| 26 | | Nagaram | SN Colony | 11KV | Keesara | 02.05 | 04.05 | 02.00 | | Line patrolling but no visible fault due to heavy rain | - | |
| 1 | | | Gymkhana | Mud Fort | 11KV | Sec-Bad | 00.08 | 01.50 | 01.42 | EL | AB Switch fault at Church Lane | - |
| 2 | | | Marredpally | Mahendra Hills | 11KV | Sec-Bad | 00.10 | 01.40 | 01.30 | EL,OL-Bph | Disc Insulator flash over at Thanvi Hospital | - |
| 3 | | | Vasanthapuri | Siripuri Colony | 11KV | Sec-Bad | 00.14 | 04.30 | 04.16 | EL,OL | No Visible Fault due to heavy rain | - |
| 4 | | I.I.C.T | Solex | 11KV | Sec-Bad | 00.20 | 07.20 | 07.00 | EL,OL | Tree braches fallen on lines at S.R.Shop | - | |
| 5 | | Lalaguda | Lalapet | 11KV | Sec-Bad | 00.35 | 08.17 | 07.42 | EL | Disc Insulator flash over at Jana Priya Apts | - | |
| 6 | | Lalaguda | Vijayapuri | 11KV | Sec-Bad | 01.10 | 07.55 | 06.45 | EL | No Visible Fault due to heavy rain | - | |
| 7 | | Gymkhana | Balamrai | 11KV | Sec-Bad | 01.12 | 09.55 | 08.43 | EL,OL | Insulator flash over at Marga Darsi Colony | Arranged B/F on 11KV Ranibagh fdr | |

| S.No | Circle | Name of 33/11KV SS | Name of 11 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Alternate Supply Arranged | |
|------|-------------|--------------------|-------------------------|-----------------|----------------------|-----------|-------|----------|------------------|--|---|---|
| 8 | HYD N | Bansilalpet | C.C.Nagar | 11KV | Sec-Bad | 01.20 | 04.00 | 02.40 | OL-Rph | Tree branches & Kite Sticks fallen on line at Kawadiguda | - | |
| 9 | | Clock Tower | Sangeeth | 11KV | Sec-Bad | 02.10 | 03.15 | 01.05 | EL,OL-Rph | No Visible Fault due to heavy rain | - | |
| 10 | | Patigadda | Sanjeevaiah Park | 11KV | Sec-Bad | 02.10 | 08.10 | 06.00 | EL | 2No. DTRs fault at Sanjeevaiah Park | - | |
| 11 | | Marredpally | Mahendra Hills | 11KV | Sec-Bad | 01.45 | 07.20 | 05.35 | EL,OL-Bph | No Visible Fault due to heavy rain | - | |
| 12 | | Clock Tower | Railway Reservation | 11KV | Sec-Bad | 01.45 | 08.27 | 06.42 | All Indication | Moiture formed in R.M.U at Parika Basti | - | |
| 13 | | Clock Tower | Natraj | 11KV | Sec-Bad | 05.25 | 16.50 | 11.25 | | Moixture formed in 2No. R.M.U Cables near Navakethan Complex | Arranged partial B/F on 11KV S.P Road fdr | |
| 14 | | Chinna Thokatta | Park View Enclave | 11KV | Bowenpally | 00.30 | 03.10 | 02.40 | EL,OL-Rph | No Visible Fault due to heavy rain | - | |
| 15 | | Bowenpally | Akshaya Enclave | 11KV | Bowenpally | 00.45 | 03.10 | 02.25 | EL,OL-Rph | No Visible Fault due to heavy rain | - | |
| 16 | | Bowenpally | Pipe Line | 11KV | Bowenpally | 00.50 | 05.00 | 04.10 | OL-Rph | No Visible Fault due to heavy rain | - | |
| 17 | | H.M.T | A.O.L | 11KV | Bowenpally | 02.10 | 04.00 | 01.50 | OL | No Visible Fault due to heavy rain | - | |
| 18 | | Bowenpally | Sancharapuri Colony | 11KV | Bowenpally | 02.30 | 05.00 | 02.30 | EL | Tree braches fallen on lines at Military Area | - | |
| 19 | | I.D.P.L | SIFCO | 11KV | Bowenpally | 03.15 | 07.20 | 04.05 | EL | Jumpers cut at 1st line AB Switch & SS | - | |
| 20 | | I.D.P.L | SVCIE | 11KV | Bowenpally | 03.20 | 05.20 | 02.00 | EL,OL | Tree braches fallen on lines at Plot.No.11, TIE Bala Nagar | - | |
| 21 | | Prashanth Nagar | Time Tech | 11KV | Bowenpally | 03.30 | 07.30 | 04.00 | OL-Bph | Disc Insulator flash over at Honda Show Room | - | |
| 22 | | Hakimpet | President of India | 11KV | Bowenpally | 00.15 | 03.50 | 03.35 | EL | Faulty loads of 11KV Raithu Bazar feeder | - | |
| 23 | | Macha Bollaram | Radha Sath Sang | 11KV | Bowenpally | 00.38 | 01.47 | 01.09 | OL-Rph | No Visible Fault due to heavy rain | - | |
| 24 | | Macha Bollaram | Reddy Enclave | 11KV | Bowenpally | 00.40 | 02.30 | 01.50 | EL,OL-Rph | No Visible Fault due to heavy rain | - | |
| 25 | | Macha Bollaram | Chinthal Bazar | 11KV | Bowenpally | 00.44 | 01.45 | 01.01 | EL | No Visible Fault due to heavy rain | - | |
| 26 | | Hakimpet | Allenby Lines | 11KV | Bowenpally | 02.20 | 07.20 | 05.00 | EL,OL-Rph | No Visible Fault due to heavy rain | - | |
| 27 | | Jubilee Hills | P.E.I - UG | 11KV | Banjarahills | 01.05 | 02.58 | 01.53 | EL | No Visible Fault due to heavy rain | - | |
| 28 | | Jubilee Hills | P.E.I - OH | 11KV | Banjarahills | 01.10 | 02.58 | 01.48 | EL | No Visible Fault due to heavy rain | - | |
| 29 | | Yousufguda | Venkatagiri | 11KV | Banjarahills | 01.55 | 03.55 | 02.00 | EL | Pin Insulator flash over at Ajay Bank | - | |
| 30 | | Jubilee Hills | Arts Gallery | 11KV | Banjarahills | 02.25 | 05.20 | 02.55 | EL,OL-Bph | Jumper cut at Arts Gallery | - | |
| 31 | | Road No.13 | Road No.1 | 11KV | Banjarahills | 03.20 | 04.20 | 01.00 | EL | No Visible Fault due to heavy rain | - | |
| 1 | | HYD S | Arundhathi Colony | Neelam Center | 11KV | Charminar | 04.25 | 06.15 | 01.50 | All Indication | Kite Stick fallen on lines at Neelam Centre | - |
| 2 | | | Panjasha | Shajahan Hotel | 11KV | Charminar | 04.30 | 06.25 | 01.55 | All Indication | Tree branches fallen on lines at Kaveli | - |
| 3 | | | Devibagh | Kamela | 11KV | Charminar | 04.39 | 05.45 | 01.06 | EL | No Visible Fault due to heavy rain | - |
| 4 | | | Kanchanbagh | Riyasath Nagar | 11KV | Charminar | 04.42 | 06.45 | 02.03 | OL-Bph | No Visible Fault due to heavy rain | - |
| 5 | | | Aliyabad | Sharada College | 11KV | Charminar | 05.25 | 06.40 | 01.15 | OL | No Visible Fault due to heavy rain | - |
| 6 | | | Kandikal Gate | Patel Nagar | 11KV | Charminar | 05.40 | 07.20 | 01.40 | EL | Kite Stick fallen on lines at Tanaji Nagar | - |
| 7 | | | Falaknuma | Farooq Nagar | 11KV | Charminar | 06.05 | 07.26 | 01.21 | EL,OL | No Visible Fault due to heavy rain | - |
| 8 | Teegalaguda | | Saleem Nagar Milk Booth | 11KV | Asmangadh | 01.31 | 04.25 | 02.54 | EL | Pin Insulator flash over at Saleem Nagar | - | |
| 9 | Asmangadh | | Shiva Ganga | 11KV | Asmangadh | 02.05 | 04.15 | 02.10 | EL | No Visible Fault due to heavy rain | - | |
| 10 | Malakpet | | Municipal Colony | 11KV | Asmangadh | 04.45 | 06.05 | 01.20 | EL | Cable Jumper sparking at MCH Cly | - | |
| 11 | Kanchanbagh | | Kanchanbagh | 11KV | Asmangadh | 04.35 | 08.40 | 04.05 | EL | No Visible Fault due to heavy rain | Arranged B/F on 11KV Habeeb Nagar feeder | |

| S.No | Circle | Name of 33/11KV SS | Name of 11 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Alternate Supply Arranged |
|------|--------|--------------------|----------------------|------|----------------------|-------|-------|----------|------------------|---|------------------------------------|
| 12 | | Karwan | Karwan | 11KV | Begumbazar | 01.20 | 04.30 | 03.10 | EL,OL-Bph | Foreign material fallen on lines at Kanaka Durga Colony | - |
| 1 | HYD C | Jawahar Nagar | Jawahar Nagar | 11KV | Saifabad | 01.10 | 03.00 | 01.50 | EL,OL-Rph | Breaker fault at SS | Arranged B/F on 11KV J.N.Home fdr |
| 2 | | Hussain Sagar | Maruthi Nagar | 11KV | Saifabad | 01.41 | 07.55 | 06.14 | All Indication | Pin Insulator flash over at Kallu Compound | - |
| 3 | | Z.P.Office | Golconda Hotel | 11KV | Saifabad | 01.48 | 03.00 | 01.12 | EL,OL | No Visible Fault due to heavy rain | - |
| 4 | | Erramanzil | Red Rose | 11KV | Saifabad | 01.54 | 04.30 | 02.36 | OL | No Visible Fault due to heavy rain | - |
| 5 | | Z.P.Office | Seven Temple | 11KV | Saifabad | 02.06 | 09.50 | 07.44 | EL | No Visible Fault due to heavy rain | - |
| 6 | | Lumbini Park | Avanthi Nagar | 11KV | Saifabad | 02.35 | 07.33 | 04.58 | EL | No Visible Fault due to heavy rain | Arranged B/F on 11KV Galaxy feeder |
| 7 | | Indira Park | Datta Nagar | 11KV | Saifabad | 03.00 | 04.36 | 01.36 | EL,OL | No Visible Fault due to heavy rain | - |
| 8 | | Indira Park | Kawadiguda | 11KV | Saifabad | 03.15 | 04.20 | 01.05 | EL | No Visible Fault due to heavy rain | - |
| 9 | | Indira Park | Secreteriate | 11KV | Saifabad | 04.40 | 08.00 | 03.20 | EL,OL | Tree braches fallen on lines at A.V.College | - |
| 10 | | Erramanzil | Red Rose | 11KV | Saifabad | 07.55 | 09.30 | 01.35 | EL | Moiture formed in R.M.U at Red Rose | - |
| 11 | | Erramanzil | Jaffer-Ali-Bagh | 11KV | Saifabad | 07.55 | 09.30 | 01.35 | EL | Moiture formed in R.M.U at Red Rose | - |
| 12 | | Bathkammakunta | D.D.Colony | 11KV | Azamabad | 01.46 | 03.05 | 01.19 | EL | No Visible Fault due to heavy rain | - |
| 13 | | Fever Hospital | Tourist Hotel | 11KV | Azamabad | 01.49 | 02.50 | 01.01 | EL,OL-Bph | Cable fault | Arranged B/F on 11KV Golnaka fdr |
| 14 | | Bathkammakunta | Ahobil Mutt | 11KV | Azamabad | 02.21 | 05.45 | 03.24 | EL | Insulator flash over at Kabeer Tower | - |
| 15 | | A.S.R.Raju Nagar | Jeevan Kalyan Nagar | 11KV | Mehdipanam | 00.20 | 01.50 | 01.30 | EL | No Visible Fault due to heavy rain | - |
| 16 | | S.D.Hospital | Ahmed Nagar Cable | 11KV | Mehdipanam | 00.40 | 02.09 | 01.29 | EL,OL-Yph | No Visible Fault due to heavy rain | - |
| 17 | | Toli Chowki | B.S.N.L | 11KV | Mehdipanam | 01.27 | 03.54 | 02.27 | EL | No Visible Fault due to heavy rain | - |
| 18 | | Langer House | Netaji Nagar | 11KV | Mehdipanam | 01.40 | 04.25 | 02.45 | EL | No Visible Fault due to heavy rain | - |
| 19 | | A.S.R.Raju Nagar | Golla Basti | 11KV | Mehdipanam | 02.15 | 06.02 | 03.47 | EL | AB Cable fault at Khaleel Hotel | - |
| 20 | | A.S.R.Raju Nagar | A.S.R.Raju Nagar | 11KV | Mehdipanam | 02.20 | 03.27 | 01.07 | EL,OL | Cable fault at KRK Garden | - |
| 21 | | Langer House | Defence Colony | 11KV | Mehdipanam | 02.30 | 04.00 | 01.30 | EL | DTR fault at Madhu Basti | - |
| 22 | | Nampally | Badi Masjid | 11KV | Mehdipanam | 02.56 | 04.20 | 01.24 | EL,OL-Bph | HT Jumper cut at Khilla | - |
| 23 | | Gudi Malkapur | Navodaya Colony | 11KV | Mehdipanam | 02.58 | 04.15 | 01.17 | OL-Y&Bph | Tree braches fallen on lines at Navodaya Colony | - |
| 24 | | Golconda | Darga OH | 11KV | Mehdipanam | 03.05 | 04.15 | 01.10 | EL,OL | No Visible Fault due to heavy rain | Opened AB Switch at Vivek Nagar |
| 25 | | A.C.Guards | Nilofer | 11KV | Mehdipanam | 03.06 | 04.45 | 01.39 | EL | Tree branches fallen on lines at Express Apts | - |
| 26 | | Golconda | Darga Cable | 11KV | Mehdipanam | 07.25 | 08.45 | 01.20 | EL,OL-Yph | No Visible Fault due to heavy rain | Opened AB Switch at D-Mart |
| 27 | | Gudi Malkapur | Amba Garden | 11KV | Mehdipanam | 13.59 | 15.39 | 01.40 | EL | Foreign material fallen on lines at Alapati Nagar | - |