

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403									
8	Hyd	194	1044		2		2		2			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>0</b>	<b>3</b>	<b>0</b>	<b>3</b>	<b>0</b>	<b>3</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1		1		1				
2	NLG	144	988		5		5		5			
3	MDK	107	933	1		1		1				
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>2</b>	<b>5</b>	<b>2</b>	<b>5</b>	<b>2</b>	<b>5</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>2</b>	<b>8</b>	<b>2</b>	<b>8</b>	<b>2</b>	<b>8</b>	<b>0</b>	<b>0</b>	

TSSPDCL - LMRC / Corporate office

Date: 15.12.18

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Kothur	Natco Pharma	33KV	Shadnagar	20.30	03.40	07.10	O/L & E/L	33KV Cable End Kit Damaged near Natco pharma Company	Natco Pharma	No
1	MDK	Narayankhed	Poosalpad	33KV	Jogipet	19:20	20:35	1:15		Conductor sanpped	Poosalpad	No

TSSPDCL - LMRC / Corporate office

Date: 15.12.18

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	B.Ramaram	Hajipur	11KV	Bhongiri	12:00	13:10	1:10	E/L	11KV Insulator failure	No
2		Narketpally IE	Vattimarthy	11KV	Nalgonda	06.00	09.47	03.47	E/L	Phase to phase melting	No
3		Akupamula	Lift	11KV	Huzurnagar	12.00	14.40	02.40	E/L	HT/LT Fault	No
4		Alingapuram	Gundlapahad	11KV	Huzurnagar	07.00	10.00	03.00	E/L	Jumper cut	No
5		B.N.Thanda	B.N.Thanda	11KV	Huzurnagar	5:25	7:20	1:55	E/L	Jumper cut	No
1	RR N	Subhash nagar	Jairam Nagar	11KV	Medchal	10:40	11:25	0:45		CT PT Problem at Sowbhagya Plastic Company	No
1	HYD N	Zamistanpur	Sanjeevapuram	11KV	Sec'bad	01.02	02.35	01.33	EL,OL-Rph	Reliance Cable fallen on lines at Reliance Tower	No
1	HYD C	Public Garden	Telugu University	11KV	Saifabad	14.52	16.00	01.08	EL	Cable fault at Azizia Hotel, Nampally	15:35 Hrs Partial feeder (50% Charged & remaining loads added on 11KV A.P.P.S.C feeder