

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403									
8	Hyd	194	1044									
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1	1	1	1	1	1			
2	NLG	144	988		5		5		5			
3	MDK	107	933									
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>1</b>	<b>6</b>	<b>1</b>	<b>6</b>	<b>1</b>	<b>6</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>1</b>	<b>6</b>	<b>1</b>	<b>6</b>	<b>1</b>	<b>6</b>	<b>0</b>	<b>0</b>	

TSSPDCL - LMRC / Corporate office

Date: 16.12.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Maddur	Mogalamadka	33KV	Narayanapet	08.35	09.40	01.05	E/L&O/L	LA Blost alternate supply arraged from 33KV Kankurthy SS	Mogalamadka	LA Blost alternate supply arraged from 33KV Kankurthy SS at 9:40Hrs

## TSSPDCL - LMRC / Corporate office

Date: 16.12.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Mothiganpur	Gangadar pally	11KV	Jadcherla	08.40	13.30	04.50		BD due to 11 kv wire cut near cheruvu at Gangadar pally.(v)	-
1	NLG	Huzurnagar	Singaram	11KV	Huzurnagar	13.40	15.30	01.50	EL	11KV Line Snapped	-
2		Munagala	Kokkereni-2	11KV	Huzurnagar	10.00	12.45	02.45	EL	11KV Line Snapped	-
3		Pamanagundla	Pittampally	11KV	Nalgonda	06.31	08.40	02.09	EL	11KV Jumper Cut	-
4		Raghunadpur	Raghunadpur AGL	11KV	Bhongiri	07.00	12.45	05.45	EL	11KV Disk Fail Dharmareddy Gudam Village	-
5		B.P.Pally	B.P.Pally	11KV	Bhongiri	00.00	09.00	09.00	EL	25KVA DTR Fail Narayanagiri Village	-