

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403									
8	Hyd	194	1044									
	Total	606	3055	0	0	0	0	0	0	0	0	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1		1		1				
2	NLG	144	988	1	6	1	6	1	6			
3	MDK	107	933	1	1	1	1	1	1			
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	3	7	3	7	3	7	0	0	
	Grand Total	1082	6468	3	7	3	7	3	7	0	0	

TSSPDCL - LMRC / Corporate office

Date: 01.11.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Midjil	Velugomula	33kv	Jadcherla	07.00	12.20	05.20	O/L	Conductor Snapped Near Ranipet(V)	Midjil	NO
1	NLG	Dirsincherla	Mukundapuram	33kv	Huzurnagar	13.30	16.30	03.00		Due to 33KV Snapped	Nereducherla	NO
1	MDK	Kandi	HFC I	33kv	Sangareddy	09.35	10.40	01.05		BD due to Lighting arrester failed		-

TSSPDCL - LMRC / Corporate office

Date: 01.11.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Aregudam	Peddakaparthi	11kv	Nalgonda	09.10	10.20	01.10	EL	11KV Jumper Cut	-
2		Penphad	Macharam	11kv	Suryapet	07.53	09.50	01.57	EL	Disk Failed	-
3		Dirsincherla	Somaram	11kv	Huzurnagar	10.00	12.00	02.00	EL	11KV Jumper Cut	-
4		Munagala	Munagala (T)	11kv	Huzurnagar	16.30	17.35	01.05	EL	11KV Line Cut	-
5		B.Ramaram	Hajipur	11kv	Bhongiri	10.10	11.10	01.00	EL	1No 100KVA DTR Failed Near Naginenipally Village	-
6		Narayanapur	Mellacheruvu	11kv	Bhongiri	09.00	12.00	03.00	EL	1No 63KVA DTR Failed Near Chetla Narsimha Bavi Mellacheruvu Village	-
1	MDK	Almaipet	Andole 24 Hrs.	11kv	Jogipet	19.52	21.14	01.22		BD due to Insulator failed	-