

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		2		2		2			
7	RR(E)	168	403									
8	Hyd	194	1044									
	Total	606	3055	0	2	0	2	0	2	0	0	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		4		4		4			
3	MDK	107	933									
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	4	0	4	0	4	0	0	
	Grand Total	1082	6468	0	6	0	6	0	6	0	0	

TSSPDCL - LMRC / Corporate office

Date: 23.12.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Narketpally IE	Vattimarthy	11KV	Nalgonda	06.00	09.00	03.00	E/L	Phase to Phase melting	-
2		Bollepally	Jampally	11KV	Bhongiri	05.00	08.00	03.00	E/L	Jumper cut	-
3		Puligilla	Kerchupally	11KV	Bhongiri	11.45	13.45	02.00	E/L	Insulator failure	-
4		Burugadda	Karkayalagudem	11KV	Huzurnagar	12.00	14.00	02.00	E/L	11KV Line cut	-
1	RR N	Jagathgirigutta	Shirdi Hills	11KV	Medchal	10.00	10.30	00.30	BD	11KV Cable Kit failed at RGK Block No-1	-
2		Petbasheerbad	Balaji Hospital	11KV	Medchal	09.05	10.25	01.20	BD	11KV UG Cable failed at Balaji Hospital	-