

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044		1		1		1			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>0</b>	<b>3</b>	<b>0</b>	<b>3</b>	<b>0</b>	<b>3</b>	<b>0</b>	<b>0</b>	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		5		5		5			
3	MDK	107	933									
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>0</b>	<b>5</b>	<b>0</b>	<b>5</b>	<b>0</b>	<b>5</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>0</b>	<b>8</b>	<b>0</b>	<b>8</b>	<b>0</b>	<b>8</b>	<b>0</b>	<b>0</b>	



## TSSPDCL - LMRC / Corporate office

Date: 27.12.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Chandampeta	Mudidandla	11KV	Devarakonda	10.00	12.00	02.00	E/L	Jumper cut	-
2		Madanapuram	Kurmedu	11KV	Devarakonda	10.15	11.15	01.00	E/L	Jumper cut	-
3		Chandupatla	Kunoor	11KV	Bhongiri	10.15	12.10	01.55	E/L	11KV Line Snapped	-
4		Aroor	Lingarajupally	11KV	Bhongiri	10.00	11.00	01.00	E/L	11KV Line Snapped	-
5		Alingapuram	Raghavapuram	11KV	Huzurnagar	09.30	12.30	03.00	E/L	11KV Line cut	-
1	RR N	Medchal	IDA Kistapur	11KV	Medchal	15.22	16.15	00.53		Tree fallen on the 11KV Line at Rudra Pratap Godom, Kistapur Village	-
1	RR E	Yapral	Tula'si Garden	11KV	Sainikpuri	21.40	22.10	00.30		11Kv Pin Insulator failed at Rack Garden (Foc Devilal/Shanker/AE/Yapral)	-
1	HYD S	Attapur	Shareef Nagar	11KV	Charminar	15.25	16.45	01.20	EL,OL-Rph	I/C Cable End Kit failed at A.B Nagar	Arranged B/F on 11KV Bahadurpura OH feeder