

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201									
5	RR(N)	82	407		4		4		4			
6	RR(E)	38	360									
7	Hyd	186	1014		1		1		1			
	<b>Total</b>	<b>504</b>	<b>2929</b>	<b>0</b>	<b>5</b>	<b>0</b>	<b>5</b>	<b>0</b>	<b>5</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969									
2	NLG	150	948		5		5		5			
3	MDK	87	828									
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	<b>Total</b>	<b>404</b>	<b>3220</b>	<b>0</b>	<b>5</b>	<b>0</b>	<b>5</b>	<b>0</b>	<b>5</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>908</b>	<b>6149</b>	<b>0</b>	<b>10</b>	<b>0</b>	<b>10</b>	<b>0</b>	<b>10</b>	<b>0</b>	<b>0</b>	



TSSPDCL - LMRC / Corporate office

Date: 04.02.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Bopparam	Midthanapally	11KV	Suryapet	06.30	08.20	01.50	E/L	Tree Branch fallen on the line	-
2		Garidepally	Ponugodu	11KV	Huzurnagar	06.30	08.15	01.45	EL	Due to 11kv Jumper cutted near Ponugodu village	-
3		Munagala	Nelamarry	11KV	Huzurnagar	09.10	11.20	02.10	EL/OL	Due to bird fall on 11Kv line near Nelamarry village	-
4		Nadigudem	Karvirala	11KV	Huzurnagar	06.30	11.00	04.30	EL	Due to pin Insulator fault occur near Karvirala village	-
5		Eduloor	Garlabaigudem	11KV	Nalgonda	07.00	11.30	04.30	EL	11KV jumper cut at SS-2	-
1	RR N	Mayurinagar	KTR colony	11KV	Kukatpally	11.20	13.00	01.40	BD	11 KV line AB cable failure &double cable feeder then cable conneting at Near SS	-
2		Aleap	Pragathinagar	11KV	Jeedimetla	11.45	12.30	00.45	BD	A bira Fallon the 11kv line at Plot : 1954, Pragathinagar	-
3		Jeedimetl-I	JETL	11KV	Jeedimetla	08.25	10.45	02.20	BD	11 KV line AB cable failure Near Vasudha Forma at Phase-I Line	-
4		Ravalkole	IDA	11KV	Medchal	15.00	16.02	01.02	BD	11KV AB Cable failed at Monark Company	-
1	HYD C	S.D.Hospital	Ahmed Nagar Cable	11KV	VII	20.50	22.07	01.17	EL	No Visible fault	Arranged B/F on 11KVMilitary fdr