

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201									
5	RR(N)	82	407									
6	RR(E)	38	360									
7	Hyd	186	1014		3		3		3			
	Total	504	2929	0	3	0	3	0	3	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969									
2	NLG	150	948		1		1		1			
3	MDK	87	828		2		2		2			
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	0	3	0	3	0	3	0	0	
	Grand Total	908	6149	0	6	0	6	0	6	0	0	

TSSPDCL - LMRC / Corporate office

Date: 05.02.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Cherkupally	Bollanpally	11KV	Devarakonda	11.00	14.30	03.30	E/L	11KV Line Conductor Cut	-
1	MDK	Rudraram	Mallupally	11KV	Siddipet	14.20	17.30	03.10		B/D Due to 11 KV INSULATOR FAILED	-
2		Kowdipally	Mohd Nagar	11KV	Medak	12.20	13.10	00.50		B/D Due to 11 KV INSULATOR FAILED	-
1	HYD N	Raheja	Info Tech	11KV	Banjarahills	13.38	14.40	01.02	EL	Cable fault at Info Tech	Arranged B/F on 11KV APIIC-I fdr
2		Nehru Nagar	Rezimental Bazar	11KV	Sec-Bad	16.52	17.58	01.06	EL	Cable fault at Himalaya Book Depot	Arranged B/F on 11KV Teachers Colony fdr
3	HYD C	A.C.Guards	N.M.D.C.	11KV	Mehdipatanam	17.55	19.30	01.35	OL-Rph	DTR fault at J.N.T.U	-----

