

TSSPDCL - LMRC / Corporate office

Date: 07.02.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	NLG	WADAPALLY	JANPHAD	33KV	Huzurnagar	05.05	10.00	04.55	EL	Due to Pin insulator Failure		-

TSSPDCL - LMRC / Corporate office

Date: 07.02.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Kodur	Loyapally	11KV	Suryapet	06.00	08.15	02.15	EL	Jumper cut	-
2		Mukundapuram	Kalluru	11KV	Huzurnagar	10.00	11.55	01.55	EL	Due to 11Kv Snapped near Kalluru village	-
3		Janpahad	Janpahad	11KV	Huzurnagar	12.40	14.54	02.14	EL	Due to 11Kv Insulator failure near Janpahad vilage	-
4		Gondriyala	Chimiryala	11KV	Huzurnagar	09.25	10.30	01.05	EL	Due to 11Kv Line Cuttted near Chimiryala village	-
1	MDK	Shalipet	Shalipet	11KV	Medak	00.00	06.00	06.00		B/D Due to Jumper Cut	-
1	RR N	J D M Ss-II	ApuroopaColony	11KV	Jeedimetla	15.20	16.22	01.02	EL	11kv Pin Insultor Failure At Phase-III	-
1	RR E	Mallapur-2	Laxmi Narsimha	11KV	Habsiguda	11.38	14.18	02.40		11KV UG Cable failed at Subash Nagar	-
1	HYD N	Kalyan Nagar	Rahamath Nagar	11KV	Banjarahills	17.07	18.18	01.11	EL,OL-Bph	End Kit Failed at Rahamath Nagar Sweet House Gally	-
2	HYD C	Langer House	Netaji Nagar	11KV	Mehdipatanam	18.00	19.50	01.50	EL	Cable damaged at Haven Garden	2No DTR's Kept off at Haven Garden

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201									
5	RR(N)	82	407		1		1		1			
6	RR(E)	38	360		1		1		1			
7	Hyd	186	1014		2		2		2			
	Total	504	2929	0	4	0	4	0	4	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969									
2	NLG	150	948	1	4	1	4	1	4			
3	MDK	87	828		1		1		1			
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	1	5	1	5	1	5	0	0	
	Grand Total	908	6149	1	9	1	9	1	9	0	0	