

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201									
5	RR(N)	82	407		2		2		2			
6	RR(E)	38	360									
7	Hyd	186	1014		2		2		2			
	<b>Total</b>	<b>504</b>	<b>2929</b>	<b>0</b>	<b>4</b>	<b>0</b>	<b>4</b>	<b>0</b>	<b>4</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969									
2	NLG	150	948		4		4		4			
3	MDK	87	828									
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	<b>Total</b>	<b>404</b>	<b>3220</b>	<b>0</b>	<b>4</b>	<b>0</b>	<b>4</b>	<b>0</b>	<b>4</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>908</b>	<b>6149</b>	<b>0</b>	<b>8</b>	<b>0</b>	<b>8</b>	<b>0</b>	<b>8</b>	<b>0</b>	<b>0</b>	

TSSPDCL - LMRC / Corporate office

Date: 09.02.18

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Ravulapally	Manapuram	11KV	Suryapet	11:30	14:00	2:30	EL	Jumper cut	No
2		Palakaveedu	Bothalapalem	11KV	Huzurnagar	11.45	17.00	05.15	EL	11KV Jumper cut near Bothalapalem village	No
3		Kopple	Bollaram	11KV	Devarakonda	05.00	06.00	01.00	EL	Jumper cut	No
4		B.ramaram	Malyala	11KV	Bhongir	13.00	14.50	01.50	EL	11KV Line snapped near Ch.Mamidi Village	No
1	RR N	Subash Nagar	Jeedimetla	11KV	Medchal	16:35	17:45	1:10		11KV AB Cable failed at Govt School backside, Jeedimetla	No
2		Kandlakoya	Kandlakoya	11KV	Medchal	16.00	16.30	00.30		11KV Pole damaged at Padma Sri Vencher, Kandlakoya	No
1	HYD N	Kalyan Nagar	Rahamath Nagar	11KV	Jublee Hills	08.24	09.56	01.32	EL,OL-Rph	Cable end kit failed at Kallu Compound Gally	No
1	HYD S	Devi Bagh	Shevala Ghat	11KV	Charminar	22.50	00.30	01.40	EL,OL-Rph	No visible fault	No

