

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201									
5	RR(N)	82	407		3		3		3			
6	RR(E)	38	360		3		3		3			
7	Hyd	186	1014		6		6		6			
	Total	504	2929	0	12	0	12	0	12	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969	1		1		1				
2	NLG	150	948		2		2		2			
3	MDK	87	828	1	1	1	1	1	1			
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	2	3	2	3	2	3	0	0	
	Grand Total	908	6149	2	15	2	15	2	15	0	0	

TSSPDCL - LMRC / Corporate office

Date: 11.02.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Rajapet	Pamukunta	11KV	Bhongir	03.00	06.00	03.00	EL	11KV Insulator failed at Pedda Cheruvu	-
2		P.D.Pally	Gajalapuram	11KV	Miryalaguda	07.30	09.00	01.30	EL	11 KV Insulator failed	-
1	MDK	Gajulagudem	Chithiriyal AGL	11KV	Medak	09.20	16.00	06.40		B/D Due to Jumper Cut	-
1	RR N	Vijayanagar	Sapathgir Colony	11KV	kukatpally	16.30	17.55	01.25	EL/OL	11kv Pin Insultor Failure opp Sub Station	-
2		HMT	Ganeshnagar	11KV	Medchal	00.05	00.35	00.30	EL/OL	11kv Cable failed at Municipal Office (Backfeeding arreaged from 11kv Padmanagar Feeder)	-
3		Ravalkole	Ravalkole	11KV	Medchal	14.00	16.20	02.20	BD	Tree fallen on 11kv Line at Nimmalagadda Bavi, Ravalkole	-
1	RR E	St.No.08	Greenhills	11KV	Habsiguda	11.35	12.42	01.07		Tree branches fallen on 11KV line near Genpact	-
2		VP Nagar	Deendayal Nagar	11KV	Sainikpuri	02.05	04.15	02.10		11Kv AB Cable Stay Wire Shot at KK Nagar Gouri Shankar Apt (LM Narasimma)	-
3		PEDDAMBERPET	KUNTLOOR	11KV	SAROORNAGAR	12.25	16.05	03.35	EL	11KV LINE CUT AT KUNTLOOR	-
1	HYD N	H.A.L	Indian Rubber	11KV	Bowenpally	11.05	12.20	01.15	EL	Cable fault at Indian Rubber	Arranged B/F on 11KV V.E. fdr & 11KV Lokesh Machine fdr
2		Gymkhana	Balamrai	11KV	Sec-Bad	12.20	13.30	01.10	EL,OL	Tree branches fallen on lines at Happy Enclave	-
1	HYD S	Karwan	Jiyaguda UG	11KV	Begumbazar	02.15	04.20	02.05	EL,OL-Rph	AB Cable fault at Himampura	Arranged B/F on 11KV Goshala fdr
2		Falaknuma	Farooq Nagar	11KV	Charminar	12.10	13.32	01.22	EL	Brass Patti cut & HG fuse B/o at Bombay Kirana Store	-
1	HYD C	Golconda	Narayanamma Engi.College	11KV	Mehdipatanam	12.45	15.32	02.47	EL,OL	Braeker fault at SS	Arranged B/F on 11KV Brindavan Colony fdr
2		Langer House	Fathe Darwaja	11KV	Mehdipatanam	13.15	14.50	01.35	EL,OL	Cable Jumper cut at HUDA Park	-

TSSPDCL - LMRC / Corporate office

Date: 11.02.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Marikal	Koilkonda Water Grid	33KV	MBNR	02.50	09.50	07.00	E/L	No Visible fault supply Stude OK	Marikal	-
1	MDK	Narayankhed	Sirgapur	33KV	Sangareddy	11.35	15.15	03.40		B/D Due to tree branches fallow on line near Ryalamadugu(V)	Narayankhed	-