

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201		1		1		1			
5	RR(N)	82	407		2		2		2			
6	RR(E)	38	360		1		1		1			
7	Hyd	186	1014		1		1		1			
	Total	504	2929	0	5	0	5	0	5	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969	1	1	1	1	1	1			
2	NLG	150	948									
3	MDK	87	828	1		1		1				
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	2	1	2	1	2	1	0	0	
	Grand Total	908	6149	2	6	2	6	2	6	0	0	

TSSPDCL - LMRC / Corporate office

Date: 12.02.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Kothamolgera	Kothamolgera	11KV	Jadcherla	06.00	10.00	04.00		11KV Wire Cut Near Kurva Ashanna Bavi Side Kappeta.	-
1	RR S	Indira Gandhi Society	Indirashivashakti	11KV	RJNR	15.40	16.30	00.50	B/D	11KV Pole damaged at SS Opp for LAB opened at Lambadibasti due to Lorry dashed	-
1	RR N	JDM SS IV	Tagore	11KV	JDM	04.45	09.55	05.10	EL	Tagore Company HG Fuse Failure touched to channel and Incoming Supply Failure.	-
2		JDM SS - 1	JETL & LV-1	11KV	JDM	16.05	18.00	01.55	EL/OL	11KV AB Cable Failure near VIP Foods.	-
1	RR E	MARUTHI NAGAR	ASTA LAXMI	11KV	SAROORNAGAR	05.00	06.45	01.45	OL	11KV INSULATER FALLOW ON KASARAM AT MARAGADHSI COLONY	-
1	HYD C	A.S.R.Raju Nagar	LIC Office	CEN	VII	17.38	19.20	01.42	EL,OL	UG Cable fault near SS	Arranged B/F on 11KV Sai Garden fdr

TSSPDCL - LMRC / Corporate office

Date: 12.02.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Wanaparthi	Peddmandadi	33KV	Wanaparthi	06.55	07.20	00.25	E/L	Due to Phase to Phase at 220KV Yard & Disc Metal Parts Damaged at Dargah at Wanaparthi	Wanaparthi	-
1	MDK	Shenigaram	Bejenki	33KV	Husnabad	05.50	08.45	02.55		BD due to Jumper cut		-