

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201									
5	RR(N)	82	407		2		2		2			
6	RR(E)	38	360									
7	Hyd	186	1014									
	Total	504	2929	0	2	0	2	0	2	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969									
2	NLG	150	948	2	1	2	1	2	1			
3	MDK	87	828		1		1		1			
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	2	2	2	2	2	2	0	0	
	Grand Total	908	6149	2	4	2	4	2	4	0	0	

TSSPDCL - LMRC / Corporate office

Date: 13.02.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Dirsenapally	Dirsenapally	11KV	Suryapet	07.30	09.30	02.00	E/L	11Kv Line Cut	-
1	MDK	Shalipet	Chennaipally	11KV	Medak	09.50	12.00	02.10		B/D DUE TO 11 KV JUMPER CUT	-
1	RR N	J D M Ss-I	NI T CO	11KV	Jeedimetla	13.48	15.00	01.12	BD	11Ab Cable Failure at vasantha chemical	-
2		J D M Ss-IV	Axies	11KV	Jeedimetla	05.40	06.55	01.15	BD	11kv Line Ground petroling no fount	-

TSSPDCL - LMRC / Corporate office

Date: 13.02.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	NLG	Suryapet	Yerkaram	33KV	Suryapet	10.40	12.50	02.10	E/L	33KV Breaker problem & Alternate supply arranged of 33Kv Nuthankal Feeder at 12:50Hrs	Yerkaram, Adivemula, R.C.Puram.	-
2		W.Kothapally	Thungathurthy	33KV	Suryapet	04.50	06.30	01.40	E/L	33Kv Jumper cut	Jellalpur, Thatipamula.	-