

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201									
5	RR(N)	82	407		3		3		3			
6	RR(E)	38	360		1		1		1			
7	Hyd	186	1014	4	1	3	1	3	1			1 No. 33KV Still
	Total	504	2929	4	5	3	5	3	5	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969	1	3	1	3	1	3			
2	NLG	150	948		2		2		2			
3	MDK	87	828									
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	1	5	1	5	1	5	0	0	
	Grand Total	908	6149	5	10	4	10	4	10	0	0	

TSSPDCL - LMRC / Corporate office

Date: 14.02.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Jadcherla	Janampet	11KV	Moosapet	08.45	12.35	03.50		11kv Jumper cut near Janampet	-
2		Jadcherla	Mallaboinpally	11KV	Ramanpadu	15.15	18.10	02.55		AB Switch fail near Jadcherla Road	-
3		Mahabubnagar	Nagaramgate	11KV	Koilsagar	09.00	10.00	01.00		11KV A B Switch Problem at Chinnarajmur (V)	-
1	NLG	Thimmareddy gudem	Thimmareddy gudem	11KV	Huzurnagar	03.00	06.00	03.00	E/L	Jumper cut	-
2		Phanigiri	Phanigiri AGL	11KV	Suryapeta	15.20	17.15	01.55	E/L	Line cut	-
1	RR N	Subash Nagar	Padma Nagar	11KV	Medchal	15.55	16.30	00.35	BD	No Fault	-
2		Medicity	Munirabad	11KV	Medchal	07.00	08.40	01.40	BD	No Fault	-
3		Gowdavelly	Basaragadi	11KV	Medchal	16.10	18.30	02.20	BD	11KV Pole damaged by Lorry at Basaragadi Back Feeding Arranged from 11KV IDA Feeder	-
1	RR E	Cherlapally-IV	Sai Nagar	11KV	Sainikpuri	06.30	08.30	02.00		Streetlight Pole wire cut & wire touched at Central Jail (AE/Foc Veera Swamy/Vijay)	-
1	HYD S	Kandikal Gate	Patel Nagar	11KV	III	15.45	17.10	01.25	EL,OL-Rph	Cable fault	Arranged B/F on 11KV Moin Bagh fdr

TSSPDCL - LMRC / Corporate office

Date: 14.02.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Palkonda	Kodur	33KV	Mahabubnagar	08.05	11.35	03.30	E/L& O/L	Tree Branches Fallen on the Line	Kodur	-
1	HYD N	132KV Erragadda	H.P.S (Idle)	33KV	Allwyn	00.27	Still		EL	Cable failure near H.P.S, Nalla Pochamma Temple	H.P.S (Idle)	---
2		132KV J.Hills	M.L.A Colony	33KV	Kalyan Ngr	02.23	02.31	00.08	OL-Bph	Cable fault near MCH Park	M.L.A Colony	Loads transferred onto 132KV J' Hills SS vai 33KV Asif Nagar Cbl
1	HYD S	220KV Ch.Gutta	Santosh Ngr-II (Idle)	33KV	Malakpet	05.57	17.17	11.20	EL,OL	Cable End Kit failed at Lucky Hotel, OYC Chowrasta	Santosh Ngr-II (Idle)	---
2		220KV Shi.Pally	Ch' Baradari	33KV	Malakpet	12.05	12.15	00.10	OL	---	Ch' Baradari	Loads transferred onto 33KV Shivarampally - Ch' Baradari OH line