

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201									
5	RR(N)	82	407									
6	RR(E)	38	360		1		1		1			
7	Hyd	186	1014		2		2		2			
	Total	504	2929	0	3	0	3	0	3	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969	1	1	1	1	1	1			
2	NLG	150	948		1		1		1			
3	MDK	87	828									
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	1	2	1	2	1	2	0	0	
	Grand Total	908	6149	1	5	1	5	1	5	0	0	

TSSPDCL - LMRC / Corporate office

Date: 23.02.18

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Kotha Molgara	Madigatla	11KV	Jadcherla	09.00	11.10	02.10		DTR Failed near Madigatla	No
1	NLG	Jalalpuram	Gottiparthu	11KV	Suryapet	8:00	10:30	2:30	E/L	Jumpur cut	No
1	RR E	Rajivswagru	Vishalandra	11KV	Saroor Nagar	13:50	14:48	0:58	OL	No visible fault	No
1	HYD S	Kanchanbagh	Riyasath Nagar	11KV	Charminar	00.17	02.50	02.33	All Indication	Incoming Cable burnt out at Naigra Masala	At 00:55Hrs partial feeder charged, 02:50Hrs arranged B/F on 11KV Omer Colony feeder
2		C.R.P.F	Omar Colony	11KV	Charminar	18:35	19:50	1:15	All Indication	O/G Cable fault at Omar Colony	Arranged B/F on 11KV Riyasath Nagar feeder

TSSPDCL - LMRC / Corporate office

Date: 23.02.18

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Kodangal	Dudyal	33KV	Mahabubnagar	13.05	17.25	04.20	E/L&O/L	33KV Jumper sanpped at 132KV SS Yard	Dudyal	No