

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201									
5	RR(N)	82	407		1		1		1			
6	RR(E)	38	360		3		3		3			
7	Hyd	186	1014		2		2		2			
	Total	504	2929	0	6	0	6	0	6	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969		1		1		1			
2	NLG	150	948									
3	MDK	87	828									
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	0	1	0	1	0	1	0	0	
	Grand Total	908	6149	0	7	0	7	0	7	0	0	

TSSPDCL - LMRC / Corporate office

Date: 24.02.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBN				NIL	NIL						-
2	NLG				NIL	NIL						-
3	MDK				NIL	NIL						-
4	RR S				NIL	NIL						-
5	RR N				NIL	NIL						-
6	RR E				NIL	NIL						-
7	HYD				NIL	NIL						-

TSSPDCL - LMRC / Corporate office

Date: 24.02.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Janampet	Moosapet	11kv	Jadcherla	12.15	13.20	01.05		Tree Follen On The 11 Kv Line Near Chakrapur(Vi)	-
1	RR N	Shemshiguda	Tulsivanam	11kv	KKP	19.30	21.30	02.00	EL&OL	11kv AB Cable Failure At yellamBanda Xroad	-
1	RR E	IDA Uppal	Metro	11kv	Habsiguda	05.20	06.10	00.50		11KV Disc failed near Neelima Organised Company at IDA Uppal	-
2		Moula-Ali	Mirzalaguda	11kv	Sainikpuri	10.10	11.02	00.52		11Kv line Jumper cut on Touched to Channel RFC Compound (L Insp Ravi)	-
3		Aushapur	Edulabad	11kv	KEESAR	18.00	19.00	01.00		Line patrolling but no visible fault and 11KV AB switch opened at Kothagudem	-
1	HYD S	Asmangadh	Saidabad Colony	11kv	VIII	03.00	04.26	01.26	EL	Cable damaged at Quadri Masjid	Arranged B/F on 11KV Laxmi Nagar feeder
2	HYD N	Bora Banda	SRT Nagar Market	11kv	IV	14.50	16.13	01.23	EL	AB Cable damaged at SRT Nagar Market	-----