

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201									
5	RR(N)	82	407		1		1		1			
6	RR(E)	38	360		2		2		2			
7	Hyd	186	1014		1		1		1			
	<b>Total</b>	<b>504</b>	<b>2929</b>	<b>0</b>	<b>4</b>	<b>0</b>	<b>4</b>	<b>0</b>	<b>4</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969	1	1	1	1	1	1			
2	NLG	150	948		3		3		3			
3	MDK	87	828		1		1		1			
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	<b>Total</b>	<b>404</b>	<b>3220</b>	<b>1</b>	<b>5</b>	<b>1</b>	<b>5</b>	<b>1</b>	<b>5</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>908</b>	<b>6149</b>	<b>1</b>	<b>9</b>	<b>1</b>	<b>9</b>	<b>1</b>	<b>9</b>	<b>0</b>	<b>0</b>	

TSSPDCL - LMRC / Corporate office

Date: 27.02.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Kosgi	Kosgi	33KV	Rural	15.42	16.15	00.33	E/L	Pole Bend & touched to the 11KV Line	Kosgi	Back Feeding From Dudyal 132KV SS Kodangal At 16:15Hrs

TSSPDCL - LMRC / Corporate office

Date: 27.02.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Nawabpet	Rudraram	11KV	Rural	09.15	11.00	01.45		11KV Wire Cut Near Ippatoor( V)	-
1	NLG	Mattapally	Sulthanpur thanda	11KV	Huzurnagar	18.13	21.08	02.55	EL	11 KV Line snapped At Sulthanpur thanda village	-
2		Penpahad	S.R Palem	11KV	Suryapet	21.00	06.00	09.00	EL	Insulator failed near Janareddy Nagar	-
3		Muppam	Muppam	11KV	Miryalaguda	06.15	09.20	03.05	EL	11KV pin insulator Failed	-
1	MDK	Seelampally	Seelampally	11KV	Medak	09.30	11.30	02.00		B/D Due to Jumper Cut	-
1	RR N	JDMSS-I	JTPL	11KV	Jeedimetla	03.30	05.05	01.35	BD	11kv line AB Cable failure near R R Plastic at phase-I Line	-
1	RR E	Mallapur 2	surya nagar	11KV	Habsiguda	02.49	04.32	01.43		11KV cable fail at Subhash nagar	-
2		Saketh	Saketh	11KV	Sainikpuri	13.46	14.35	00.49		11Kv Pin Insuletor failure on Blost on 11Kv line cut at Pochamma Temple Saibaba Nagar (LM Balaram)	-
1	HYD C	Indira Park	Gulshan Nagar	11KV	I	09.40	11.20	01.40	OL-R&Bph	HT Line snapped at Gulshan Nagar	(09:50 Hrs partial fdr charged)